



Solstice Development Services
HELE Power Station
Cost and Efficiency Report

June 2017

Executive summary

Background

Solstice Development Services (SDS) has been retained by ACA Low Emissions Technologies Ltd to investigate the case for High Efficiency Low Emission (HELE) power stations in Australia's future power generation mix.

SDS has engaged GHD Pty Ltd (GHD) to support this investigation by providing information on performance and costs for a generic HELE plant in Australia.

This information includes:

- Likely performance for a new plant under typical Australian conditions,
- A range of capital cost estimates for a new plant, considering Australian labour costs, as well as utilising lower cost equipment from China,
- Benchmarks of the cost estimate methodology against reported costs for similar plants built in the last decade.

This report contains the information developed by GHD.

Plant and performance

The base case HELE plant is a 650 MW (sent out), wet cooled single unit generator. The boiler is fuelled by black coal and a typical Hunter Valley specification has been used for modelling. Steam conditions are 275 barg and 604 °C for the high pressure steam and 59 barg and 604 °C for the intermediate pressure steam.

A dry cooling system was also modelled as an alternative. The performance figures for both at an ambient temperature of 25 °C are presented in Table 1.

Table 1 Summary of performance figures

| Parameter | Unit | Base case (wet cooling) | Dry cooling comparison case |
|----------------------------|--------|-------------------------|-----------------------------|
| Inputs and outputs | | | |
| Coal consumed | tph | 195.6 | 201.4 |
| Steam turbine output | MW | 675.5 | 678.8 |
| Auxiliary loads and losses | MW | 25.5 | 28.8 |
| Net (sent out) output | MW | 650.0 | 650.0 |
| CO ₂ emissions | tph | 505.3 | 520.3 |
| Heat rate | | | |
| Heat rate (net, LHV) | kJ/kWh | 8,396 | 8,646 |
| Efficiency (net, LHV) | % | 42.88 | 41.64 |
| Heat rate (net, HHV) | kJ/kWh | 8,704 | 8,963 |
| Efficiency (net, HHV) | % | 41.36 | 40.16 |

Capital costs

Preliminary cost estimates have been produced using Thermoflow's PEACE™ (Preliminary Engineering and Cost Estimation) software. This software uses a "factored cost" approach, which has recognised limitations on accuracy. The estimates are presented in Table 2.

Table 2 Summary of capital costs

| Cost categories | Base case (wet cooling) | Dry cooling comparison case |
|---|-------------------------|-----------------------------|
| Contractor's Internal Cost | US\$1,121.8 M | US\$1,162.1 M |
| Contractor's Soft & Miscellaneous Costs | US\$211.7 M | US\$224.9 M |
| Total - Contractor's Cost | US\$1,333.4 M | US\$1,387.0 M |
| Net Plant Output (MW) | 650 | 650 |
| Cost per kW - Contractor's | US\$2,051 | US\$2,134 |

The 'Contractor's Cost' is the cost to build the plant, and excludes additional costs incurred by the owner (e.g. project development, finance and legal fees, interest during construction).

At an exchange rate of AU\$1=US\$0.75, the 'Contractor's Cost' for the base case would be AU\$1.778b.

PEACE uses a number of cost multipliers to reflect the local cost of constructing a power station relative to the cost at the United States (US) reference location. The PEACE database contains default cost multipliers for different regions in the US as well as for various countries around the world. The default multipliers can be manually overridden by the user if there are better project specific figures available.

In addition to using the default Thermoflow cost factors for Australia, GHD has considered three alternative scenarios in order to assess the potential range of outcomes under different combinations of cost multiples. These three additional cases reflect consideration of:

1. A set of cost multipliers produced by WorleyParsons for a report published by CO2CRC for the Hunter Valley region of Australia¹ that include higher Australian labour costs,
2. Incorporation of a lower cost multiplier for 'Specialised Equipment' to reflect sourcing this equipment from China,
3. A combination of the above.

The costs for the alternative scenarios are shown in Table 3 and illustrate the potential cost savings from use of Chinese equipment.

¹ CO2CRC (et. al.) 2015, *Australian Power Generation Technology Report*

Table 3 Cost scenario results

| Cost categories | Base Case - PEACE default factors for Australia | Alternative 1 – WorleyParsons amended factors | Alternative 2 – Base case factors amended for Chinese sourcing | Alternative 3 – Combination of alternatives 1 and 2 |
|----------------------------|---|---|--|---|
| Total – Contractor's Cost | US\$1,333.4 M | US\$1,293.6 M | US\$1,143.7 M | US\$1,187.3 M |
| Net Plant Output (MW) | 650 | 650 | 650 | 650 |
| Cost per kW – Contractor's | US\$2,051 | US\$1,990 | US\$1,760 | US\$1,827 |
| Percentage of default cost | 100% | 97.0% | 85.8% | 89.1% |

Benchmarking

A benchmarking exercise has been undertaken to compare publicly available cost information for existing projects against the estimates produced by PEACE. The intention of this benchmarking exercise is to provide a level of confidence in the PEACE estimates presented in this report based on the error margins calculated against known projects.

A report published by the IEA Clean Coal Centre (IEACCC) in 2016 states that 164 HELE plants were built between 2010 and 2016 across China, Japan, the UK and the EU, of which 142 were in China².

Publicly available information for HELE projects constructed over the last decade has been identified and used for this benchmarking exercise. To compare the reported costs to the PEACE estimates, the published cost figures have been escalated to 2016 costs using the Producer Price Index for the country in which the plant is located.

It should be noted that the public information is often not specific in relation to the configuration of the plant, what the stated cost covers, and the reliability of the source. Some assumptions have been made to address these uncertainties and they are reflected in the results.

The results from this benchmarking exercise are presented in Figure 1, which shows the percentage deviation of the published costs against the PEACE estimate.

² Dr Malgorzata Wiatros-Motyka 2016, *An overview of HELE technology deployment in the coal power plant fleets of China, EU, Japan and USA*, IEACCC




Figure 1 Benchmark project deviation from PEACE estimate

The following key points are noted:

- Three of the largest negative outliers are for projects that have been undertaken in China,
- Three of the four positive outliers are for three similar projects undertaken in Taiwan, and all present similar error percentages (approx. 40-60% higher than the cost predicted by PEACE),
- The remaining positive outlier is for the first and only ultra-supercritical (USC) project carried out in the United States,
- 12 out of the 17 benchmark projects are within (or close to) $\pm 40\%$ accuracy.

The same benchmarking methodology was used to compare the PEACE estimate with the reported cost of Kogan Creek Power Station. The PEACE estimate was approximately 18% higher than the escalated reported figure.

Table of contents

| | | |
|-----|---|----|
| 1. | Introduction..... | 1 |
| 1.1 | Background..... | 1 |
| 1.2 | Purpose of this report..... | 1 |
| 1.3 | Scope and limitations..... | 1 |
| 1.4 | Assumptions | 2 |
| 1.5 | Acronyms and abbreviations | 3 |
| 2. | Base case model and cost estimate | 4 |
| 2.1 | Base model and results | 4 |
| 2.2 | Alternative dry cooling model..... | 6 |
| 2.3 | Preliminary cost estimate methodology | 7 |
| 2.4 | Cost multipliers and sensitivity cases | 8 |
| 2.5 | Preliminary capital cost estimate | 11 |
| 2.6 | Potential brownfield plant cost savings..... | 12 |
| 2.7 | Potential savings for carbon capture plant using Chinese sourced equipment..... | 14 |
| 3. | Benchmarking | 15 |
| 3.1 | Methodology | 15 |
| 3.2 | Results | 16 |
| 3.3 | Benchmark against CO2CRC APGT report..... | 18 |

Table index

| | | |
|----------|--|-----|
| Table 1 | Summary of performance figures | i |
| Table 2 | Summary of capital costs..... | ii |
| Table 3 | Cost scenario results | iii |
| Table 4 | Number of installed HELE units in China, Japan, EU, and US | 1 |
| Table 5 | Acronyms and abbreviations | 3 |
| Table 6 | Base case model key parameters | 4 |
| Table 7 | Siemens published operating USC plant conditions..... | 5 |
| Table 8 | Manjung 4 published USC steam conditions..... | 5 |
| Table 9 | Base case model technical characteristics | 6 |
| Table 10 | Dry cooling comparison | 7 |
| Table 11 | Thermoflow cost multipliers for Australia | 8 |
| Table 12 | WorleyParsons Hunter Valley Cost factors..... | 9 |
| Table 13 | PEACE equivalent cost multipliers of WorleyParsons factors..... | 9 |
| Table 14 | Thermoflow default China cost multipliers..... | 10 |
| Table 15 | Cost multiplier cases..... | 10 |

| | | |
|----------|--|----|
| Table 16 | Base cast cost estimate | 11 |
| Table 17 | Cost multiplier sensitivity case cost estimates..... | 11 |
| Table 18 | Dry cooling comparison case cost estimate | 12 |
| Table 19 | Potential brownfield plant cost savings..... | 12 |
| Table 20 | Potential carbon capture cost savings achieved with Chinese equipment..... | 14 |
| Table 21 | PEACE benchmarking results | 17 |
| Table 22 | Capital cost estimate benchmark against CO2CRC APGT report | 18 |

Figure index

| | | |
|----------|---|----|
| Figure 1 | Benchmark project deviation from PEACE estimate | iv |
| Figure 2 | Benchmark project deviation from PEACE estimate | 16 |

Appendices

- Appendix A – PEACE and STEAM PRO Results for the Base Case
- Appendix B – PEACE and STEAM PRO Results for the Dry Cooling Case
- Appendix C – Benchmarking Details

1. Introduction

1.1 Background

Solstice Development Services (SDS) has been retained by ACA Low Emissions Technologies Ltd to investigate the case for High Efficiency Low Emission (HELE) power stations in Australia's future power generation mix.

SDS has engaged GHD Pty Ltd (GHD) to support this investigation by providing information on performance and costs for a generic HELE plant in Australia. This report contains the information developed by GHD.

While the term *HELE* is sometimes used to refer to supercritical (SC) plants as well as ultra-supercritical (USC) plants, it is used in this report exclusively as the latter (USC). As such, wherever the term HELE is used in this report, it is referring to USC coal-fired power plants, which are broadly defined as having high pressure steam conditions above 250 bar and 580 °C.

As an indication of the progression and maturity of HELE technology globally, a table of HELE units installed across China, Japan, the EU and the US is presented below. It should be noted that the numbers presented in Table 4 are the number of units installed, not the number of unique locations or power plants.

Table 4 Number of installed HELE units in China, Japan, EU, and US³

| | China | EU | Japan | US | Total |
|--------------|------------|-----------|-----------|----------|------------|
| Pre-2000 | 0 | 1 | 8 | 0 | 9 |
| 2000-2009 | 40 | 3 | 13 | 0 | 56 |
| 2010-2016 | 142 | 18 | 3 | 1 | 164 |
| Total | 182 | 22 | 24 | 1 | 229 |

1.2 Purpose of this report

The purpose of this report is to provide objective estimates of the performance and capital cost of a HELE plant, and to benchmark those costs against publically available costs for HELE plants recently constructed overseas.

1.3 Scope and limitations

The scope of the investigation was to:

- Calculate the performance of a HELE plant using current technology and operating in Australia on black coal,
- Provide an estimate of the cost of constructing the plant in Australia using the PEACE output from STEAM PRO power plant modelling software,
- Comment on the potential cost reduction for a "brownfield" plant,
- Benchmark the PEACE estimated figures against publically available cost information for overseas plants.

The plant configuration was to be consistent with previous publically available studies to provide transparency and consistency in interpretation. No specific site was nominated, but it would be located in an area where there are aged existing coal-fired stations. As such there would be

³ Dr Malgorzata Wiatros-Motyka 2016, *An overview of HELE technology deployment in the coal power plant fleets of China, EU, Japan and USA*, IEACCC

existing infrastructure and the opportunity for the new HELE plant to replace older coal-fired plants.

The performance and cost information has only considered the plant within the power station fence line. The plant is based on current technology operating at USC steam conditions.

GHD does not have access to the PEACE database and cannot comment on the accuracy of the cost estimates. Benchmark costs have been included to provide comparative references.

This report has been prepared by GHD for SDS and may only be used and relied on by SDS for the purpose agreed between GHD and the SDS as set out in this section of this report.

GHD otherwise disclaims responsibility to any person other than SDS arising in connection with this report. GHD also excludes implied warranties and conditions, to the extent legally permissible.

The services undertaken by GHD in connection with preparing this report were limited to those specifically detailed in this report and are subject to the scope limitations set out in this report.

The opinions, conclusions and any recommendations in this report are based on conditions encountered and information reviewed at the date of preparation of the report. GHD has no responsibility or obligation to update this report to account for events or changes occurring subsequent to the date that the report was prepared.

The opinions, conclusions and any recommendations in this report are based on assumptions made by GHD described in this section of this report. GHD disclaims liability arising from any of the assumptions being incorrect.

GHD has not been involved in the preparation of Solstice Development Service's Report (SDS Report) and has had no contribution to, or review of the SDS Report other than in this report. GHD shall not be liable to any person for any error in, omission from, or false or misleading statement in, any other part of the SDS Report.

GHD has prepared the preliminary cost estimate set out in Section 2.3 to 2.6 of this report ("Cost Estimate") using information reasonably available to the GHD employee(s) who prepared this report; and based on assumptions and judgments made by GHD.

The Cost Estimate has been prepared for the purpose of informing debate and must not be used for any other purpose.

The Cost Estimate is a preliminary estimate only. Actual prices, costs and other variables may be different to those used to prepare the Cost Estimate and may change. Unless as otherwise specified in this report, no detailed quotation has been obtained for actions identified in this report. GHD does not represent, warrant or guarantee that the works or project can or will be undertaken at a cost which is the same or less than the Cost Estimate.

1.4 Assumptions

This report is based on the following assumptions:

- The HELE plant will only be required to operate as a base load power supplier. No features or costs have been included for other modes of operation,
- Australian low sulphur black coal will be used as fuel and a Flue Gas Desulphurisation system will not be required,
- A suitable, flat site with favourable geotechnical conditions is available,
- Existing environmental standards will be applicable. The site will be located in an area with aged existing power stations and with suitable planning requirements,

- Suitable off-site infrastructure/utilities will be located nearby,
- Information in reports quoted by GHD is correct and accurate. GHD has not tried to verify the accuracy of this information,
- Information sourced from public sources for benchmarking is suitably correct. GHD has not tried to verify the accuracy of this information, other than to try to obtain multiple references (which may be from the same source).

1.5 Acronyms and abbreviations

The following is a list of acronyms or abbreviations that have been used in this report.

Table 5 Acronyms and abbreviations

| Acronym/abbreviation | Definition |
|----------------------|---|
| Bara | Absolute pressure in bar |
| Barg | Gauge pressure in bar |
| CO2CRC | CO2CRC Ltd |
| ESP | Electrostatic Precipitators |
| HELE | High Efficiency Low Emissions |
| HP | High pressure |
| IDC | Interest During Construction |
| IP | Intermediate pressure |
| kJ | kilojoule |
| kWh | kilowatt hour |
| m | metre |
| MW | Megawatt |
| PEACE | Preliminary Engineering and Cost Estimation |
| PPI | Producer Price Index |
| SC | Supercritical |
| tph | Tonnes per hour |
| USC | Ultra-supercritical |
| USGC | United States Gulf Coast |

2. Base case model and cost estimate

2.1 Base model and results

The base case model has been developed with the key parameters presented in Table 6.

Table 6 Base case model key parameters

| Parameter | Value | Basis / comment |
|----------------------------|---|---|
| Output | 650 MW (net) | Selected to match the USC plant size used in the Australian Power Generation Technology Report ⁴ . Considered to be an appropriate size for a HELE plant. Compatibility with Australian electricity grid has not been assessed because no specific location has been considered. The size selected is smaller than Kogan Creek single generation unit. |
| Cooling type | Wet cooling (natural draft cooling tower) | Many existing baseload coal-fired power plants in Australia have access to fresh water for wet cooling. It is assumed that that water currently being used by existing power stations will be transferred to the HELE plant and the existing plants retired. This aligns with the HELE objectives of achieving a highly efficient plant, it is considered reasonable that a site will be selected that provides wet cooling capability. An alternative of air cooling is considered in Section 2.2. |
| HP/IP steam temperature | 604 °C/604 °C | Consistent with the CO2CRC steam conditions and within typical parameters for HELE technology (as confirmed by review of publicly available details of operational HELE plants – refer Table 7). |
| HP/IP steam pressure | 276 bara/60 bara | HP steam pressure consistent with CO2CRC condition (275 barg). IP steam pressure selected as default by STEAM PRO and confirmed appropriate via review of published operating plant conditions (refer Table 8 for one example). |
| Nominal location | Hunter Valley | Consistent with the nominal location selected for the CO2CRC report and considered to be an appropriate location for a HELE plant to replace existing aging generators in the area. |
| Nominal fuel specification | Hunter Valley coal (from Thermoflow fuel library) | Consistent with a potential location and considered to be representative of Australian black coal. |

⁴ CO2CRC (et. al.) 2015, *Australian Power Generation Technology Report*

Table 7 Siemens published operating USC plant conditions⁵

| Plant | Country | Power output | Main steam | Reheat steam | Commercial operation |
|----------------|-------------|--------------|------------------|--------------|----------------------|
| Isogo | Japan | 1 x 600 MW | 251 bar / 600 °C | 610 °C | 2001 |
| Yuhuan | China | 4 x 1000 MW | 262 bar / 600 °C | 600 °C | 2007 |
| Wai Gao Qiao 3 | China | 2 x 1000 MW | 270 bar / 600 °C | 600 °C | 2009 |
| Westfalen | Germany | 2 x 800 MW | 275 bar / 600 °C | 610 °C | 2011 |
| Eemshafen | Netherlands | 2 x 800 MW | 275 bar / 600 °C | 610 °C | 2012 |
| Lunen | Germany | 1 x 800 MW | 270 bar / 600 °C | 610 °C | 2012 |
| Mainz | Germany | 1 x 800 MW | 273 bar / 600 °C | 610 °C | 2013 |

Table 8 Manjung 4 published USC steam conditions⁶

| Parameter | Value |
|-------------------------------|-----------|
| Main steam flow | 3226 tph |
| Superheater outlet pressure | 282.4 bar |
| Superheater steam temperature | 600 °C |
| Feedwater temperature | 304 °C |
| Reheater steam flow | 2687 tph |
| Reheater steam pressure | 60.6 bar |
| Reheater steam temperature | 605 °C |
| Reheater inlet temperature | 364 °C |

Using the parameters detailed in Table 6, a thermodynamic model was developed in STEAM PRO. STEAM PRO is part of an internationally recognised suite of power generation modelling programmes developed by Thermoflow Inc⁷. STEAM Pro has been developed for Rankin cycle systems such as coal-fired power stations. Software updates are issued annually.

The key technical characteristics of this model are presented in Table 9. Detailed modelling results are included in Appendix A.

⁵ Siemens AG 2008, *USC Steam Turbine technology for maximum efficiency and operational flexibility*, POWER-GEN Asia 2008

⁶ <http://www.powerengineeringint.com/articles/print/volume-20/issue-8/power-report/manjung-4-an-ultra-supercritical-first-in-southeast-asia.html>

⁷ <https://www.thermoflow.com/>

Table 9 Base case model technical characteristics

| Parameter | Unit | Value |
|--|--------|-------|
| Ambient conditions | | |
| Reference ambient temperature (dry bulb) | °C | 25 |
| Reference ambient relative humidity | % | 60 |
| Elevation | m | 111 |
| Ambient pressure | bara | 1 |
| Steam conditions | | |
| HP steam temperature | °C | 604 |
| HP steam pressure | bara | 276 |
| IP (reheat) steam temperature | °C | 604 |
| IP (reheat) steam pressure | bara | 60 |
| Inputs and Outputs | | |
| Coal consumed | tph | 195.6 |
| Steam turbine output | MW | 675.5 |
| Auxiliary loads and losses | MW | 25.5 |
| Net electricity (sent out) | MW | 650.0 |
| CO ₂ emissions | tph | 505.3 |
| Heat rate | | |
| Heat rate (net, LHV) | kJ/kWh | 8,396 |
| Efficiency (net, LHV) | % | 42.88 |
| Heat rate (net, HHV) | kJ/kWh | 8,704 |
| Efficiency (net, HHV) | % | 41.36 |

2.2 Alternative dry cooling model

As noted in Table 6, wet cooling has been selected for the base case model. In the event that a nominated plant location does not have a water supply sufficient to enable wet cooling, dry cooling or hybrid cooling (wet and dry) technologies will need to be used. To assess this, and to properly understand the impact of selecting wet cooling for the base case model, a comparison case using dry air cooled condensers has been developed. The key results from this comparison model are presented alongside the base case parameters in Table 10.

It is noted that the design parameters and design conditions (e.g. ambient conditions, steam temperatures/pressures, etc.) for the comparison case are the same as for the base case.

Table 10 shows that wet cooling achieves lower auxiliary loads and a higher efficiency than the dry cooling alternative. A wet cooled HELE plant will use less water per unit of electrical output than current coal-fired power stations in Australia. A dry cooled system will use significantly less water, but will have slightly lower efficiency.

Table 10 Dry cooling comparison

| Parameter | Unit | Base case (wet cooling) | Dry cooling comparison case |
|---------------------------|--------|-------------------------|-----------------------------|
| Inputs and outputs | | | |
| Coal consumed | tph | 195.6 | 201.4 |
| Steam turbine output | MW | 675.5 | 678.8 |
| Aux. loads and losses | MW | 25.5 | 28.8 |
| Net (sent out) output | MW | 650.0 | 650.0 |
| CO ₂ emissions | tph | 505.3 | 520.3 |
| Heat rate | | | |
| Heat rate (net, LHV) | kJ/kWh | 8,396 | 8,646 |
| Efficiency (net, LHV) | % | 42.88 | 41.64 |
| Heat rate (net, HHV) | kJ/kWh | 8,704 | 8,963 |
| Efficiency (net, HHV) | % | 41.36 | 40.16 |

2.3 Preliminary cost estimate methodology

Preliminary cost estimation has been carried out using Thermoflow's PEACE™ (Preliminary Engineering and Cost Estimation) software. This software uses a 'factored cost' approach, which has recognised limitations on accuracy. This software is ideal for producing high level estimates for comparative and screening purposes, however is not intended to produce robust final cost figures for project execution. It is considered suitable for this report due to the generic nature of the estimate.

The methodology used in PEACE to develop the high level cost estimate is:

- Thermodynamic model developed using STEAM PRO and user supplied inputs as detailed in Section 2.1,
- STEAM PRO initialisation of PEACE-specific variables (i.e. design selections that have no bearing on the thermodynamic model developed in STEAM PRO but are used in the PEACE estimate process, such as type and size of on-site storage or buildings),
- User adjustment of PEACE specific variables (if known),
- Development of preliminary engineering and cost estimate using PEACE based on Thermoflow's reference cost information for low cost US-based reference plants in the US Gulf Coast (USGC) area,
- Adjustment of cost estimate from US-based reference location to a project-specific location using cost multipliers – this is discussed in detail in Section 2.4.

Note that all costs throughout this process have been analysed and are presented in US\$ unless stated otherwise.

PEACE develops the preliminary cost estimate according to the following major categories:

- Contractor's internal costs (i.e. the cost to build the plant, including sub-categories such as 'Specialised Equipment', 'Other Equipment', 'Civil Works', 'Mechanical Works' etc.),
- Contractor's soft and miscellaneous costs (e.g. contractor's contingencies, profit, contractor's fee),
- Owner's soft and miscellaneous costs (e.g. development costs, permits, legal and financial costs, interest during construction).

To be consistent with existing industry publications, costs presented in this report are 'Contractor's Costs' and therefore do not include the 'Owner's soft and miscellaneous costs' listed above (unless stated otherwise).

2.4 Cost multipliers and sensitivity cases

PEACE uses a number of cost multipliers to reflect the local cost of constructing a power station relative to the cost at the US reference location. The PEACE database contains default cost multipliers for different regions in the US as well as for various countries around the world. The user can manually override the default multipliers if there is better project specific figures available.

Thermoflow's default cost multipliers for Australia are presented in Table 11.

Table 11 Thermoflow cost multipliers for Australia

| Cost categories | Cost category definition | Australia cost multiplier |
|-------------------------|--|---------------------------|
| 'Specialised Equipment' | Includes items that are typically manufactured or engineered by a relatively small number of specialised firms worldwide. These items are likely to be imported if the project is in a country with a less developed manufacturing industry. Examples are boilers, steam turbines, transformers etc. | 1.3 |
| 'Other Equipment' | Includes equipment commonly used in a wide range of industries and is typically manufactured by many firms in many countries. These items are less likely to be imported if the project is in a country with some industrial base. | 1.3 |
| 'Commodities' | Includes basic materials such as common pipes, concrete etc. These are the least likely to be imported if the project is in a country with some level of development. | 1.3 |
| 'Labour Cost' | A multiplier that combines factors for productivity and hourly wages. A multiplier of 2.025 implies that it will cost 102.5% more to complete the same work in comparison to the reference site. | 2.025 |

GHD has considered three alternative scenarios in order to assess the potential range of outcomes under different combinations of cost multiples. These alternative scenarios are:

1. Cost multipliers developed by WorleyParson for the CO2CRC Report,
2. Incorporation of a lower cost multiplier to reflect the lower cost of "Specialised Equipment" from China,
3. A combination of scenario 1 and 2.

2.4.1 WorleyParsons Regional Cost Study

For the CO2CRC report⁸, a regional cost study was carried out by WorleyParsons to develop a set of cost factors for converting from a USGC cost basis to an Australian cost basis, as is required here. The most relevant output of the WorleyParsons study to the current work is the table shown in Table 12, displaying cost factors to convert from USGC reference costs to Hunter Valley costs.

⁸ CO2CRC (et. al) 2015, *Australian Power Generation Technology Report*

Table 12 WorleyParsons Hunter Valley Cost factors⁹

| Discipline | Hunter Valley vs. USGC | | | Currency exchange rate (A\$:US\$) |
|------------------------------|----------------------------|------------------|----------------------|-----------------------------------|
| | Labour productivity factor | Crew rate factor | Material cost factor | |
| Civil | 1.40 | 1.49 | 1.20 | 1.30 |
| Electrical bulks | 1.40 | 1.52 | 1.16 | 1.30 |
| Electrical equipment | 1.40 | 1.70 | 1.08 ^a | 1.30 |
| Insulation | 1.40 | 1.65 | 1.02 | 1.30 |
| Instrumentation and controls | 1.40 | 1.70 | 1.08 ^a | 1.30 |
| Mechanical equipment | 1.40 | 1.87 | 1.08 ^a | 1.30 |
| Piping and valves | 1.40 | 1.80 | 1.07 | 1.30 |
| Concrete | 1.40 | 1.50 | 1.50 | 1.30 |
| Structural steel | 1.40 | 1.55 | 1.13 ^b | 1.30 |

a: Based on US costs (inclusive of domestic freight), modified to include overseas freight at 8%

b: Based on US costs (inclusive of domestic freight), modified to include overseas freight at 8% and import duty at 5%

To use these figures as a benchmark against Thermoflow's built-in Australian cost multipliers it is necessary to convert them from discipline specific factors (which are not used by Thermoflow) to the four categories presented in Table 11.

It is noted that in addition to providing discipline specific crew rate factors as seen in Table 12, WorleyParsons calculated a *weighted average crew rate* based on a typical distribution of man-hours by crew for a project of this kind. For the Hunter Valley, WorleyParsons reported this weighted average crew rate cost factor as 1.73¹⁰.

Using the above information, PEACE equivalent costs multipliers have been developed as presented in Table 13.

Table 13 PEACE equivalent cost multipliers of WorleyParsons factors

| Cost categories | PEACE equivalent cost multipliers | Methodology for calculating equivalent factor |
|-------------------------|-----------------------------------|--|
| 'Specialised Equipment' | 1.08 | Calculated as the average of the electrical equipment, instrumentation and controls, mechanical equipment, and piping and valves line items. |
| 'Other Equipment' | 1.08 | As for 'Specialised Equipment'. |
| 'Commodities' | 1.20 | Calculated as the average of civil, electrical bulks, insulation, concrete, and structural steel line items. |
| 'Labour Cost' | 2.422 | Weighted average crew rate (1.73) multiplied by productivity factor (1.4) = 2.422. |

⁹ CO2CRC (et. al) 2015, *Australian Power Generation Technology Report*, Table 93

¹⁰ CO2CRC (et. al) 2015, *Australian Power Generation Technology Report*, Table 96

2.4.2 Chinese equipment cost multipliers

The use of cost multipliers based on procurement of Chinese equipment has been considered as a sensitivity case. Thermoflow's default cost multipliers for China are presented in Table 14.

Table 14 Thermoflow default China cost multipliers

| Cost categories | Thermoflow default China cost multipliers |
|-------------------------|---|
| 'Specialised Equipment' | 1.00 |
| 'Other Equipment' | 0.65 |
| 'Commodities' | 0.70 |
| 'Labour Cost' | 0.54 |

In incorporating the procurement of Chinese equipment into an Australian project, the following was considered:

- Chinese cost multipliers for 'Other Equipment', 'Commodities', and 'Labour Cost' are not applicable as they will apply to a Chinese project only,
- Thermoflow's default China 'Specialised Equipment' multiplier of 1.0 indicates that it would cost the same to manufacture specialised equipment in China as it would in the USGC. At the same time, Thermoflow's 'Other Equipment' and 'Commodities' multipliers of 0.65 and 0.7 respectively would indicate that manufacturing costs are lower in China than in the USGC, as would be expected. Given the prevalence of 'Specialised Equipment' manufacturing capability in China, it is considered that a more appropriate factor for 'Specialised Equipment' would be 0.7,
- In their study, WorleyParsons added 8% overseas freight cost to the USGC 'Specialised Equipment' cost in order to buy US equipment and ship to Australia. If this methodology is applied to procurement of Chinese equipment, the resultant 'Specialised Equipment' cost multiplier would be approximately 0.8.

2.4.3 Summary of cost multiplier sensitivity cases

Based on the information presented in the preceding sections, a set of cost multiplier cases have been developed, as shown in Table 15.

Table 15 Cost multiplier cases

| Cost categories | Thermoflow default Australia | WorleyParsons Hunter Valley | Thermoflow default, Chinese Specialised Equipment | WorleyParsons, Chinese Specialised Equipment |
|-------------------------|------------------------------|-----------------------------|---|--|
| 'Specialised Equipment' | 1.3 | 1.08 | 0.8 | 0.8 |
| 'Other Equipment' | 1.3 | 1.08 | 1.3 | 1.08 |
| 'Commodities' | 1.3 | 1.2 | 1.3 | 1.2 |
| 'Labour Cost' | 2.025 | 2.422 | 2.025 | 2.422 |

2.5 Preliminary capital cost estimate

2.5.1 Base case cost estimate

A base case cost estimate has been developed using the STEAM PRO model detailed in Table 6 and Table 9 and the Thermoflow default Australian cost multipliers presented in Table 15. The results from this process are presented in Table 16.

Table 16 Base cast cost estimate

| Cost category | Cost (US\$) |
|---|----------------------|
| Contractor's Internal Cost | US\$1,121.8 M |
| Contractor's Soft & Miscellaneous Costs | US\$211.7 M |
| Contractor's Cost | US\$1,333.4 M |
| Net Plant Output (MW) | 650 |
| Cost per kW - Contractor's | US\$2,051 |

The 'Contractor's Cost' is the cost to build the plant, and excludes additional costs incurred by the owner (e.g. project development, finance and legal fees, interest during construction).

Note that these costs are all in US\$. At an exchange rate of AU\$1=US\$0.75 the Contractor's Cost would be AU\$1,778b.

2.5.2 Cost multiplier scenarios

The cost multiplier scenarios presented in Table 15 have been used to develop the cost estimate results presented in Table 17.

Table 17 Cost multiplier sensitivity case cost estimates

| Cost categories | Thermoflow default Australia | WorleyParsons Hunter Valley | Thermoflow default, Chinese Specialised Equipment | WorleyParsons, Chinese Specialised Equipment |
|---|------------------------------|-----------------------------|---|--|
| Contractor's internal cost | US\$1,121.8 M | US\$1,070.9 M | US\$950.8 M | US\$975.2 M |
| Contractor's Soft & Miscellaneous Costs | US\$211.7 M | US\$222.7 M | US\$192.9 M | US\$212.1 M |
| Contractor's Cost | US\$1,333.4 M | US\$1,293.6 M | US\$1,143.7 M | US\$1,187.3 M |
| Net Plant Output (MW) | 650 | 650 | 650 | 650 |
| Cost per kW - Contractor's | US\$2,051 | US\$1,990 | US\$1,760 | US\$1,827 |
| Percentage of default cost | 100% | 97.0% | 85.8% | 89.1% |

The figures indicate that the costs calculated using the default figures and those in the WorleyParsons scenario are similar. Obtaining lower cost 'Specialised Equipment' from China may result in a 10-15% lower cost.

2.5.3 Dry cooling comparison

To consider the impact of dry cooling on the cost of a HELE project, a PEACE estimate was developed using the methodology detailed in the preceding sections and the dry cooling comparison model detailed in Section 2.1. The results of this exercise are presented in Table 18 against the base case cost estimate. Both of these estimates have been developed using the Thermoflow default cost multipliers for Australia.

Table 18 Dry cooling comparison case cost estimate

| Cost categories | Base case (wet cooling) | Dry cooling comparison case |
|---|-------------------------|-----------------------------|
| Contractor's Internal Cost | US\$1,121.8 M | US\$1,162.1 M |
| Contractor's Soft & Miscellaneous Costs | US\$211.7 M | US\$224.9 M |
| Contractor's Cost | US\$1,333.4 M | US\$1,387.0 M |
| Net Plant Output (MW) | 650 | 650 |
| Cost per kW - Contractor's | US\$2,051 | US\$2,134 |

The dry cooled power station would cost approximately 4% more than a wet cooled plant with the same net output.

2.6 Potential brownfield plant cost savings

An assessment was undertaken to consider the possible cost savings that may be achieved if a new HELE plant is developed at an existing power plant location. It is envisaged that cost savings may be achievable in areas such as:

- Use of existing common infrastructure (buildings, roads, services, etc.),
- Reduction of cost from repurposing existing equipment (e.g. coal handling, stockpile),
- Use of existing ancillary equipment (e.g. black start generators).

To make this high level assessment, items in the PEACE cost estimate for the base case model were attributed one of the three following potential savings characteristics:

- 0% savings – no benefit of brownfield plant over greenfield plant,
- 50% savings – some cost savings achievable,
- 100% savings – cost can be mostly or totally negated.

The areas identified as presenting potential savings are detailed in Table 19. It should be noted that only areas attributed with 50% or 100% potential savings have been listed.

This assessment has been carried out using the base case model and the default Thermoflow Australia cost multipliers.

Table 19 Potential brownfield plant cost savings

| Area | Potential cost saving | Value of saving |
|--------------------------------|-----------------------|-----------------|
| Specialised equipment | | |
| Transmission voltage equipment | 50% | US\$7,355,000 |
| Other equipment | | |
| Demineralized Water tank | 50% | US\$32,000 |
| Raw Water tank | 50% | US\$32,000 |

| | | |
|--|-------------|-----------------------|
| Neutralized Water tank | 50% | US\$22,000 |
| Acid Storage tank | 50% | US\$5,000 |
| Caustic Storage tank | 50% | US\$5,000 |
| Dedicated Fire Protection Water Storage tank | 50% | US\$125,000 |
| Station/Instrument Air Compressors | 50% | US\$508,000 |
| Emergency/Black Start Gensets | 100% | US\$17,616,000 |
| Coal handling equipment | 50% | US\$15,334,000 |
| Ash handling equipment | 50% | US\$2,794,000 |
| Civil | | |
| Site work (e.g. clearing, grading, drainage, etc.) | 50% | US\$10,806,000 |
| Excavation and backfill | 50% | US\$2,456,000 |
| Roads, parking, walkways | 50% | US\$572,000 |
| Buildings | | |
| Admin, control room, warehouse | 50% | US\$1,422,000 |
| Guard house | 100% | US\$37,000 |
| Owner's soft costs | | |
| Permits, licenses, fees | 50% | US\$13,334,000 |
| Legal and financial costs | 50% | US\$13,334,000 |
| Project admin and developer's fee | 50% | US\$6,667,000 |
| Total | 5.8% | US\$92,456,000 |

This preliminary assessment indicates there is likely to be only a small savings (approx. 6%) in capital cost due reuse of existing facilities if a HELE plant was to be constructed near an existing power station. This figure also assumes there are no additional costs due to constraints or limitations caused by any existing infrastructure.

Any potential savings or avoided costs in infrastructure outside the power station (existing fuel supply, water supply, transmission system, roads, etc.) have not been considered in this assessment. These are generally considered to be included in any lower operational cost for those services (e.g. the cost of coal).

The potential savings presented above are proportional to the value of the project, and within the accuracy of the estimate, are therefore generally scalable with plant size. The scalability of these savings will be limited by the overall scale of the existing infrastructure in comparison to the scale of the new plant being built. For example, coal handling infrastructure of an existing 650 MW plant is not likely to be sufficient for a new build 1000 MW plant, and therefore the achievable savings will not scale proportionally.

2.7 Potential savings for carbon capture plant using Chinese sourced equipment

The majority of this report excludes consideration of a carbon capture plant as part of the HELE model. This subsection alone considers the cost and technical implications of inclusion of a carbon capture plant, in particular with regards to the scale of cost savings that may be achieved by sourcing Chinese specialised equipment.

The factors considered by the modified STEAM PRO model are:

- Additional steam loads and cooling loads of the carbon capture system,
- Additional parasitic loads,
- Cost of the carbon capture system using Australian cost factors,
- Potential cost savings that may be achieved on the basis that the specialised equipment components of the carbon capture plant can be sourced from China at the same relative cost as the remainder of the HELE plant.

The following limitations apply to the modelling undertaken for this exercise:

- The carbon capture model in STEAM PRO is not intended to serve as a detailed chemical and thermodynamic model of the process. Rather, the model, together with user-defined inputs, provides an estimate of the total auxiliary power, heat consumption, and cooling duty required by the process, and its impact on the overall combined cycle,
- The model does not consider the storage or disposal of the captured carbon,
- The cost estimates developed for the carbon capture plant are indicative only and are used exclusively to develop an order-of-magnitude estimate of the cost savings that may be achieved if specialised equipment can be sourced from China at a reduced cost.

The STEAM PRO model has been developed from the base case model (described in Section 2.1) using the following methodology:

- Base case model parameters used (refer Section 2.1),
- Net plant output maintained at 650 MW,
- Carbon capture plant added using STEAM PRO default values (assumes 90% effective carbon capture from flue gas),
- Indicative cost estimates developed using PEACE using cost factors detailed in Section 2.4.

The results from this process are shown in Table 20.

Table 20 Potential carbon capture cost savings achieved with Chinese equipment

| Item | Thermoflow default Australian cost factors | Thermoflow default, Chinese Specialised Equipment | Percent saving achieved |
|-----------------------------|--|---|-------------------------|
| Contractor's cost (US\$/kW) | US\$3,859 | US\$3,185 | 17% |

3. Benchmarking

A benchmarking exercise has been undertaken to compare publicly available cost information for existing projects against the estimates produced by PEACE. One recently announced, but not constructed, plant has also been included. The intention of this benchmarking exercise is to provide a level of confidence in the PEACE estimates presented in this report based on the error margins calculated against known projects.

3.1 Methodology

Publicly available information for existing projects has been identified and used for this benchmarking exercise in the following way:

- Plant identified and confirmed to be based on HELE technology (i.e. USC steam conditions),
- Relevant available information recorded (size, location, year of operation),
- Cost information recorded if available, along with pertinent details required for benchmarking (i.e. reference year for cost information, currency of reported cost),
- Reported cost corrected from reported cost year to 2016 using the Producer Price Index (PPI) ratio for the country in which the plant is located between the reported year and 2016,
- Reported cost (corrected to 2016) converted from reported currency to US\$ using the exchange rate as of April 2017.

Kogan Creek Power Station has also been included in this benchmarking exercise. Although it does not operate at USC conditions, it is the only coal-fired plant of similar size and technology built in Australia in the past decade.

Estimates have been developed using STEAM PRO and PEACE to compare to these benchmarked figures according to the following methodology:

- Base case model (as detailed in Section 2.1) adjusted to match the reported unit size, number of units, and location (all design parameters have been kept consistent with the base case model due to the lack of consistent comprehensive plant details across the benchmark projects),
- Cost multipliers (as discussed in 2.4) adjusted to the PEACE default values for that project location),
- Preliminary cost estimate produced by PEACE and recorded for comparison against publicly available information.

This process makes a number of assumptions which must be considered in the interpretation of the results. Many of these assumptions must be made due to the lack of comprehensive information available for the projects which would be required to improve the granularity of the process. These include:

- Plant configuration of all benchmark projects is assumed to be the same as the base case model developed for this exercise. This includes the cooling type (natural draft wet cooling tower has been assumed), emissions control technologies (electrostatic precipitators (ESP) have been used for particulate control), and no flue gas desulphurisation has been included as is consistent with Australian projects) and several others,

- It is assumed that the reported cost is the Owner's total cost (including Owner's fees such as Interest During Construction (IDC)), and therefore the comparison estimates developed using PEACE also include Owner's costs,
- It is assumed that PPI rates in the country of construction (rather than, for example, the country of equipment supply) are applicable to the project in order to correct the reported costs to a 2016 cost basis.

3.2 Results

The results from this process are presented in Table 21. A more detailed version of this results spreadsheet is provided in Appendix C, including information used to produce the final figures used in the benchmarking exercise (such as PPI values, reference year for reported cost figures, exchange rates etc.).

Figure 2 shows one of the key results from this exercise – the deviation of the benchmark projects from the PEACE preliminary cost estimate. In this figure, a positive percentage indicates that the benchmark project reported a cost that was higher than the PEACE estimate by that percentage. Similarly, a negative percentage indicates that the reported cost was lower than predicated by PEACE.




Figure 2 Benchmark project deviation from PEACE estimate

Table 21 PEACE benchmarking results

| Publicly available plant details | | | | | | | PEACE estimate | | |
|---|-------------|----------------|---------|-----------------|-------------------|-----------------|-------------------|-----------------|--|
| Plant Name | Location | Unit size (MW) | # units | Plant size (MW) | Cost in 2016 US\$ | US\$ million/MW | Plant cost (US\$) | US\$ million/MW | Benchmark project deviation from PEACE |
| Linkou Power Station | Taiwan | 800 | 3 | 2,400 | US\$5,284 M | \$2.2 | US\$3,680 M | \$1.5 | 44% |
| Talin Power Station | Taiwan | 800 | 2 | 1,600 | US\$4,130 M | \$2.6 | US\$2,510 M | \$1.6 | 65% |
| Shenao Power Station | Taiwan | 800 | 2 | 1,600 | US\$3,773 M | \$2.4 | US\$2,510 M | \$1.6 | 50% |
| Maasvlakte 3 Power Plant | Netherlands | 1,100 | 1 | 1,100 | US\$1,098 M | \$1.0 | US\$1,920 M | \$1.7 | -43% |
| Mannheim Power Plant | Germany | 912 | 1 | 912 | US\$1,263 M | \$1.4 | US\$1,670 M | \$1.8 | -24% |
| Wai Gao Qiao 3 Power Plant | China | 1,000 | 2 | 2,000 | US\$1,296 M | \$0.6 | US\$2,280 M | \$1.1 | -43% |
| Westfalen Units D and E | Germany | 800 | 2 | 1,600 | US\$2,527 M | \$1.6 | US\$2,840 M | \$1.8 | -11% |
| John W. Turk, Jr. Power Plant | America | 600 | 1 | 600 | US\$1,695 M | \$2.8 | US\$1,060 M | \$1.8 | 60% |
| Huaibei Pingshan Power Plant | China | 660 | 2 | 1,320 | US\$791 M | \$0.6 | US\$1,630 M | \$1.2 | -51% |
| Eemshaven Power Plant | Netherlands | 800 | 2 | 1,600 | US\$2,086 M | \$1.3 | US\$2,800 M | \$1.8 | -26% |
| Safi Power Plant | Morocco | 693 | 2 | 1,386 | US\$2,411 M | \$1.7 | US\$2,000 M | \$1.4 | 21% |
| Tanjung Bin Energy Power Plant | Malaysia | 1,000 | 1 | 1,000 | US\$1,060 M | \$1.1 | US\$1,510 M | \$1.5 | -30% |
| Chugoku Electric Power Plant | Malaysia | 1,000 | 2 | 2,000 | US\$2,957 M | \$1.5 | US\$2,860 M | \$1.4 | 3% |
| Manjung Unit 4 Power Plant | Malaysia | 1,000 | 1 | 1,000 | US\$938 M | \$0.9 | US\$1,510 M | \$1.5 | -38% |
| Lunen Power Plant | Germany | 820 | 1 | 820 | US\$1,468 M | \$1.8 | US\$1,530 M | \$1.9 | -4% |
| Moorburg Power Plant | Germany | 820 | 2 | 1,640 | US\$2,945 M | \$1.8 | US\$2,900 M | \$1.8 | 2% |
| Yuhuan Power Station | China | 1,000 | 4 | 4,000 | US\$2,187 M | \$0.5 | US\$4,400 M | \$1.1 | -50% |
| Kogan Creek Power Station (NOTE: SC plant only) | Australia | 750 | 1 | 750 | US\$1,084 M | \$1.4 | US\$1,330 M | \$1.8 | -18% |
| Tanjung Jati B Power Station * | Indonesia | 1,000 | 2 | 2,000 | US\$4,600 M | \$2.3 | US\$3,130 M | \$1.6 | 47% |

* Recently announced, not yet under construction

The following key results are identified:

- Three of the largest negative outliers are for projects that have been undertaken in China,
- Three of the four positive outliers are for three similar projects undertaken in Taiwan, and all present similar error percentages (approx. 40-60% higher than the cost predicted by PEACE,
- One of the two remaining positive outliers is for the first and only USC project carried out in the United States,
- 13 out of the 19 benchmark projects are within (or close to) $\pm 40\%$ accuracy,
- The most recent supercritical project delivered in Australia (Kogan Creek), based on a reported cost of AU\$1.2 billion in 2007, is within 20% accuracy.

3.3 Benchmark against CO2CRC APGT report

Capital cost estimates for various new-build power plants were reported recently in CO2CRC's report¹¹, including a cost for a black coal-fired USC power plant of similar characteristics to the base case presented in this report.

A comparison against the cost reported by CO2CRC and that developed in this report is presented in Table 22.

The USC plant considered in the CO2CRC report is dry cooled, and the reported cost excludes Owner's Costs. As such, the 'Contractor's Cost' for the dry cooling comparison case presented in Section 2.2 has been used for this benchmarking exercise.

It is noted that the cost presented by CO2CRC is in June 2015 AU\$, and has been converted to US\$ in the table below using an exchange rate of 1AU\$=0.75US\$.

Table 22 Capital cost estimate benchmark against CO2CRC APGT report

| Item | Unit | Value |
|---|------------------|-------|
| CO2CRC reported total plant cost estimate | US\$/kW sent-out | 2,325 |
| Dry cooling comparison case "Contractor's Cost" estimate from this report | US\$/kW sent-out | 2,134 |
| Percent deviation of CO2CRC value from base case value | % | 9% |


¹¹ CO2CRC (et. al) 2015, *Australian Power Generation Technology Report*, Table 96

Appendices

Appendix A – PEACE and STEAM PRO Results for the Base Case

Plant gross power 675529 kW
 Plant net power 649989 kW
 Number of units 1
 Plant net HR (HHV) 8704 kJ/kWh
 Plant net HR (LHV) 8396 kJ/kWh
 Plant net eff (HHV) 41.36 %
 Plant net eff (LHV) 42.88 %
 Aux. & losses 25539 kW
 Fuel heat input (HHV) 5658 GJ/h
 Fuel heat input (LHV) 5457 GJ/h
 Fuel flow 4693 t/day

Ambient 1 p
 25 T
 60% RH
 19.45 T wet bulb




Double HP Feed Water Heater Train & Single LP Feed Water Heater Train

p [bar] T [C] M [t/h] x [-]

BOILER EFF (HHV/LHV) 89.8% / 93.1%
 NET PLANT EFF (HHV/LHV) 41.4% / 42.9%


NET POWER 649989 kW
 NET PLANT HR (HHV/LHV) 8704 / 8396 kJ/kWh

AUX 25539 kW
 TURBINE HR 7502 kJ/kWh



Fuel chemical LHV input = 1515877 kJ/s
Fuel chemical HHV input = 1571569 kJ/s


Plant Energy Flow Schematic [kJ/s]



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)


Auxiliaries & Losses [kW]

Total auxiliaries & transformer losses = 25539 kW




Plant Water Consumption [t/h]

Plant water consumption = 1122.5 t/h




Plant Water Discharge [t/h]

Plant water discharge = 224.5 t/h



Plume not visible




| HX | Tin | Tout | M |
|------|-------|-------|--------|
| ECO1 | 287.7 | 343.5 | 1863.6 |
| CS1 | 427.6 | 462.5 | 1863.6 |
| RSH | 462.5 | 532.3 | 1863.6 |
| CS2 | 532.3 | 606 | 1863.6 |
| CR1 | 372.7 | 485.3 | 1689.2 |
| CR2 | 485.3 | 605.4 | 1689.2 |

| FUEL | WEIGHT% |
|------|---------|
| C | % 70.8 |
| H | % 4.7 |
| O | % 13.05 |
| N | % 1.53 |
| S | % 0.57 |
| ASH | % 9.4 |


STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
 FILE: C:\Users\ldcbaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp BOILER SCHEMATIC

| p | T | m | BOILER EFF | BOILER FUEL INPUT (kJ/s) |
|-----|---|-----|---------------------------|---------------------------|
| bar | C | t/h | 89.8 % (HHV) 93.1 % (LHV) | 1571569(HHV) 1515877(LHV) |


Boiler - TQ Diagram




ECO1 - TQ Diagram




CS1 - TQ Diagram




CS2 - TQ Diagram




CR1 - TQ Diagram




CR2 - TQ Diagram




Furnace - TQ Diagram




Rotary Air Heater - TQ Diagram



Expansion power 683127 kW
 Mechanical loss 1707.8 kW
 Generator loss 5890 kW
 Generator power 675529 kW





p [bar] T [C] h [kJ/kg] M [t/h] x [-]




p [bar] T [C] h [kJ/kg] M [t/h] x [-]

Steam Turbine Exhaust Loss






p [bar] T [C] M [t/h] x [-]





Double HP Feed Water Heater Train & Single LP Feed Water Heater Train




p [bar] T [C] h [kJ/kg] M [t/h] Q [kJ/s] x [-]

FWH System T-Q Diagram




 STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
 FILE: C:\Users\dcabatie\Desktop\HELE documentation\Model\USC model_wet cooling.stp
 p T m Q A
 bar C t/h kJ/s m²


FWH 1 T-Q Diagram



FWH 1
40910 Q
1250.1 A

Steam: 58.43 m, 0.346 p, 72.42 Tin, 72.42 Tex
Water: 1193.6 m, 21.6 p, 40.08 Tin, 69.65 Tex


FWH 2 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcabaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 3 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcabatie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 4 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcbaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 5 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcbaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 6 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcbaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 7 T-Q Diagram



FWH 7
35785 Q
1414 A

Steam: 59.82 m, 41.42 p, 302.4 Tin, 225.1 Tex
Water: 931.8 m, 308 p, 220.1 Tin, 250.7 Tex


FWH 8 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcbaptie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 9 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-11-2017 10:23:59 Steam Properties: IFC-67
FILE: C:\Users\dcabatie\Desktop\HELE documentation\Model\USC model_wet cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |

| | | |
|------------------------------|--------|------|
| Condenser heat rejection | 724868 | kJ/s |
| Condensate pump power | 1072.2 | kW |
| Condenser CW pump power | 4435 | kW |
| Cooling tower heat rejection | 728999 | kJ/s |
| CW blowdown | 224.5 | t/h |
| CW makeup | 1122.5 | t/h |



p [bar] T [C] h [kJ/kg] M [t/h] x [-]

Psychrometric Chart

AIR STATES:
A) Ambient or Inlet:
 Pressure = 1 bar
 Dry bulb = 25 C
 Wet bulb = 19.45 C
 RH = 60 %
E) Air Exit:
 Dry bulb = 34.47 C
 Wet bulb = 34.47 C
 RH = 100 %
 Plume invisible
 (Plume Visibility
 index = 0.00)

A


B

C

D

E

F



A

B

C


D

E


F

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Natural Draft CT |
| Date: 04/11/17 | |
| Drawing No: | |
| | |

WCC - TQ Diagram




Natural Draft CT - TQ Diagram




Plant Energy In [kJ/s]

Plant energy in = 1611030 kJ/s
Plant fuel chemical LHV input = 1515877 kJ/s, HHV = 1571569 kJ/s



Plant Energy Out [kJ/s]


Plant energy out = 1611049 kJ/s



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)


Boiler Energy In [kJ/s]

Boiler energy in = 1617417 kJ/s
Plant fuel chemical LHV input = 1515877 kJ/s, HHV = 1571569 kJ/s



Boiler Energy Out [kJ/s]


Boiler energy out = 1617421 kJ/s



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)


Steam Cycle Energy In [kJ/s]

Steam cycle energy in = 1436424 kJ/s




Steam Cycle Energy Out [kJ/s]


Steam cycle energy out = 1436438 kJ/s



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)





| | |
|------------------|-----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Pump (P1) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |



| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2070.6 t/h |
| Nameplate head | 81.81 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 83.82 m |
| Nameplate RPM | 600 |
| Design flow | 1863.6 t/h |
| Design head | 87.01 m |
| Design RPM | 600 |
| Minimum continuous flow | 310.6 t/h |
| Maximum continuous flow | 2795.3 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Booster Pump (P3) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |





| | |
|--------------------------|------------|
| No. per ST | 2 |
| No. operating per ST | 1 |
| Nameplate flow | 1326.2 t/h |
| Nameplate head | 242.4 m |
| Nameplate flow (nominal) | 22712 lpm |
| Nameplate head (nominal) | 243.8 m |
| Nameplate RPM | 1500 |
| Design flow | 1193.6 t/h |
| Design head | 218.1 m |
| Design RPM | 1500 |
| Minimum continuous flow | 198.9 t/h |
| Maximum continuous flow | 1790.4 t/h |

| | |
|------------------|---------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Condensate Forwarding Pump (P6) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |

STEAM PRO 26.1 GHD GHD Pty Ltd
 588 04-21-2017 16:13:26 G:\41\30763\Tech\HELE documentation\Model\USC model_wet cooling.stp
 Program revision date: February 16, 2017
 Steam source: Conventional boiler
 Steam turbine: Single reheat condensing turbine 3000+3000/3000
 Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train
 Cooling system: Water cooling with natural draft cooling tower
 Steam Property Formulation: IFC-67

| SYSTEM SUMMARY | | | | | | |
|--------------------|-------------------|---------------|-------------------|----------------|--------------|-------------|
| | Power Output (kW) | | Fuel Input (kJ/s) | | Fuel Flows | |
| | Gross | Net | LHV | HHV | t/h | t/day |
| Plant Total | 675529 | 649989 | 1515877 | 1571569 | 195.6 | 4693 |

| | | |
|---|---|------|
| Number of units = | 1 | |
| Net process heat output = | 0 | kJ/s |
| as % of total output (net elec. + net heat) = | 0 | % |

| PLANT EFFICIENCY AND HEAT RATE | | | | | | | |
|--------------------------------|--------------|--------------|--------------|--------------|---------------------|--------------|---------------|
| | LHV* | | HHV* | | Boiler Heat Input** | | |
| | Gross | Net | Gross | Net | Gross | Net | |
| Heat rate | 8078 | 8396 | 8375 | 8704 | 8078 | 8396 | kJ/kWh |
| Electric efficiency | 44.56 | 42.88 | 42.98 | 41.36 | 44.56 | 42.88 | % |
| CHP (Total) efficiency | | 42.88 | | 41.36 | | 42.88 | % |
| U.S. PURPA efficiency | | 42.88 | | 41.36 | | 42.88 | % |

* Heat input is based on fuel chemical energy, LHV or HHV, at 77 F/25 C
 ** Boiler heat input includes fuel chemical LHV energy at 77 F/ 25 C, plus enthalpy of supply air (gas) in excess of ambient temperature.
 Total heat input (LHV adjusted) = 1515877 kJ/s
 Fuel input to boiler (LHV adjusted) = 1515874 kJ/s.

| STEAM CYCLE/BOILER PERFORMANCE | | |
|---------------------------------------|--------------|---------------|
| Steam cycle heat rate | 7520 | kJ/kWh |
| Steam cycle efficiency | 47.87 | % |
| Turbine heat rate | 7502 | kJ/kWh |
| Boiler LHV adjusted efficiency | 93.09 | % |
| Boiler HHV adjusted efficiency | 89.79 | % |

| ESTIMATED PLANT AUXILIARIES | | |
|---|----------------|-----------|
| Boiler primary air fan* | 1395.3 | kW |
| Boiler secondary air fan* | 1868.7 | kW |
| Boiler induced draft fan* | 2593.6 | kW |
| Boiler fuel delivery* | 4311.4 | kW |
| Boiler forced circulation pump | 0.0 | kW |
| Electrostatic precipitator (ESP) | 1566.7 | kW |
| Ash handling | 831.9 | kW |
| Condenser cooling water pump | 4435.4 | kW |
| Cooling tower fan | 0.0 | kW |
| Condensate pump* | 1072.2 | kW |
| Contact heater feed forward pump(s)* | 0.0 | kW |
| Boiler feed pump* | 0.0 | kW |
| Boiler feed booster pump* | 567.3 | kW |
| FW heater drain pump(s)* | 215.7 | kW |
| Aux. from PEACE running motor/load list | 2948.8 | kW |
| Miscellaneous ST auxiliaries | 354.7 | kW |
| Miscellaneous plant auxiliaries | 1688.8 | kW |
| Constant plant auxiliary load | 0.0 | kW |
| Program estimated overall plant auxiliaries | 23850.7 | kW |
| Actual (user input) overall plant auxiliaries | 23850.7 | kW |
| Transformer losses | 1688.8 | kW |
| Total auxiliaries & transformer losses | 25539.5 | kW |
| * Heat balance related auxiliaries | | |

| PLANT HEAT BALANCE | | |
|---|----------------|------------------|
| Energy In | 1611030 | kW |
| Ambient air sensible | 16920 | kW |
| Ambient air latent | 19783 | kW |
| Fuel enthalpy @ supply | 1574327 | kW |
| External steam | 0 | kW |
| External water | 0 | kW |
| Makeup, process return, and blowdown recovery | 0 | kW |
| FGD water | 0 | kW |
| FGD oxidation air | 0 | kW |
| CO2 capture makeup water | 0 | kW |
| Condensate external heating or cooling | 0 | kW |
| Energy Out | 1611049 | kW |
| Net power output | 649989 | kW |
| Stack gas sensible | 104337 | kW |
| Stack gas latent | 76842 | kW |
| Bottom ash | 1364.2 | kW |
| Fly ash | 387.9 | kW |
| Unburned carbon | 4535 | kW |
| Boiler minor loss | 21167 | kW |
| Fuel delivery energy loss | 862.3 | kW |
| Main condenser | 724868 | kW |
| BFPT condenser | 0 | kW |
| Process steam | 0 | kW |
| Process water | 0 | kW |
| District heat | 0 | kW |
| Discharged seal steam | 0 | kW |
| Blowdown | 0 | kW |
| Steam pipe losses | 3902 | kW |
| ST/generator mech/elec/gear loss | 7598 | kW |
| BFPT mech loss | 236.8 | kW |
| Pumps mech/elec loss | 859.7 | kW |
| Fans mech/elec loss | 585.8 | kW |
| ESP heat loss | 0 | kW |
| FGD energy loss | 0 | kW |
| CO2 capture energy loss | 0 | kW |
| Desal heat | 0 | kW |
| Non-heat balance related auxiliaries | 13515 | kW |
| Other | 0 | kW |
| Energy In - Energy Out | -19.12 | kW |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | |
| | | -0.0012 % |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|---|----------|--------|------------|----------|----------------|
| Note: This is a fixed format table. Not all streams are applicable to current heat balance. | | | | | H2O: ref @ 32F |
| Zero enthalpy: steam & liquid water at 32 F (273.15 K). | | | | | |
| 1 Feedwater into boiler | 306.7 | 287.7 | 1266.98 | 1863.57 | - |
| 2 Feedwater leaving grate cooling HX | 306.7 | 287.7 | 1266.98 | 1863.57 | - |
| 3 Water leaving 1st economiser | 303.7 | 343.5 | 1568.27 | 1863.57 | - |
| 4 Water entering 2nd economiser | 303.7 | 343.5 | 1568.27 | 1863.57 | - |
| 5 Water leaving 2nd economiser | 303.7 | 343.5 | 1568.27 | 1863.57 | - |
| 6 Boiler blowdown | - | - | - | - | - |
| 7 Steam leaving CEV | - | - | - | - | - |
| 8 Steam leaving REV | 288.5 | 427.6 | 2690.99 | 1863.57 | - |
| 9 Steam leaving CEV+REV | 288.5 | 427.6 | 2690.99 | 1863.57 | - |
| 10 1st superheater inlet | 288.5 | 427.6 | 2690.99 | 1863.57 | - |
| 11 1st superheater exit | 285.9 | 462.5 | 2934.68 | 1863.57 | - |
| 12 2nd superheater inlet | 285.9 | 462.5 | 2934.68 | 1863.57 | - |
| 13 2nd superheater exit | 282.7 | 532.3 | 3236.20 | 1863.57 | - |
| 14 3rd superheater inlet | 282.7 | 532.3 | 3236.20 | 1863.57 | - |
| 15 3rd superheater exit | 280.1 | 606.0 | 3479.90 | 1863.57 | - |
| 16 4th superheater inlet | 280.1 | 606.0 | 3479.90 | 1863.57 | - |
| 17 4th superheater exit | 280.1 | 606.0 | 3479.90 | 1863.57 | - |
| 18 Steam leaving superheater | 280.1 | 606.0 | 3479.89 | 1863.57 | - |
| 19 Cold reheat after pipe | 63.04 | 372.7 | 3101.70 | 1689.24 | - |
| 20 Mixing cold reheat with steam add. | 63.04 | 372.7 | 3101.70 | 1689.24 | - |
| 21 1st reheater inlet | 63.04 | 372.7 | 3101.70 | 1689.24 | - |
| 22 1st reheater exit | 62.12 | 485.3 | 3384.68 | 1689.24 | - |
| 23 2nd reheater inlet | 62.12 | 485.3 | 3384.68 | 1689.24 | - |
| 24 2nd reheater exit | 62.12 | 485.3 | 3384.68 | 1689.24 | - |
| 25 3rd reheater inlet | 62.12 | 485.3 | 3384.68 | 1689.24 | - |
| 26 3rd reheater exit | 61.2 | 605.4 | 3667.67 | 1689.24 | - |
| 27 4th reheater inlet | 61.2 | 605.4 | 3667.67 | 1689.24 | - |
| 28 4th reheater exit | 61.2 | 605.4 | 3667.67 | 1689.24 | - |
| 29 Steam leaving reheater | 61.2 | 605.4 | 3667.67 | 1689.24 | - |
| 30 Cold LP reheat after pipe | - | - | - | - | - |
| 31 Mixing cold LP reheat with steam add. | - | - | - | - | - |
| 32 1st LP reheater inlet | - | - | - | - | - |
| 33 1st LP reheater exit | - | - | - | - | - |
| 34 2nd LP reheater inlet | - | - | - | - | - |
| 35 2nd LP reheater exit | - | - | - | - | - |
| 36 3rd LP reheater inlet | - | - | - | - | - |
| 37 3rd LP reheater exit | - | - | - | - | - |
| 38 4th LP reheater inlet | - | - | - | - | - |
| 39 4th LP reheater exit | - | - | - | - | - |
| 40 Steam leaving LP reheater | - | - | - | - | - |
| 41 HPT inlet, before stop valves | 276 | 604.0 | 3477.57 | 1863.57 | 6.306 |
| 42 HPT inlet, after stop valves | 269.1 | 601.9 | 3477.57 | 1831.68 | - |
| 43 HPT exit | 64.3 | 374.5 | 3104.00 | 1689.24 | 6.402 |
| 44 PIPT inlet, before intercept valve | - | - | - | - | - |
| 45 PIPT exit | - | - | - | - | - |
| 46 IPT inlet, before intercept valve | 60 | 604.0 | 3665.34 | 1689.24 | 7.177 |
| 47 IPT bowl | 58.8 | 602.2 | 3662.01 | 1719.74 | 7.182 |
| 48 LPT crossover | 7 | 296.7 | 3052.62 | 1259.92 | 7.287 |
| 49 LPT exhaust | 0.0716 | 39.5 | 2344.72 | 1058.99 | 7.537 |
| 50 ST group 1 inlet | 269.1 | 601.9 | 3477.57 | 1831.68 | 6.317 |
| 51 ST group 1 blading exit | 212.3 | 562.3 | 3416.49 | 1831.68 | 6.34 |
| 52 ST group 1 addition / extraction | - | - | - | - | - |
| 53 ST group 2 inlet | 212.3 | 562.3 | 3416.49 | 1831.68 | 6.34 |
| 54 ST group 2 blading exit | 64.3 | 374.5 | 3104.00 | 1831.68 | 6.402 |
| 55 ST group 2 addition / extraction | 64.3 | 374.5 | 3104.00 | -128.63 | 6.402 |
| 56 ST group 3 inlet | 58.8 | 602.2 | 3662.01 | 1719.74 | 7.182 |
| 57 ST group 3 blading exit | 42.67 | 549.7 | 3555.23 | 1719.74 | 7.2 |
| 58 ST group 3 addition / extraction | 42.67 | 549.7 | 3555.23 | -119.65 | 7.2 |
| 59 ST group 4 inlet | 42.67 | 549.7 | 3555.23 | 1600.10 | 7.2 |
| 60 ST group 4 blading exit | 22.9 | 454.3 | 3363.28 | 1600.10 | 7.232 |
| 61 ST group 4 addition / extraction | 22.9 | 454.3 | 3363.28 | -63.91 | 7.232 |
| 62 ST group 5 inlet | 22.9 | 454.3 | 3363.28 | 1536.19 | 7.232 |
| 63 ST group 5 blading exit | 13.04 | 375.4 | 3206.91 | 1536.19 | 7.259 |
| 64 ST group 5 addition / extraction | 13.04 | 375.4 | 3206.91 | -74.55 | 7.259 |
| 65 ST group 6 inlet | 13.04 | 375.4 | 3206.91 | 1461.64 | 7.259 |
| 66 ST group 6 blading exit | 7 | 296.5 | 3052.15 | 1461.64 | 7.286 |
| 67 ST group 6 addition / extraction | 7 | 296.5 | 3052.15 | -210.51 | 7.286 |
| 68 ST group 7 inlet | 7 | 296.7 | 3052.62 | 1259.92 | 7.287 |
| 69 ST group 7 blading exit | 3.083 | 205.1 | 2875.37 | 1259.92 | 7.32 |
| 70 ST group 7 addition / extraction | 3.083 | 205.1 | 2875.37 | -73.43 | 7.32 |
| 71 ST group 8 inlet | 3.083 | 205.1 | 2875.37 | 1186.48 | 7.32 |
| 72 ST group 8 blading exit | 1.167 | 113.0 | 2700.39 | 1186.48 | 7.355 |
| 73 ST group 8 addition / extraction | 1.167 | 113.0 | 2700.39 | -69.06 | 7.355 |
| 74 ST group 9 inlet | 1.167 | 113.0 | 2700.39 | 1117.42 | 7.355 |
| 75 ST group 9 blading exit | 0.363 | 73.6 | 2526.06 | 1117.42 | 7.396 |
| 76 ST group 9 addition / extraction | 0.363 | 73.6 | 2526.06 | -58.43 | 7.396 |
| 77 ST group 10 inlet | 0.363 | 73.6 | 2526.06 | 1058.99 | 7.396 |
| 78 ST group 10 blading exit | 0.0716 | 39.5 | 2323.38 | 1058.99 | 7.469 |
| 79 ST group 10 addition / extraction | 0.0716 | 39.5 | 2344.72 | 1058.99 | 7.537 |
| 80 ST group 11 inlet | - | - | - | - | - |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|--|----------|--------|------------|----------|--------------|
| 81 ST_group 11 blading exit | - | - | - | - | - |
| 82 ST_group 11 addition / extraction | - | - | - | - | - |
| 83 ST_group 12 inlet | - | - | - | - | - |
| 84 ST_group 12 blading exit | - | - | - | - | - |
| 85 ST_group 12 addition / extraction | - | - | - | - | - |
| 86 ST_group 13 inlet | - | - | - | - | - |
| 87 ST_group 13 addition / extraction | - | - | - | - | - |
| 88 ST_group 13 blading exit | - | - | - | - | - |
| 89 ST_group 14 inlet | - | - | - | - | - |
| 90 ST_group 14 blading exit | - | - | - | - | - |
| 91 ST_group 14 addition / extraction | - | - | - | - | - |
| 92 ST_group 15 inlet | - | - | - | - | - |
| 93 ST_group 15 blading exit | - | - | - | - | - |
| 94 ST_group 15 addition / extraction | - | - | - | - | - |
| 95 ST_group 16 inlet | - | - | - | - | - |
| 96 ST_group 16 addition / extraction | - | - | - | - | - |
| 97 ST_group 16 blading exit | - | - | - | - | - |
| 98 ST_group 17 inlet | - | - | - | - | - |
| 99 ST_group 17 blading exit | - | - | - | - | - |
| 100 ST_group 17 addition / extraction | - | - | - | - | - |
| 101 ST_group 18 inlet | - | - | - | - | - |
| 102 ST_group 18 blading exit | - | - | - | - | - |
| 103 ST_group 18 addition / extraction | - | - | - | - | - |
| 104 ST_group 19 inlet | - | - | - | - | - |
| 105 ST_group 19 blading exit | - | - | - | - | - |
| 106 ST_group 19 addition / extraction | - | - | - | - | - |
| 107 FW into condensate pump | 0.3707 | 39.4 | 165.15 | 1193.57 | - |
| 108 FW after condensate pump | 21.6 | 39.7 | 168.18 | 1193.57 | - |
| 109 FW after recovery HXs before 1st FWH | 21.6 | 40.1 | 169.65 | 1193.57 | - |
| 110 FW before booster pump | 14.9 | 190.4 | 809.24 | 1863.57 | - |
| 111 FW after booster pump | 22.38 | 190.5 | 810.26 | 1863.57 | - |
| 112 FW into boiler feed pump | 22.38 | 190.5 | 810.26 | 1863.57 | - |
| 113 FW after boiler feed pump | 308.6 | 197.4 | 854.14 | 1863.57 | - |
| 114 FWH1 heating steam | 0.3458 | 72.4 | 2523.74 | 58.43 | - |
| 115 FWH1 feedwater inlet | 21.6 | 40.1 | 169.65 | 1193.57 | - |
| 116 FWH1 feedwater exit | 19.62 | 69.6 | 293.04 | 1193.57 | - |
| 117 FWH1 drain | 0.3458 | 72.4 | 303.11 | 283.26 | - |
| 118 FWH2 heating steam | 1.112 | 111.6 | 2698.06 | 69.06 | - |
| 119 FWH2 feedwater inlet | 19.62 | 70.2 | 295.45 | 1476.83 | - |
| 120 FWH2 feedwater exit | 17.71 | 99.8 | 419.60 | 1476.83 | - |
| 121 FWH2 drain | 1.112 | 75.2 | 314.91 | 219.61 | - |
| 122 FWH3 heating steam | 2.936 | 203.6 | 2873.04 | 73.43 | - |
| 123 FWH3 feedwater inlet | 17.71 | 99.8 | 419.60 | 1476.83 | - |
| 124 FWH3 feedwater exit | 16.18 | 130.0 | 547.31 | 1476.83 | - |
| 125 FWH3 drain | 2.936 | 104.8 | 439.59 | 150.55 | - |
| 126 FWH4 heating steam | 6.667 | 294.9 | 3049.83 | 77.12 | - |
| 127 FWH4 feedwater inlet | 16.18 | 130.0 | 547.31 | 1476.83 | - |
| 128 FWH4 feedwater exit | 14.9 | 160.2 | 676.90 | 1476.83 | - |
| 129 FWH4 drain | 6.667 | 135.0 | 568.00 | 77.12 | - |
| 130 FWH5 heating steam | 12.66 | 374.0 | 3204.58 | 74.55 | - |
| 131 FWH5 feedwater inlet | 12.66 | 160.3 | 676.90 | 1476.83 | - |
| 132 FWH5 feedwater exit | 12.66 | 190.4 | 809.24 | 1476.83 | - |
| 133 FWH5 drain | 12.66 | 190.4 | 809.24 | 386.73 | - |
| 134 FWH6 heating steam | 22.24 | 452.8 | 3360.95 | 63.91 | - |
| 135 FWH6 feedwater inlet | 308.6 | 197.4 | 854.14 | 1863.57 | - |
| 136 FWH6 feedwater exit | 308 | 220.1 | 953.68 | 1863.57 | - |
| 137 FWH6 drain | 22.24 | 202.4 | 863.26 | 312.18 | - |
| 138 FWH7 heating steam | 41.42 | 302.4 | 2963.86 | 119.65 | - |
| 139 FWH7 feedwater inlet | 308 | 220.1 | 953.68 | 1863.57 | - |
| 140 FWH7 feedwater exit | 307.4 | 250.7 | 1091.94 | 1863.57 | - |
| 141 FWH7 drain | 41.42 | 225.1 | 967.53 | 248.28 | - |
| 142 FWH8 heating steam | 62.42 | 372.1 | 3101.67 | 128.63 | - |
| 143 FWH8 feedwater inlet | 307.4 | 250.7 | 1091.94 | 1863.57 | - |
| 144 FWH8 feedwater exit | 306.8 | 279.9 | 1229.16 | 1863.57 | - |
| 145 FWH8 drain | 62.42 | 255.7 | 1113.67 | 128.63 | - |
| 146 FWH9 heating steam | 41.42 | 548.2 | 3552.90 | 119.65 | - |
| 147 FWH9 feedwater inlet | 306.8 | 279.9 | 1229.16 | 1863.57 | - |
| 148 FWH9 feedwater exit | 306.7 | 287.7 | 1266.98 | 1863.57 | - |
| 149 FWH9 drain | 41.42 | 302.4 | 2963.86 | 119.65 | - |
| 150 FWH10 heating steam | - | - | - | - | - |
| 151 FWH10 feedwater inlet | - | - | - | - | - |
| 152 FWH10 feedwater exit | - | - | - | - | - |
| 153 FWH10 drain | - | - | - | - | - |
| 154 FWH11 heating steam | - | - | - | - | - |
| 155 FWH11 feedwater inlet | - | - | - | - | - |
| 156 FWH11 feedwater exit | - | - | - | - | - |
| 157 FWH11 drain | - | - | - | - | - |
| 158 FWH12 heating steam | - | - | - | - | - |
| 159 FWH12 feedwater inlet | - | - | - | - | - |
| 160 FWH12 feedwater exit | - | - | - | - | - |
| 161 FWH12 drain | - | - | - | - | - |
| 162 Condenser inlet steam | 0.0716 | 39.5 | 2351.44 | 1193.57 | 7.559 |
| 163 Condenser condensate exit | 0.3707 | 39.4 | 165.15 | 1193.57 | - |
| 164 Condenser CW inlet | 3.366 | 26.1 | 109.79 | 53678.23 | - |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|---|----------|--------|------------|----------|--------------|
| 165 Condenser CW exit | 2.495 | 37.8 | 158.41 | 53678.23 | - |
| 166 CW into cooling tower | 1.897 | 37.8 | 158.41 | 53678.23 | - |
| 167 CW leaving cooling tower basin | 1 | 26.1 | 109.52 | 53678.23 | - |
| 168 CW after circulation pump | 3.366 | 26.1 | 109.79 | 53678.23 | - |
| 169 FPT inlet before valve | 6.667 | 294.9 | 3049.83 | 133.40 | 7.304 |
| 170 FPT 1st group inlet | 5.333 | 293.3 | 3049.83 | 133.40 | 7.406 |
| 171 FPT extraction 1 | 0.0716 | 39.5 | 2410.74 | 133.40 | 7.748 |
| 172 FPT 2nd group inlet | - | - | - | - | - |
| 173 FPT extraction 2 | - | - | - | - | - |
| 174 FPT 3rd group inlet | - | - | - | - | - |
| 175 FPT extraction 3 | - | - | - | - | - |
| 176 FPT condenser condensate exit | - | - | - | - | - |
| 177 FPT condenser CW inlet | - | - | - | - | - |
| 178 FPT condenser CW exit | - | - | - | - | - |
| 179 External steam source 1 | - | - | - | - | - |
| 180 External steam source 2 | - | - | - | - | - |
| 181 Process stream 1 | - | - | - | - | - |
| 182 Process stream 2 | - | - | - | - | - |
| 183 Process stream 3 | - | - | - | - | - |
| 184 Process stream 4 | - | - | - | - | - |
| 185 Process stream 5 | - | - | - | - | - |
| 186 Steam addition 1 | - | - | - | - | - |
| 187 Steam addition 2 | - | - | - | - | - |
| 188 Steam addition 3 | - | - | - | - | - |
| 189 Water extraction 1 | - | - | - | - | - |
| 190 Water extraction 2 | - | - | - | - | - |
| 191 Water extraction 3 | - | - | - | - | - |
| 192 Water addition 1 | - | - | - | - | - |
| 193 Water addition 2 | - | - | - | - | - |
| 194 Water addition 3 | - | - | - | - | - |
| 195 DHW return | - | - | - | - | - |
| 196 DHTR1 heating steam | - | - | - | - | - |
| 197 DHTR1 DHW inlet | - | - | - | - | - |
| 198 DHTR1 DHW exit | - | - | - | - | - |
| 199 DHTR1 drain | - | - | - | - | - |
| 200 DHTR2 heating steam | - | - | - | - | - |
| 201 DHTR2 DHW inlet | - | - | - | - | - |
| 202 DHTR2 DHW exit | - | - | - | - | - |
| 203 DHTR2 drain | - | - | - | - | - |
| 204 SSR inlet steam | 1.241 | 344.4 | 3163.62 | 6.40 | 8.267 |
| 205 GSC inlet steam | 0.8274 | 344.0 | 3163.62 | 0.63 | - |
| 206 SAH1 heating steam | - | - | - | - | - |
| 207 SAH1 drain | - | - | - | - | - |
| 208 SAH2 heating steam | - | - | - | - | - |
| 209 SAH2 drain | - | - | - | - | - |
| 210 Fuel heater heating stream | - | - | - | - | - |
| 211 Fuel heater drain | - | - | - | - | - |
| 212 CO2 capture first steam after pipe | - | - | - | - | - |
| 213 CO2 capture first condensate after pump | - | - | - | - | - |
| 214 CO2 capture second steam after pipe | - | - | - | - | - |
| 215 CO2 capture second condensate after pump | - | - | - | - | - |
| 216 CO2 capture CW inlet | - | - | - | - | - |
| 217 CO2 capture CW exit | - | - | - | - | - |
| 218 Total desalinated water from desalination plant | - | - | - | - | - |
| 219 Desalinated water from MSF plant | - | - | - | - | - |
| 220 MSF plant heating steam before pipe | - | - | - | - | - |
| 221 MSF plant heating steam after pipe | - | - | - | - | - |
| 222 MSF plant vacuum steam | - | - | - | - | - |
| 223 MSF plant condensate return | - | - | - | - | - |
| 224 Seawater supply to MSF plant | - | - | - | - | - |
| 225 Seawater discharge from MSF plant | - | - | - | - | - |
| 226 Brine discharge from MSF plant | - | - | - | - | - |
| 227 Desalinated water from RO plant | - | - | - | - | - |
| 228 Seawater supply to RO plant | - | - | - | - | - |
| 229 Brine discharge from RO plant | - | - | - | - | - |

| Warning Messages | |
|-------------------|---|
| | No warning messages |
| Advisory Messages | |
| 1. | Natural Draft CT: CW flow may be too low for natural draft cooling tower. Mechanical draft tower may be better choice. |
| Remarks | |
| 1. | FWH 6 exit water temperature has been cut-off at minimum pinch of 1.667 C. Desired = 220.6 C, Actual = 220.1 C |
| 2. | FWH 8 exit water temperature has been cut-off at minimum pinch of 1.667 C. Desired = 280.9 C, Actual = 279.9 C |
| 3. | CS2: The user-defined water-side pressure drop (0.9267 % or 2.596 bar) is much higher than the pressure drop determined by the HX hardware (0.0826 % or 0.2314 bar). The water-side pressure drop correction factor which will be used for off-design has been set to the maximum value (2.056). When converted to off-design, your computed pressure drop may be lower than the present value. |

| STEAM PRO 26.1 GHD GHD Pty Ltd | | | | | | |
|---|---|-------------------------|-----------------------------------|---------------------------|-------------------------|------------------------|
| 588 04-21-2017 16:13:26 G:\41\30763\Tech\HELE documentation\Model\USC model_wet cooling.stp | | | | | | |
| Program revision date: February 16, 2017 | | | | | | |
| Steam source: Conventional boiler | | | | | | |
| Steam turbine: Single reheat condensing turbine 3000+3000/3000 | | | | | | |
| Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train | | | | | | |
| Cooling system: Water cooling with natural draft cooling tower | | | | | | |
| Steam Property Formulation: IFC-67 | | | | | | |
| BOILER HEAT BALANCE | | | | | | |
| Energy in = | 1617417 | kJ/s | | | | |
| Fuel enthalpy to boiler | Heat from Steam/Water Air Heater | Sorbent Sensible | Energy Gain from Sulfation | Inlet Air Sensible | Inlet Air Latent | Other* |
| 1574341 | 0 | 0 | 0 | 16920 | 19783 | 6387 |
| Energy out = | 1617421 | kJ/s | | | | |
| Water & Steam | Bottom Ash Sensible | Fly Ash Sensible | Calcination of Sorbent | Exhaust Gas | Minor Losses | Unburned Carbon |
| 1411123 | 1364 | 388 | 0 | 178844 | 21167 | 4535 |
| * 'Others' includes energy of fan (excluding ID fan) and fuel delivery power. | | | | | | |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | | | | | |
| Heat Balance Error (In - Out) = | -3.8 | kJ/s | = | -0.0002 | % | |

| BOILER AIR/GAS ZONE SUMMARY | | | | | | | | | | | | | |
|-----------------------------|-----------|--------|-----------------|-----------|----------|-------|-------|-------|----------------------|------|------|------|--------------------------|
| Zone | Name | T C | Dp millibar | Q kJ/s | M t/h | M.W. | N2 | O2 | Mole Composition [%] | | | | Ash t/h |
| | | | | | | | | | CO2 | H2O | Ar | SO2 | |
| | | 25.0 | | | 2024.4 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| 1 | FD Fan | 27.9 | 30.514 | 1682 | 2024.4 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | 25 | | | | | | | | | | | |
| 3 | PA Fan | 37.06 | 129.504 | 1255.8 | 368.3 | | | | | | | | |
| | | | | | -168.7 | | | | | | | | Pulverizer tempering air |
| | | | | | -17.35 | | | | | | | | Cold end leakage |
| 3 | PA Heater | 37.06 | 4.873 | 7524 | | | | | | | | | |
| | | 182.2 | | | 182.2 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | | | -8.675 | | | | | | | | Hot end leakage |
| | | | | | 168.7 | | | | | | | | Pulverizer tempering air |
| | | | | | -128.8 | | | | | | | | Cold end leakage |
| 3 | SA Heater | 27.94 | 6.212 | 133458 | | | | | | | | | |
| | | 273.9 | | | 1895.5 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | | | -55.21 | | | | | | | | Hot end leakage |
| 4 | Burner | 248.6 | 12.463 | 1515877 | 2182.6 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | Adiabatic flame | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 18.87 |
| 5 | Furnace | | 0.000 | 756389 | | | | | | | | | |
| | | 1176.7 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |
| 7 | CS2 | 1176.7 | 0.129 | 119972 | | | | | | | | | |
| | | 1036.2 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |
| 8 | CR2 | 1036.2 | 0.175 | 134779 | | | | | | | | | |
| | | 875.1 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |
| 10 | CS1 | 875.1 | 0.247 | 128044 | | | | | | | | | |
| | | 718.4 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |
| 11 | CR1 | 718.4 | 0.571 | 134779 | | | | | | | | | |
| | | 548.0 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |
| 14 | ECO1 | 548.0 | 0.698 | 158309 | | | | | | | | | |
| | | 338.4 | | | 2359.3 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.09 |

| | | | | | | | | | | | | | |
|--|--------------------------|-------|--------|---------|--------|----------------------------|-------|------|-------|------|------|------|-------|
| | | | | | 55.21 | Secondary air hot leakage | | | | | | | |
| | | | | | 8.675 | Primary air hot leakage | | | | | | | |
| | | 336.5 | | | | | | | | | | | |
| 16 | Air Heater (gas side) | 144.1 | 9.107 | -140982 | | | | | | | | | |
| | | | | | 2423.1 | 29.81 | 73.73 | 3.76 | 14.15 | 7.43 | 0.89 | 0.04 | 15.09 |
| | | | | | 128.8 | Secondary air cold leakage | | | | | | | |
| | | | | | 17.35 | Primary air cold leakage | | | | | | | |
| | | 137.8 | | | | | | | | | | | |
| 19 | ESP | 137.8 | 8.101 | 0 | | | | | | | | | |
| | | | | | 2569.3 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 137.8 | | | | | | | | | | | |
| 20 | ID Fan | 140.9 | 24.318 | 2334 | | | | | | | | | |
| | | | | | 2569.3 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 140.9 | | | | | | | | | | | |
| 30 | STK | 140.9 | -2.812 | 0 | | | | | | | | | |
| | | | | | 2569.3 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 140.9 | | | | | | | | | | | |
| Excess Air = | | | | | 20 | % | | | | | | | |
| Adiabatic flame temperature is greater than | | | | | 1093.3 | C | | | | | | | |
| Miscellaneous & ducts air-side pressure drop = | | | | | 12.45 | millibar | | | | | | | |
| Miscellaneous & ducts gas-side pressure drop = | | | | | 7.472 | millibar | | | | | | | |

| BOILER HEAT EXCHANGER SUMMARY | | | | | | | | | |
|-------------------------------|-------------|-------------|--------------|--------------|--------------|---------|---------|------|------|
| Zone | Tg | Tw | DT | Afrn | DP | Mg | Qg | Vg | Tube |
| /path | C | C | C | m^2 | millibar | t/h | kJ/s | m/s | rows |
| 5 | 1176.7 | 427.6 | 749.1 | | | | | | |
| | REV | | | | 0.0 | 2359.3 | 589907 | 10.0 | |
| | 1176.7 | 343.5 | 833.2 | | | | | | |
| 6 | 1176.7 | 532.3 | 644.4 | | | | | | |
| | RSH | | | | 0.0 | 2359.3 | 158429 | 10.0 | |
| | 1176.7 | 462.5 | 714.2 | | | | | | |
| 7 | 1176.7 | 532.3 | 644.4 | | | | | | |
| 0 | CS2 | | | 352.6 | 0.1 | 2374.3 | 119972 | 10.4 | 14.0 |
| | 1036.2 | 606.0 | 430.1 | | | | | | |
| 8 | 1036.2 | 485.3 | 550.9 | | | | | | |
| 0 | CR2 | | | 352.6 | 0.2 | 2374.3 | 134779 | 9.6 | 20.0 |
| | 875.1 | 605.4 | 269.7 | | | | | | |
| 10 | 875.1 | 462.5 | 412.7 | | | | | | |
| 0 | CS1 | | | 343.4 | 0.2 | 2374.3 | 128046 | 10.3 | 16.0 |
| | 718.4 | 427.6 | 290.8 | | | | | | |
| 11 | 718.4 | 485.3 | 233.1 | | | | | | |
| 0 | CR1 | | | 343.4 | 0.6 | 2374.3 | 134779 | 10.5 | 24.0 |
| | 548.0 | 372.7 | 175.4 | | | | | | |
| 14 | 548.0 | 343.5 | 204.5 | | | | | | |
| 0 | ECO1 | | | 343.4 | 0.7 | 2374.3 | 158308 | 7.5 | 20.0 |
| | 338.4 | 287.7 | 50.7 | | | | | | |
| Totals | | | | | 1.8 | | 1424220 | | 94.0 |
| Note: g = gas + ash | | | | | | | | | |
| BOILER HEAT TRANSFER SURFACES | | | | | | | | | |
| | Economizers | Evaporators | Superheaters | HP Reheaters | LP Reheaters | TOTAL | | | |
| Q | 155969 | 581189 | 408391 | 265574 | 0 | 1411123 | kJ/s | | |
| A | 46762 | 5121 | 13010 | 19116 | 0 | 84009 | m^2 | | |

| BOILER WATER/STEAM SUMMARY | | | | | | | | |
|----------------------------|----------|--------|------------|----------|--------------|--------------|-----------|---------------------|
| Stream | P bar | T C | h kJ/kg | M t/h | s kJ/kg-K | UA kJ/s-K | Q kJ/s | A m ² |
| ECO1 inlet | 306.75 | 287.7 | 1267.0 | 1863.6 | 3.0652 | | | |
| ECO1 exit | 303.71 | 343.5 | 1568.3 | 1863.6 | 3.5772 | 1414.1 | 155968 | 46763 |
| REV exit | 288.54 | 427.6 | 2691.0 | 1863.6 | 5.2705 | | 581189 | 5121 |
| CS1 inlet | 288.54 | 427.6 | 2691.0 | 1863.6 | 5.2705 | | | |
| CS1 exit | 285.95 | 462.5 | 2934.7 | 1863.6 | 5.6132 | 362.3 | 126154 | 6971 |
| RSH inlet | 285.95 | 462.5 | 2934.7 | 1863.6 | 5.6132 | | | |
| RSH exit | 282.74 | 532.3 | 3236.2 | 1863.6 | 6.0097 | | 156065 | 1829.8 |
| CS2 inlet | 282.74 | 532.3 | 3236.2 | 1863.6 | 6.0097 | | | |
| CS2 exit | 280.14 | 606.0 | 3479.9 | 1863.6 | 6.3032 | 237.8 | 126152 | 4210 |
| HP steam | 280.14 | 606.0 | 3479.9 | 1863.6 | 6.3032 | | | |
| Cold RH steam | 63.04 | 372.7 | 3101.7 | 1689.2 | 6.4065 | | | |
| CR1 inlet | 63.04 | 372.7 | 3101.7 | 1689.2 | 6.4065 | | | |
| CR1 exit | 62.12 | 485.3 | 3384.7 | 1689.2 | 6.8175 | 654.5 | 132787 | 12767 |
| CR2 inlet | 62.12 | 485.3 | 3384.7 | 1689.2 | 6.8175 | | | |
| CR2 exit | 61.20 | 605.4 | 3667.7 | 1689.2 | 7.1705 | 337.2 | 132787 | 6349 |
| Hot RH steam | 61.20 | 605.4 | 3667.7 | 1689.2 | 7.1705 | | | |

| FUEL - 'Hunter Valley' (Solid) | | |
|--------------------------------------|------------|-------------------|
| Fuel Name: Hunter Valley | | |
| Thermoflow library fuel | | |
| Coal, High-volatile B bituminous | | |
| Fuel supply temp. | 25.00 | C |
| Heating Values | | |
| LHV | 27904.8 | kJ/kg |
| HHV | 28930.0 | kJ/kg |
| Ultimate Analysis (weight %) | | |
| Moisture | 4.80 | % |
| Ash | 9.40 | % |
| Carbon | 70.72 | % |
| Hydrogen | 4.16 | % |
| Nitrogen | 1.53 | % |
| Chlorine | 0.04 | % |
| Sulfur | 0.57 | % |
| Oxygen | 8.78 | % |
| Total | 100.00 | % |
| Proximate Analysis (weight %) | | |
| Moisture | 4.80 | % |
| Ash | 9.40 | % |
| Volatile Matter | 31.70 | % |
| Fixed Carbon | 54.10 | % |
| Total | 100.00 | % |
| Ash Analysis (weight %) | | |
| SiO2 | 63.90 | % |
| Al2O3 | 22.30 | % |
| Fe2O3 | 7.40 | % |
| CaO | 0.80 | % |
| MgO | 0.70 | % |
| Na2O | 0.20 | % |
| K2O | 1.60 | % |
| TiO2 | 0.80 | % |
| P2O5 | 0.70 | % |
| SO3 | 0.50 | % |
| Other | 1.10 | % |
| Total | 100.00 | % |
| Ash Characteristics | | |
| Fouling | Low/Medium | |
| Initial deformation temperature | 1280.00 | C |
| Softening temperature | 1480.00 | C |
| Bulk density | 768.89 | kg/m ³ |
| Mercury content (dry basis) | 0.00 | ppmw |

| | | |
|---|----------|----------|
| Pseudo molecular weight | 7.8810 | |
| Mole flow | 6.2449 | kg-mol/s |
| Mass flow (ash-free) | 177.1778 | t/h |
| Mass flow | 195.5605 | t/h |
| Mass flow | 4693 | t/day |
| LHV (ash-free) @ 25 C | 30800.00 | kJ/kg |
| LHV (adjusted)* @ 25 C | 30800.00 | kJ/kg |
| Enthalpy (ash-free) ref. to 0 C | 31987.95 | kJ/kg |
| Atomic percentage | | |
| C | 51.25 | % |
| H | 40.56 | % |
| O | 7.09 | % |
| N | 0.95 | % |
| S | 0.15 | % |
| Ar | 0.00 | % |
| * Adjusted heating values include fuel sensible enthalpy above 77 F/25 C and are on an ash-free basis | | |

| ASME Boiler Energy Balance | | | |
|--|------------------|------------------|----------|
| Energy In | HHV based | LHV based | |
| Energy input from fuel* | 1571570 | 1515877 | kW |
| Credit due to entering dry air | 2873.8 | 2873.8 | kW |
| Credit due to moisture in entering air | 63.94 | 63.94 | kW |
| Credit due to sensible heat in fuel | 0 | 0 | kW |
| Credit due to sulfation | 0 | 0 | kW |
| Credit due to sensible heat in sorbent | 0 | 0 | kW |
| Credit due to auxiliary equipment power | 3449 | 3449 | kW |
| Total credits | 6387 | 6387 | kW |
| Total energy in | 1577956 | 1522264 | kW |
| Energy Out | | | |
| Energy output to steam and water | 1411123 | 1411123 | kW |
| Loss due to sensible heat in dry gas | 77158 | 77158 | kW |
| Loss due to moisture in fuel | 6924 | 554.2 | kW |
| Loss due to moisture from burning hydrogen | 53625 | 4292 | kW |
| Loss due to moisture in air | 1680.8 | 1680.8 | kW |
| Loss due to unburned carbon | 4535 | 4535 | kW |
| Loss due to calcination of sorbent | 0 | 0 | kW |
| Loss due to radiation and unmeasured losses | 22919 | 22919 | kW |
| Total losses | 166842 | 111139 | kW |
| Total energy out | 1577966 | 1522262 | kW |
| ASME fuel efficiency (Output/Input) | 89.79 | 93.09 | % |
| ASME gross efficiency (Output/(Input+Credits)) | 89.43 | 92.7 | % |
| *Energy input from fuel is based upon fuel heating value at 77 F/25 C | | | |
| Zero enthalpy: dry gases & liquid water at 77 F/25 C | | | |
| The entering air enthalpy is calculated based on air temperature before air heater. | | | |
| The leaving gas enthalpy is calculated based on flue gas temperature after air heater. | | | |

| Solid Fuel | | |
|---|-------|-------------------|
| Fuel Name: Hunter Valley | | |
| Type: Coal, High-volatile B bituminous | | |
| Fuel supply temperature | 25 | C |
| Total LHV + Sensible heat @ 25C | 27905 | kJ/kg |
| Total fuel enthalpy referenced to 0C | 28981 | kJ/kg |
| Heating Values (at 25C) | | |
| LHV (moisture and ash included) | 27905 | kJ/kg |
| HHV (moisture and ash included) | 28930 | kJ/kg |
| Ultimate Analysis (weight %) | | |
| Moisture | 4.8 | % |
| Ash | 9.4 | % |
| Carbon | 70.72 | % |
| Hydrogen | 4.16 | % |
| Nitrogen | 1.53 | % |
| Chlorine | 0.04 | % |
| Sulfur | 0.57 | % |
| Oxygen | 8.78 | % |
| Total | 100 | % |
| Proximate Analysis (weight %) | | |
| Moisture | 4.8 | % |
| Ash | 9.4 | % |
| Volatile Matter | 31.7 | % |
| Fixed Carbon | 54.1 | % |
| Total | 100 | % |
| Other Properties | | |
| Specific Heat @ 25C, dry | 1.214 | kJ/kg-C |
| Specific Heat @ 300C, dry | 1.968 | kJ/kg-C |
| Bulk density | 768.9 | kg/m ³ |
| Hardgrove Grindability Index (HGI) | 50 | |
| Mercury content (dry basis) | 0 | ppmw |
| Ash Analysis (weight %) | | |
| SiO ₂ | 63.9 | % |
| Al ₂ O ₃ | 22.3 | % |
| Fe ₂ O ₃ | 7.4 | % |
| CaO | 0.8 | % |
| MgO | 0.7 | % |
| Na ₂ O | 0.2 | % |
| K ₂ O | 1.6 | % |
| TiO ₂ | 0.8 | % |
| P ₂ O ₅ | 0.7 | % |
| SO ₃ | 0.5 | % |
| Other | 1.1 | % |
| Total | 100 | % |
| Ash Characteristics | | |
| Fouling | | Low/Medium |
| Ash Initial Deformation Temperature (reducing atm.) | 1280 | C |
| Ash Softening Temperature (reducing atm.) | 1480 | C |

| Pulverizer | | |
|---|-------------------------|-------------------|
| Design Data | | |
| Pulverizer type | Vertical air-swept mill | |
| Number per boiler | 6 | |
| Number operating | 5 | |
| Capacity margin | 15 | % |
| Nameplate capacity at standard condition* (each) | 44.98 | tonne/hr |
| Full load capacity at current condition** (each) | 44.98 | tonne/hr |
| Fineness correction factor | 1 | |
| HGI correction factor | 1 | |
| Moisture correction factor | 1 | |
| Total correction factor | 1 | |
| Nameplate specific power consumption | 22.05 | kWh/tonne |
| Specific power consumption at current condition | 22.05 | kWh/tonne |
| * Nameplate condition: Fineness = 70%, Moisture = 8%, HGI = 50 | | |
| ** Current condition: Fineness = 70%, Moisture = 4.8%, HGI = 50 | | |
| Heat Balance (each) | | |
| Desired pulverizer exit temperature | 70 | C |
| Desired fuel outlet moisture | 1.734 | % |
| Air/fuel mass ratio | 1.75 | |
| Total power consumption | 862.3 | kW |
| Fuel in | | |
| Flow | 39.11 | t/h |
| Temperature | 25 | C |
| Moisture | 4.8 | % |
| LHV | 27905 | kJ/kg |
| HHV | 28930 | kJ/kg |
| Fuel out | | |
| Flow | 37.89 | t/h |
| Temperature | 70 | C |
| Moisture | 1.734 | % |
| LHV | 28882 | kJ/kg |
| HHV | 29862 | kJ/kg |
| Hot gas inlet | | |
| Hot gas flow | 34.7 | t/h |
| Hot gas pressure | 1.125 | bar |
| Hot gas temperature | 182.2 | C |
| Tempering air flow | 33.75 | t/h |
| Tempering air pressure | 1.125 | bar |
| Tempering air temperature | 37.06 | C |
| Drying air flow | 68.45 | t/h |
| Drying air temperature | 110.9 | C |
| Pressure | 1.125 | bar |
| Percentage of tempering air over drying air | 49.3 | % |
| Gas outlet | | |
| Mass flow | 69.67 | t/h |
| Pressure | 1.1 | bar |
| Temperature | 70 | C |
| Gauge pressure | 99.63 | millibar |
| Dew point | 33.16 | C |
| Relative humidity | 16.28 | % |
| Volume flow | 17.64 | m ³ /s |
| Pulverizer(integral) Performance | | |
| Total moisture evaporated | 6.101 | t/h |
| Actual percentage of fuel moisture evaporated | 65 | % |
| Total power consumption | 4311 | kW |
| Pressure drop | 24.91 | millibar |
| Energy in | | |
| Energy provided by drying fluid | 793.1 | kW |
| Grinding heat | 689.8 | kW |
| Total | 1482.9 | kW |
| Energy consumed | | |
| Fuel heating | 692 | kW |
| Moisture evaporation | 790.9 | kW |
| Total | 1482.9 | kW |

| | | |
|---|-----------|------------|
| ECO1 | | |
| Heat Balance | | |
| Inlet Water | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 306.7 | bar |
| Temperature | 287.7 | C |
| Enthalpy | 1267 | kJ/kg |
| Exit Water | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 303.7 | bar |
| Temperature | 343.5 | C |
| Enthalpy | 1568.3 | kJ/kg |
| Gas | | |
| Mass flow | 2359.3 | t/h |
| Flyash mass flow | 15.09 | t/h |
| Inlet temperature | 548 | C |
| Exit temperature | 338.4 | C |
| Sulfur dew point temperature | 119.8 | C |
| Dew point temperature | 40.5 | C |
| Static pressure drop | 0.6971 | millibar |
| Heat Transfer | | |
| Heat from gas | 157273 | kW |
| Heat from ash | 1034.5 | kW |
| Heat transfer to water/steam | 155968 | kW |
| Heat loss | 2339.5 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Solid fins |
| Tube arrangement | | In line |
| Tube material | | T22 |
| Number of tube rows (longitudinal) | | 20 |
| Number of tubes per row (transverse) | | 134 |
| Number of rows per waterside flow pass | | 2 |
| Longitudinal row pitch | 101.6 | mm |
| Gas path transverse width | 18.72 | m |
| Tube length | 18.34 | m |
| Tube outer diameter | 50.8 | mm |
| Tube wall thickness | 7.62 | mm |
| Transverse tube pitch | 139.7 | mm |
| Tube metal conductivity @ 500F (260C) | 36.86 | W/m-C |
| Tube metal conductivity slope | -0.0109 | W/m-C^2 |
| Fins | | |
| Fin material | | T22 |
| Fin height | 19.05 | mm |
| Fin spacing | 8.944 | mm |
| Fin thickness | 1.905 | mm |
| Number of fins per meter | 92.17 | per meter |
| Fin metal conductivity @ 500F (260C) | 36.86 | W/m-C |
| Fin metal conductivity slope | -0.0109 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 343.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5884 | |
| H.T. surface area / min. free flow cross section | 11.57 | |
| Primary tube surface / total heat transfer surf. | 0.1383 | |
| Water side flow cross section area | 0.2662 | m^2 |
| Heat exchanger prime outside surface | 6468 | m^2 |
| Heat exchanger total fin area | 40295 | m^2 |
| Heat exchanger total outside area | 46763 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 4.402 | m/s |
| Face mass flux | 6.915 | t/h-m^2 |
| Velocity at minimum flow area | 7.482 | m/s |
| Mass flux at minimum flow area | 11.75 | t/h-m^2 |
| Reynolds number | 5377 | |
| Prandtl number | 0.7196 | |
| Convective Nusselt number | 42.94 | |
| Convective heat transfer coefficient | 40.77 | W/m^2-C |
| Radiative heat transfer coefficient | 2.297 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 43.06 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1799 | |
| Friction factor Re coefficient | 3.222 | |
| Radiation beam mean length | 0.257 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.6971 | millibar |

| ECO1 | | |
|--|------------|---------------------|
| Water Side | | |
| Mass flux | 7001 | t/h-m ² |
| Mean velocity | 2.689 | m/s |
| Reynolds number | 786625 | |
| Prandtl number | 0.8345 | |
| Nusselt number | 1128.3 | |
| Heat transfer coefficient | 17818 | W/m ² -C |
| Fouling resistance | 1.7612E-04 | m ² -C/W |
| Pressure drop correction factor | 1.402 | |
| User-defined pressure drop | 3.037 | bar |
| Hardware determined pressure drop | 2.166 | bar |
| Overall Performance | | |
| Fin effectiveness | 0.794 | |
| Effective / total external area | 0.8225 | |
| Overall heat transfer coefficient | 30.24 | W/m ² -C |
| Tube metal mean temperature | 322.9 | C |
| Fin metal mean temperature | 340.2 | C |
| Estimated minimum tube surface temperature | 293.5 | C |
| Estimated maximum tube wall temperature | 366.8 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum fin tip temperature | 415.1 | C |
| Recommended maximum fin metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 392.7 | bar |
| Heat transfer rate from gas | 157273 | kW |
| Heat from fly ash | 1034.5 | kW |
| Heat transfer rate to water | 155968 | kW |
| Heat loss | 2339.5 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 1414.1 | kW/C |
| Heat exchanger effectiveness | 0.8052 | |

| | | |
|---|------------|----------|
| CS1 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 288.5 | bar |
| Temperature | 427.6 | C |
| Enthalpy | 2691 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 285.9 | bar |
| Temperature | 462.5 | C |
| Enthalpy | 2934.7 | kJ/kg |
| Gas | | |
| Mass flow | 2359.3 | t/h |
| Flyash mass flow | 15.09 | t/h |
| Inlet temperature | 875.1 | C |
| Exit temperature | 718.4 | C |
| Static pressure drop | 0.2472 | millibar |
| Heat Transfer | | |
| Heat from gas | 127232 | kW |
| Heat from ash | 814 | kW |
| Heat transfer to water/steam | 126154 | kW |
| Heat loss | 1892.3 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Bare |
| Tube arrangement | | In line |
| Tube material | | T91 |
| Number of tube rows (longitudinal) | | 16 |
| Number of tubes per row (transverse) | | 120 |
| Number of rows per waterside flow pass | | 2 |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 18.87 | m |
| Tube length | 18.2 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 7.62 | mm |
| Transverse tube pitch | 157.2 | mm |
| Tube metal conductivity @ 500F (260C) | 27 | W/m-C |
| Tube metal conductivity slope | 0.0053 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 343.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5961 | |
| H.T. surface area / min. free flow cross section | 2.128 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 0.439 | m^2 |
| Heat exchanger prime outside surface | 6971 | m^2 |
| Heat exchanger total outside area | 6971 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 6.151 | m/s |
| Face mass flux | 6.915 | t/h-m^2 |
| Velocity at minimum flow area | 10.32 | m/s |
| Mass flux at minimum flow area | 11.6 | t/h-m^2 |
| Reynolds number | 5330 | |
| Prandtl number | 0.7172 | |
| Convective Nusselt number | 41.93 | |
| Convective heat transfer coefficient | 42.28 | W/m^2-C |
| Radiative heat transfer coefficient | 14.57 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 56.85 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1769 | |
| Friction factor Re coefficient | 0.1003 | |
| Radiation beam mean length | 0.1495 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.2472 | millibar |
| Water Side | | |
| Mass flux | 4245 | t/h-m^2 |
| Mean velocity | 8.305 | m/s |
| Reynolds number | 1886004 | |
| Prandtl number | 1.556 | |
| Nusselt number | 2789.3 | |
| Heat transfer coefficient | 7373 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 2.056 | |
| User-defined pressure drop | 2.596 | bar |
| Hardware determined pressure drop | 2.294 | bar |

| CS1 | | |
|--|--------|---------------------|
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 51.98 | W/m ² -C |
| Tube metal mean temperature | 452.1 | C |
| Estimated minimum tube surface temperature | 439.2 | C |
| Estimated maximum tube wall temperature | 478.9 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 340.4 | bar |
| Heat transfer rate from gas | 127232 | kW |
| Heat from fly ash | 814 | kW |
| Heat transfer rate to water | 126154 | kW |
| Heat loss | 1892.3 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 362.3 | kW/C |
| Heat exchanger effectiveness | 0.3502 | |

| | | |
|---|------------|----------|
| CS2 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 282.7 | bar |
| Temperature | 532.3 | C |
| Enthalpy | 3236 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 280.1 | bar |
| Temperature | 606 | C |
| Enthalpy | 3480 | kJ/kg |
| Gas | | |
| Mass flow | 2359.3 | t/h |
| Flyash mass flow | 15.09 | t/h |
| Inlet temperature | 1176.7 | C |
| Exit temperature | 1036.2 | C |
| Static pressure drop | 0.1285 | millibar |
| Heat Transfer | | |
| Heat from gas | 119282 | kW |
| Radiant heat influx | 8071 | kW |
| Heat from ash | 690.6 | kW |
| Heat transfer to water/steam | 126152 | kW |
| Heat loss | 1892.3 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | Bare | |
| Tube arrangement | In line | |
| Tube material | TP347 HFG | |
| Number of tube rows (longitudinal) | 14 | |
| Number of tubes per row (transverse) | 80 | |
| Number of rows per waterside flow pass | 7 | |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 18.71 | m |
| Tube length | 18.84 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 8.344 | mm |
| Transverse tube pitch | 233.9 | mm |
| Tube metal conductivity @ 500F (260C) | 18.34 | W/m-C |
| Tube metal conductivity slope | 0.015 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 352.6 | m^2 |
| Min. gas free flow cross section / frontal area | 0.7285 | |
| H.T. surface area / min. free flow cross section | 1.171 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 0.9639 | m^2 |
| Heat exchanger prime outside surface | 4210 | m^2 |
| Heat exchanger total outside area | 4210 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 7.56 | m/s |
| Face mass flux | 6.734 | t/h-m^2 |
| Velocity at minimum flow area | 10.38 | m/s |
| Mass flux at minimum flow area | 9.243 | t/h-m^2 |
| Reynolds number | 3663 | |
| Prandtl number | 0.716 | |
| Convective Nusselt number | 28.9 | |
| Convective heat transfer coefficient | 35.29 | W/m^2-C |
| Radiative heat transfer coefficient | 28.9 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 64.19 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1557 | |
| Friction factor Re coefficient | 0.0688 | |
| Radiation beam mean length | 0.2479 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.1285 | millibar |
| Water Side | | |
| Mass flux | 1933.4 | t/h-m^2 |
| Mean velocity | 6.193 | m/s |
| Reynolds number | 744838 | |
| Prandtl number | 1.043 | |
| Nusselt number | 1162.4 | |
| Heat transfer coefficient | 2608.1 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 2.056 | |
| User-defined pressure drop | 2.596 | bar |
| Hardware determined pressure drop | 0.2314 | bar |

| CS2 | | |
|--|--------|---------------------|
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 56.48 | W/m ² -C |
| Tube metal mean temperature | 588 | C |
| Estimated minimum tube surface temperature | 577.6 | C |
| Estimated maximum tube wall temperature | 636.3 | C |
| Maximum allowable tube wall metal temperature | 1093.3 | C |
| Estimated maximum allowable water side pressure | 296.9 | bar |
| Heat transfer rate from gas | 119282 | kW |
| Radiant heat influx | 8071 | kW |
| Heat from fly ash | 690.6 | kW |
| Heat transfer rate to water | 126152 | kW |
| Heat loss | 1892.3 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 237.8 | kW/C |
| Heat exchanger effectiveness | 0.218 | |

| | | |
|---|------------|----------|
| CR1 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1689.2 | t/h |
| Pressure | 63.04 | bar |
| Temperature | 372.7 | C |
| Enthalpy | 3102 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1689.2 | t/h |
| Pressure | 62.12 | bar |
| Temperature | 485.3 | C |
| Enthalpy | 3385 | kJ/kg |
| Gas | | |
| Mass flow | 2359.3 | t/h |
| Flyash mass flow | 15.09 | t/h |
| Inlet temperature | 718.4 | C |
| Exit temperature | 548 | C |
| Static pressure drop | 0.5709 | millibar |
| Heat Transfer | | |
| Heat from gas | 133889 | kW |
| Heat from ash | 890.2 | kW |
| Heat transfer to water/steam | 132787 | kW |
| Heat loss | 1991.8 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | Bare | |
| Tube arrangement | In line | |
| Tube material | T91 | |
| Number of tube rows (longitudinal) | 24 | |
| Number of tubes per row (transverse) | 146 | |
| Number of rows per waterside flow pass | 4 | |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 18.8 | m |
| Tube length | 18.26 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 2.794 | mm |
| Transverse tube pitch | 128.8 | mm |
| Tube metal conductivity @ 500F (260C) | 27 | W/m-C |
| Tube metal conductivity slope | 0.0053 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 343.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5069 | |
| H.T. surface area / min. free flow cross section | 3.056 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 1.538 | m^2 |
| Heat exchanger prime outside surface | 12767 | m^2 |
| Heat exchanger total outside area | 12767 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 5.313 | m/s |
| Face mass flux | 6.915 | t/h-m^2 |
| Velocity at minimum flow area | 10.48 | m/s |
| Mass flux at minimum flow area | 13.64 | t/h-m^2 |
| Reynolds number | 6743 | |
| Prandtl number | 0.7177 | |
| Convective Nusselt number | 51.9 | |
| Convective heat transfer coefficient | 47.59 | W/m^2-C |
| Radiative heat transfer coefficient | 9.892 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 57.48 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1879 | |
| Friction factor Re coefficient | 0.1364 | |
| Radiation beam mean length | 0.1129 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.5709 | millibar |
| Water Side | | |
| Mass flux | 1098.1 | t/h-m^2 |
| Mean velocity | 14.62 | m/s |
| Reynolds number | 688430 | |
| Prandtl number | 0.992 | |
| Nusselt number | 1073.7 | |
| Heat transfer coefficient | 1185.6 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 0.8917 | |
| User-defined pressure drop | 0.918 | bar |
| Hardware determined pressure drop | 0.7953 | bar |

| | | |
|--|--------|---------------------|
| CR1 | | |
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 51.27 | W/m ² -C |
| Tube metal mean temperature | 435.4 | C |
| Estimated minimum tube surface temperature | 383.7 | C |
| Estimated maximum tube wall temperature | 499.9 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 105.1 | bar |
| Heat transfer rate from gas | 133889 | kW |
| Heat from fly ash | 890.2 | kW |
| Heat transfer rate to water | 132787 | kW |
| Heat loss | 1991.8 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 654.5 | kW/C |
| Heat exchanger effectiveness | 0.4928 | |

| | | |
|---|------------|-----------|
| CR2 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1689.2 | t/h |
| Pressure | 62.12 | bar |
| Temperature | 485.3 | C |
| Enthalpy | 3385 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1689.2 | t/h |
| Pressure | 61.2 | bar |
| Temperature | 605.4 | C |
| Enthalpy | 3668 | kJ/kg |
| Gas | | |
| Mass flow | 2359.3 | t/h |
| Flyash mass flow | 15.09 | t/h |
| Inlet temperature | 1036.2 | C |
| Exit temperature | 875.1 | C |
| Static pressure drop | 0.1752 | millibar |
| Heat Transfer | | |
| Heat from gas | 133989 | kW |
| Heat from ash | 790.3 | kW |
| Heat transfer to water/steam | 132787 | kW |
| Heat loss | 1991.8 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Bare |
| Tube arrangement | | In line |
| Tube material | | TP347 HFG |
| Number of tube rows (longitudinal) | | 20 |
| Number of tubes per row (transverse) | | 84 |
| Number of rows per waterside flow pass | | 5 |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 18.61 | m |
| Tube length | 18.95 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 2.794 | mm |
| Transverse tube pitch | 221.6 | mm |
| Tube metal conductivity @ 500F (260C) | 18.34 | W/m-C |
| Tube metal conductivity slope | 0.015 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 352.6 | m^2 |
| Min. gas free flow cross section / frontal area | 0.7134 | |
| H.T. surface area / min. free flow cross section | 1.262 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 1.106 | m^2 |
| Heat exchanger prime outside surface | 6349 | m^2 |
| Heat exchanger total outside area | 6349 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 6.829 | m/s |
| Face mass flux | 6.734 | t/h-m^2 |
| Velocity at minimum flow area | 9.572 | m/s |
| Mass flux at minimum flow area | 9.439 | t/h-m^2 |
| Reynolds number | 3954 | |
| Prandtl number | 0.7165 | |
| Convective Nusselt number | 30.92 | |
| Convective heat transfer coefficient | 35.16 | W/m^2-C |
| Radiative heat transfer coefficient | 23.93 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 59.08 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1585 | |
| Friction factor Re coefficient | 0.0715 | |
| Radiation beam mean length | 0.2321 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.1752 | millibar |
| Water Side | | |
| Mass flux | 1526.9 | t/h-m^2 |
| Mean velocity | 24.96 | m/s |
| Reynolds number | 802304 | |
| Prandtl number | 0.9309 | |
| Nusselt number | 1188.3 | |
| Heat transfer coefficient | 1580.9 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 0.8917 | |
| User-defined pressure drop | 0.918 | bar |
| Hardware determined pressure drop | 1.264 | bar |

| | | |
|--|--------|---------------------|
| CR2 | | |
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 53.11 | W/m ² -C |
| Tube metal mean temperature | 556.5 | C |
| Estimated minimum tube surface temperature | 515.2 | C |
| Estimated maximum tube wall temperature | 620 | C |
| Maximum allowable tube wall metal temperature | 1093.3 | C |
| Estimated maximum allowable water side pressure | 93.06 | bar |
| Heat transfer rate from gas | 133989 | kW |
| Heat from fly ash | 790.3 | kW |
| Heat transfer rate to water | 132787 | kW |
| Heat loss | 1991.8 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 337.2 | kW/C |
| Heat exchanger effectiveness | 0.2923 | |
| | | |

| | | |
|---|---------|----------|
| Furnace | | |
| Design Heat Balance: Once through - Coal fired | | |
| Furnace gage pressure | -0.6226 | millibar |
| Excess air | 20 | % |
| Secondary Air | | |
| Temperature | 273.9 | C |
| Mass flow | 1840.3 | t/h |
| Primary Air into Pulverizer | | |
| Temperature | 182.2 | C |
| Mass flow | 173.5 | t/h |
| Tempering Air into Pulverizer | | |
| Temperature | 37.06 | C |
| Mass flow | 168.7 | t/h |
| Pulverizer inlet Dry Air | | |
| Temperature | 110.9 | C |
| Mass flow | 342.2 | t/h |
| Pulverizer outlet Gas | | |
| Temperature | 70 | C |
| Mass flow | 348.3 | t/h |
| Gage pressure | 124.5 | millibar |
| Flue Gas | | |
| Temperature | 1176.7 | C |
| Mass flow | 2359.2 | t/h |
| Ash mass flow | 15.09 | t/h |
| Mole percent N2 | 73.65 | % |
| Mole percent O2 | 3.287 | % |
| Mole percent CO2 | 14.55 | % |
| Mole percent H2O | 7.587 | % |
| Mole percent SO2 | 0.044 | % |
| Mole percent Ar | 0.8853 | % |
| SO3 in flue gas | 2.2 | ppm |
| Emission | | |
| Reference O2 content | 6 | % |
| Actual O2 content in exit gas | 3.287 | % |
| H2O content in exit gas | 7.587 | % |
| Hg from combustion | 0 | kg/hr |
| Hg in exit gas | 0 | kg/hr |
| HCl in exit gas | 64.36 | kg/hr |
| NOx production | 0 | kg/hr |
| NOx volume concentration in exit gas | 0 | ppmv |
| NOx mass concentration in exit gas | 0 | ppm |
| Exit Steam | | |
| Steam produced by waterwall | 1863.6 | t/h |
| Pressure | 288.5 | bar |
| Temperature | 427.6 | C |
| Enthalpy | 2691 | kJ/kg |
| Inlet Water | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 303.7 | bar |
| Temperature | 343.5 | C |
| Enthalpy | 1568.3 | kJ/kg |
| Radiant Superheater Exit Steam | | |
| Mass flow | 1863.6 | t/h |
| Pressure | 282.7 | bar |
| Temperature | 532.3 | C |
| Enthalpy | 3236 | kJ/kg |
| Radiant Superheater Inlet Steam | | |
| Pressure | 285.9 | bar |
| Temperature | 462.5 | C |
| Enthalpy | 2934.7 | kJ/kg |
| Inlet Fuel : Solid | | |
| Fuel mass flow | 195.6 | t/h |
| LHV @ 77 F (25 C) | 27905 | kJ/kg |
| HHV @ 77 F (25 C) | 28930 | kJ/kg |
| Fuel input (LHV) | 1515.9 | MW |
| Fuel input (HHV) | 1571.6 | MW |
| Weight percent ash | 9.4 | % |
| Fuel ash flow | 18.38 | t/h |
| Fuel inlet temperature | 25 | C |
| Exit Ash | | |
| Bottom ash flow | 3.773 | t/h |
| Unburnt carbon flow in bottom ash | 0.0968 | t/h |

| | | |
|---|----------------|--------------------|
| Furnace | | |
| Unburnt carbon in bottom ash | 2.566 | % |
| Fly ash flow | 15.09 | t/h |
| Unburnt carbon flow in fly ash | 0.3872 | t/h |
| Unburnt carbon in fly ash | 2.566 | % |
| Total unburnt carbon flow in ash | 0.484 | t/h |
| Combustion efficiency | 99.7 | % |
| Heat Transfer | | |
| Heat transfer to waterwall | 581189 | kW |
| Heat transfer to radiant superheater | 156065 | kW |
| Unburnt carbon in ash | 4535 | kW |
| Heat losses | 11058 | kW |
| Radiant flux past screen | 8071 | kW |
| Bottom ash (bed drain) sensible heat | 1364.2 | kW |
| Fly ash sensible heat | 5457 | kW |
| Performance | | |
| Fuel delivery power | 4311 | kW |
| Ash handling power | 831.9 | kW |
| Heat Transfer | | |
| Furnace Ratings | | |
| Heat absorption rate | 107.2 | kW/m ² |
| Heat release rate | 235.4 | kW/m ² |
| Volumetric heat release rate | 75.1 | kW/m ³ |
| Heat Transfer and Heat Balance | | |
| Energy In | | |
| Fuel input | 1515874 | kW |
| Fuel delivery energy included in heat balance calculation | 3449 | kW |
| Air input | 139433 | kW |
| Total Energy In | 1658755 | kW |
| Energy Out | | |
| Flue gas | 890994 | kW |
| Heat transfer to waterwall | 581189 | kW |
| Heat transfer to radiant superheater | 156065 | kW |
| Heat losses | 11058 | kW |
| Radiant flux past screen | 8071 | kW |
| Unburnt carbon in ash | 4535 | kW |
| Bottom ash (bed drain) sensible heat | 1364.2 | kW |
| Fly ash sensible heat | 5457 | kW |
| Total Energy Out | 1658733 | kW |
| Heat Balance Error | 0.0013 | % |
| Heat Transfer Characteristics | | |
| Gas emissivity | 0.8402 | |
| Gas absorptivity | 0.8606 | |
| Radiating mean beam length | 14.51 | m |
| Adiabatic temperature | 2029.4 | C |
| Effective radiating temperature | 1607.1 | C |
| Waterwall surface temperature | 1163.1 | C |
| Furnace exit temperature | 1176.7 | C |
| Gas mass flux @ aperture | 6.734 | t/h-m ² |
| Gas velocity leaving aperture @ furnace exit temperature | 7.561 | m/s |
| Furnace velocity @ Effective radiating temperature | 10 | m/s |
| Radiant flux to waterwall effective projected heat transfer surface | 112.7 | kW/m ² |
| Mean flux to waterwall effective projected heat transfer surface | 113.5 | kW/m ² |

| | | |
|---|--------|---------------------|
| Rotary Air Heater | | |
| Heat Balance | | |
| Number per station | | 3 |
| Number operating | | 3 |
| Primary Air Path (station) | | |
| Primary air flow | 173.5 | t/h |
| Primary air temperature | 182.2 | C |
| Inlet air flow | 199.5 | t/h |
| Inlet pressure | 1.13 | bar |
| Inlet temperature | 37.06 | C |
| Cold side leakage | 17.35 | t/h |
| Hot side leakage | 8.675 | t/h |
| Pressure drop | 4.869 | millibar |
| Channel velocity | 6.761 | m/s |
| Reynolds number | 3147 | |
| Stanton number | 0.005 | |
| Heat transfer coefficient | 49.73 | W/m ² -C |
| Secondary Air Path (station) | | |
| Secondary air flow | 1840.3 | t/h |
| Secondary air temperature | 273.9 | C |
| Inlet pressure | 1.018 | bar |
| Inlet temperature | 27.94 | C |
| Cold side leakage to flue gas | 128.8 | t/h |
| Hot side leakage to flue gas | 55.21 | t/h |
| Pressure drop | 6.207 | millibar |
| Channel velocity | 8.317 | m/s |
| Reynolds number | 2914.5 | |
| Stanton number | 0.0051 | |
| Heat transfer coefficient | 50.78 | W/m ² -C |
| Flue Gas Path (station) | | |
| Flue gas flow | 2359.3 | t/h |
| Fly ash flow | 15.09 | t/h |
| Flue gas temperature | 338.4 | C |
| After mixing with hot side leakages | 336.5 | C |
| Exit temperature (uncorrected) | 144.1 | C |
| Exit temperature with leakage (corrected) | 137.8 | C |
| Exit flow | 2569.3 | t/h |
| Pressure @ heater inlet | 0.9976 | bar |
| Pressure drop | 9.101 | millibar |
| Channel velocity | 11.58 | m/s |
| Reynolds number | 3137 | |
| Stanton number | 0.0051 | |
| Heat transfer coefficient | 60.73 | W/m ² -C |
| Performance (station) | | |
| Flue gas heat transfer to air paths | 140132 | kW |
| Fly ash heat transfer to air paths | 850 | kW |
| Secondary air heat transfer | 133458 | kW |
| Primary air heat transfer | 7524 | kW |
| Average cold end temperature (ACET) | 86.04 | C |
| Cold end minimum metal temperature | 68.33 | C |
| Flue gas exit water dew point temperature | 39.09 | C |
| Flue gas exit SO3 | 2.014 | ppm |
| Flue gas exit sulfur dew point temperature | 118.1 | C |
| Flue gas sulfur dew point temperature within air heater | 119.1 | C |
| Heat transfer effectiveness | 77.07 | % |
| Modified number of transfer units (NTU0) | 2.602 | |

| Heat Balance Results | | | |
|--|----------------------|--|-------------------------------------|
| Stack | | | |
| Inlet | | | |
| Pressure | 0.9972 | bar | |
| Temperature | 140.9 | C | |
| Mass flow | 2569.3 | t/h | |
| Exit to air | | | |
| Pressure | 0.9823 | bar | |
| Temperature | 140.9 | C | |
| Water dew point temperature | 39.25 | C | |
| Sulfur dew point temperature | 138 | C | |
| Mass flow | 2569.3 | t/h | |
| Mercury (Hg) | 0 | kg/hr | |
| Exit Velocity | 18.29 | m/s | |
| Miscellaneous | | | |
| Heat loss | 0 | kW | |
| Buoyancy (DPc-DPh) | 5.473 | millibar | |
| -- Pressure by cold air column outside stack (DPc) | 17.67 | millibar | |
| -- Pressure by hot air column inside stack (DPh) | 12.2 | millibar | |
| Pressure drop (inlet to ambient) | -2.81 | millibar | |
| -- Entrance loss | 0.8655 | millibar | |
| -- Leaving loss | 1.443 | millibar | |
| -- Friction loss | 0.3554 | millibar | |
| -- Buoyancy gain | 5.473 | millibar | |
| Emissions | | | |
| | ng/J25C HHV @ | mg/Nm³ @ 6% O₂, dry | ppmv @ 6% O₂, dry |
| Dust load | 13.34 | 39.59 | |
| Sulfur Dioxide (SO ₂) | 393.9 | 1169.2 | 409.1 |
| Nitrogen Oxides (NO _x) | 0 | 0 | 0 |
| Mercury (Hg) | 0 | 0 | 0 |
| Plume invisible | | | |
| Plume visibility index | 0 | | |

| STEAM PRO 26.1 GHD GHD Pty Ltd | | | | | | | | | | |
|---|----------|-------------|-----------|--------|---------|-----------|----------|---------|-------|---------|
| 588 04-21-2017 16:13:26 G:\41\30763\Tech\HELE documentation\Model\USC model_wet cooling.stp | | | | | | | | | | |
| Program revision date: February 16, 2017 | | | | | | | | | | |
| Steam source: Conventional boiler | | | | | | | | | | |
| Steam turbine: Single reheat condensing turbine 3000+3000/3000 | | | | | | | | | | |
| Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train | | | | | | | | | | |
| Cooling system: Water cooling with natural draft cooling tower | | | | | | | | | | |
| Steam Property Formulation: IFC-67 | | | | | | | | | | |
| STEAM CYCLE HEAT BALANCE | | | | | | | | | | |
| Energy in = | | 1436424 | kJ/s | | | | | | | |
| Boiler Heat | External | | External | Makeup | Process | Pump | Blowdown | | | |
| Addition | Steam | | Water | | Return | Aux. Load | Recovery | | | |
| 1411123 | 0 | | 0 | 0 | 0 | 25300 | 0 | | | |
| Energy out = | | 1436438 | kJ/s | | | | | | | |
| ST/Gen | BFPT | Mech/Elec/ | Main | BFPT | Process | | Pipe | CO2 | Desal | Others* |
| Output | Output | Gear Losses | Condenser | | Steam | Water | Losses | Capture | | |
| 675529 | 23682 | 7598 | 724868 | 0 | 0 | 0 | 3902 | 0 | 0 | 860 |
| * 'Others' includes pump losses, heat to air heater, fuel heater, district heating system, misc heat to/from condensate, discharged seal steam and blowdown. | | | | | | | | | | |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | | | | | | | | | |
| Heat Balance Error (In - Out) = | | | -14.2 | kJ/s | = | -0.0010 | % | | | |

| STEAM TURBINE FLOWS | | | | | | | | | | |
|----------------------|---------|-------|--------|----------|---------|---------------|---------|---------|---------|--------|
| | P | T | h | M | s | Super-heat, C | Quality | Exp Pwr | Eff | # of |
| | bar | C | kJ/kg | t/h | kJ/kg-K | | | kW | % | Stages |
| HP steam | 280.140 | 606.0 | 3479.9 | 1863.565 | | | | | | |
| HP pipe inlet | 280.140 | 606.0 | 3479.9 | 1863.565 | | | | | | |
| HP pipe outlet | 276.000 | 604.0 | 3477.6 | 1863.565 | | | | | | |
| ST inlet | 276.000 | 604.0 | 3477.6 | 1863.565 | 6.3065 | 211.2 | | | | |
| After HPT stop valve | 269.100 | 601.9 | 3477.6 | | | | | | | |
| -Valve Stem leak 1 | | | 3477.6 | -4.186 | | | | | | |
| -Valve Stem leak 2 | | | 3477.6 | -1.380 | | | | | | |
| -HPT HP leak 1 | | | 3477.6 | -26.321 | | | | | | |
| HPT Casing: Group 1 | | | | | | | | | | |
| GROUP IN | 269.100 | 601.9 | 3477.6 | 1831.677 | 6.3166 | 211.2 | | | 68.47* | 1 |
| GROUP OUT | 212.308 | 562.3 | 3416.5 | 1831.677 | 6.3403 | 191.6 | | 31079 | 75.57** | |
| HPT Casing: Group 2 | | | | | | | | | | |
| GROUP IN | 212.308 | 562.3 | 3416.5 | 1831.677 | 6.3403 | 191.6 | | | 88.79* | 9 |
| GROUP OUT | 64.297 | 374.5 | 3104.0 | 1831.677 | 6.4019 | 94.4 | | 158997 | 88.79** | |
| Port (1) extraction | 64.297 | 374.5 | 3104.0 | -128.630 | 6.4019 | 94.4 | | | | |
| -HPT LP leak 1 | | | 3104.0 | -11.376 | | | | | | |
| -HPT LP leak 2 | | | 3104.0 | -2.435 | | | | | | |
| Cold RH pipe inlet | 64.297 | 374.5 | 3104.0 | 1689.237 | 6.4019 | 94.4 | | | | |
| Cold RH pipe outlet | 63.036 | 372.7 | 3101.7 | 1689.237 | | | | | | |
| RH steam | 61.200 | 605.4 | 3667.7 | 1689.237 | | | | | | |
| Hot RH pipe inlet | 61.200 | 605.4 | 3667.7 | 1689.237 | | | | | | |
| Hot RH pipe outlet | 60.000 | 604.0 | 3665.3 | 1689.237 | | | | | | |
| IPT inlet | 60.000 | 604.0 | 3665.3 | 1689.237 | 7.1767 | 328.4 | | | | |
| +Valve Stem leak 1 | | | 3477.6 | 4.186 | | | | | | |
| +HPT HP leak 1 | | | 3477.6 | 26.321 | | | | | | |
| IP bowl | 58.800 | 602.2 | 3662.0 | 1719.744 | 7.1819 | 327.9 | | | | |
| IPT1 Casing: Group 3 | | | | | | | | | | |
| GROUP IN | 58.800 | 602.2 | 3662.0 | 1719.744 | 7.1819 | 327.9 | | | 82.61* | 3 |
| GROUP OUT | 42.666 | 549.7 | 3555.2 | 1719.744 | 7.2001 | 295.6 | | 51010 | 87.61** | |
| Port (3) extraction | 42.666 | 549.7 | 3555.2 | -119.647 | 7.2001 | 295.6 | | | | |
| IPT1 Casing: Group 4 | | | | | | | | | | |
| GROUP IN | 42.666 | 549.7 | 3555.2 | 1600.098 | 7.2001 | 295.6 | | | 89.22* | 4 |
| GROUP OUT | 22.902 | 454.3 | 3363.3 | 1600.098 | 7.2321 | 235.0 | | 85319 | 89.22** | |
| Port (4) extraction | 22.902 | 454.3 | 3363.3 | -63.906 | 7.2321 | 235.0 | | | | |

| IPT1 Casing: Group 5 | | | | | | | | | | |
|---|--------|-------|--------|----------|--------|-------|-------|-------|---------|---|
| GROUP IN | 22.902 | 454.3 | 3363.3 | 1536.191 | 7.2321 | 235.0 | | | 90.06* | 3 |
| GROUP OUT | 13.040 | 375.4 | 3206.9 | 1536.191 | 7.2589 | 183.7 | | 66725 | 90.06** | |
| Port (5) extraction | 13.040 | 375.4 | 3206.9 | -74.550 | 7.2589 | 183.7 | | | | |
| IPT1 Casing: Group 6 | | | | | | | | | | |
| GROUP IN | 13.040 | 375.4 | 3206.9 | 1461.641 | 7.2589 | 183.7 | | | 90.92* | 3 |
| GROUP OUT | 7.000 | 296.5 | 3052.2 | 1461.641 | 7.2862 | 131.5 | | 62834 | 90.92** | |
| Port (6) extraction | 7.000 | 296.5 | 3052.2 | -210.515 | 7.2862 | 131.5 | | | | |
| -IPT LP leak | | | 3052.2 | -2.585 | | | | | | |
| +HPT LP leak 1 | | | 3104.0 | 11.376 | | | | | | |
| LPT crossover | 7.000 | 296.7 | 3052.6 | 1259.917 | 7.2870 | 131.7 | | | | |
| LPT1 Casing: Group 7 | | | | | | | | | | |
| GROUP IN | 7.000 | 296.7 | 3052.6 | 1259.917 | 7.2870 | 131.7 | | | 91.8* | 3 |
| GROUP OUT | 3.083 | 205.1 | 2875.4 | 1259.917 | 7.3202 | 70.6 | | 62036 | 91.8** | |
| Port (7) extraction | 3.083 | 205.1 | 2875.4 | -73.433 | 7.3202 | 70.6 | | | | |
| LPT1 Casing: Group 8 | | | | | | | | | | |
| GROUP IN | 3.083 | 205.1 | 2875.4 | 1186.484 | 7.3202 | 70.6 | | | 92.85* | 2 |
| GROUP OUT | 1.167 | 113.0 | 2700.4 | 1186.484 | 7.3554 | 9.0 | | 57670 | 92.85** | |
| Port (8) extraction | 1.167 | 113.0 | 2700.4 | -69.064 | 7.3554 | 9.0 | | | | |
| LPT1 Casing: Group 9 | | | | | | | | | | |
| GROUP IN | 1.167 | 113.0 | 2700.4 | 1117.421 | 7.3554 | 9.0 | | | 92.57* | 2 |
| GROUP OUT | 0.363 | 73.6 | 2526.1 | 1117.421 | 7.3957 | | 0.954 | 54111 | 92.57** | |
| Port (9) extraction | 0.363 | 73.6 | 2526.1 | -58.428 | 7.3957 | | 0.954 | | | |
| LPT1 Casing: Group 10 | | | | | | | | | | |
| GROUP IN | 0.363 | 73.6 | 2526.1 | 1058.993 | 7.3957 | | 0.954 | | 80.4* | 3 |
| GROUP OUT | 0.072 | 39.5 | 2323.4 | 1058.993 | 7.4689 | | 0.896 | | 89.86** | |
| After LL | 0.072 | 39.5 | 2344.7 | 1058.993 | 7.5371 | | 0.905 | 53345 | | |
| To condenser | 0.072 | 39.5 | 2344.7 | 1058.993 | 7.5371 | | 0.905 | | | |
| *There are 2 symmetric IPT paths, each same as IPT1 | | | | | | | | | | |
| *The LPT mass flow rates are multiplied by 2 | | | | | | | | | | |
| * : Group overall efficiency (including control valve and/or leaving losses) | | | | | | | | | | |
| ** : Group blading efficiency (excluding control valve and/or leaving losses) | | | | | | | | | | |

| STEAM TURBINE DESIGN | | | | | | |
|-----------------------------------|---------------------------------|--------------|------------------|-----------------------|-----------------------|--|
| Group | Adj Nozzle Area, m ² | No. of Steps | Dry Step Eff., % | Group Blading Eff., % | Group Overall Eff., % | |
| 1 | 0.027 | 1 | 75.57 | 75.57 | 68.47 | |
| 2 | 0.022 | 9 | 87.34 | 88.79 | 88.79 | |
| 3 | 0.111 | 3 | 86.77 | 87.61 | 82.61 | |
| 4 | 0.112 | 4 | 88.56 | 89.22 | 89.22 | |
| 5 | 0.194 | 3 | 89.64 | 90.06 | 90.06 | |
| 6 | 0.299 | 3 | 90.51 | 90.92 | 90.92 | |
| 7 | 0.424 | 3 | 91.11 | 91.80 | 91.80 | |
| 8 | 0.806 | 2 | 92.41 | 92.85 | 92.85 | |
| 9 | 1.755 | 2 | 93.17 | 92.57 | 92.57 | |
| 10 | 4.817 | 3 | 95.00 | 89.86 | 80.40 | |
| No. of parallel paths at LPT | | 1 x 2 | | | | |
| Last stage rotor exit angle | | 62.22 | | degree | | |
| Last stage blade length | | 1144.48 | | mm | | |
| Last stage pitch diameter | | 2983.51 | | mm | | |
| Exhaust annulus area / end | | 10.73 | | m ² | | |
| DRY EXHAUST LOSS | | | | | | |
| Annulus Vel | Exh Loss | Annulus Vel | Exh Loss | Annulus Vel | Exh Loss | |
| m/s | kJ/kg | m/s | kJ/kg | m/s | kJ/kg | |
| 39 | 206.59 | 122 | 73.29 | 244 | 28.71 | |
| 46 | 202.27 | 137 | 57.65 | 274 | 38.01 | |
| 53 | 196.68 | 152 | 45.92 | 305 | 52.71 | |
| 61 | 190.46 | 168 | 37.37 | 335 | 70.57 | |
| 76 | 155.45 | 183 | 31.44 | 366 | 89.08 | |
| 91 | 120.74 | 198 | 27.80 | 396 | 106.60 | |
| 107 | 93.89 | 213 | 26.21 | 427 | 123.49 | |
| EXHAUST END VELOCITIES AND LOSSES | | | | | | |
| | | LPT1 | | | | |
| Annulus velocity | | 246.9 | | m/s | | |
| Dry exhaust loss | | 29.35 | | kJ/kg | | |
| Corrected exhaust loss | | 21.34 | | kJ/kg | | |

| STEAM TURBINE CASING POWER | | |
|--|----------|----------------------|
| Casing | | Expansion Power (kW) |
| HPT | | 190076 |
| IPT1 | | 265889 |
| LPT1 x 2 | | 227161 |
| | | |
| H2 COOLED GENERATOR 50 Hz | | |
| Turbine Shaft Speed | 3000 RPM | |
| Expansion power | 683127 | kW |
| ST mechanical loss | 1707.8 | kW |
| ST shaft power | 681419 | kW |
| Generator efficiency | 99.14 | % |
| Generator electrical & mechanical loss | 5889.9 | kW |
| - Generator electrical & windage loss | 5141.4 | kW |
| - Generator mechanical loss | 748.5 | kW |
| Generator power | 675528.9 | kW |
| | | |

| STEAM TURBINE LEAKAGES | | | | | | |
|---|-------------------|---------------|--------------------|-------------------------|---------|--------|
| Group No. | Leakage | Destination | Leakage Flow Model | C Factor m ² | h kJ/kg | M t/h |
| 1 | Valve Stem leak 1 | IPT inlet | Automatic | 8.1 | 3477.6 | 4.186 |
| 2 | Valve Stem leak 2 | SSR | Automatic | 9.3 | 3477.6 | 1.380 |
| 4 | HPT HP leak 1 | IPT inlet | Automatic | 49.9 | 3477.6 | 26.321 |
| 7 | HPT LP leak 1 | LPT cROssover | Automatic | 75.5 | 3104.0 | 11.376 |
| 8 | HPT LP leak 2 | SSR | Automatic | 123.1 | 3104.0 | 2.435 |
| 16 | IPT LP leak | SSR | Automatic | 63.9 | 3052.2 | 2.585 |
| SEALING STEAM REGULATOR & GLAND SEAL CONDENSER (IF ANY) | | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | | |
| Valve Stem leak 2 | | | 3477.6 | 1.38 | | |
| HPT LP leak 2 | | | 3104.0 | 2.435 | | |
| IPT LP leak | | | 3052.2 | 2.585 | | |
| Steam at SSR inlet | 1.241 | 344.4 | 3163.6 | 6.401 | | |
| LPT SS to condenser | | | 3163.6 | 0.5443 | | |
| LPT SS packing exhaust to GSC | | | 3163.6 | 0.6349 | | |
| SS to FWH1 from SSR | | | 3163.6 | 5.222 | | |
| Steam at GSC inlet | 0.8274 | 344.0 | 3163.6 | 0.6349 | | |
| GSC drain to Condenser | | | 395.5 | 0.6349 | | |

| CONDENSER: Water cooling with natural draft cooling tower | | | | | |
|---|--------|-------|-----------|--------|-------|
| | P | T | h | M | |
| | bar | C | kJ/kg | t/h | |
| LPT exhaust | 0.0716 | 39.45 | 2344.7 | 1059 | |
| LPT SS to condenser | | | 3163.6 | 0.5443 | |
| FPT exhaust | 0.0716 | 39.45 | 2410.7 | 133.4 | |
| Drain from GSC | 0.827 | 94.47 | 395.5 | 0.6349 | |
| Condenser in | 0.0716 | 39.45 | 2351.4 | 1193.6 | |
| Condensate | 0.3707 | 39.45 | 165.2 | 1193.6 | |
| Cooling water in | 3.366 | 26.13 | 109.8 | 53678 | |
| Cooling water out | 2.495 | 37.79 | 158.4 | 53678 | |
| Cooled water from cooling tower | 1 | 26.12 | 109.5 | 53678 | |
| Before cooling water pump | 1 | 26.12 | | 53678 | |
| After cooling water pump | 3.366 | 26.13 | 109.8 | 53678 | |
| Hot cooling water mixed from all condensers | 2.495 | 37.79 | 158.4 | 53678 | |
| Hot water to cooling tower | 1.897 | 37.80 | 158.4 | 53678 | |
| Condenser cooling water pump power = | 4435 | | kW | | |
| Main condenser heat rejection = | 724868 | | kJ/s | | |
| COOLING TOWER (Natural Draft) | | | | | |
| | P | T | Twet bulb | M | RH |
| | bar | C | C | t/h | % |
| Air in | 1.00 | 25.00 | 19.45 | 38092 | 60.0 |
| Air out | 1.00 | 34.47 | 34.47 | 38990 | 100.0 |
| Hot water in | 1.90 | 37.80 | | 53678 | |
| Cold water out | 1.00 | 26.12 | | 53678 | |
| Makeup | | | | 1122.5 | |
| Blowdown | | | | 224.5 | |
| Cooling tower heat rejection = | 728999 | | kJ/s | | |
| Range = | 11.68 | | C | | |
| Approach = | 6.667 | | C | | |
| Cycles of concentration = | 5 | | | | |

| CONDENSATE, MAKEUP WATER & FEEDWATER | | | | | |
|---|--------|---------|-------|--------|----------------|
| | P | T | h | M | |
| | bar | C | kJ/kg | t/h | |
| Condenser condensate | 0.3707 | 39.45 | 165.2 | 1193.6 | |
| Condensate pump suction | 0.3707 | 39.45 | 165.2 | 1193.6 | |
| Condensate pump exit | 21.6 | 39.72 | 168.2 | 1193.6 | |
| To SJAE, GSC & recovery heat exchangers | 21.6 | 39.72 | 168.2 | 1193.6 | |
| -Enthalpy change due to GSC | | | 1.47 | | |
| Feedwater to 1st feedwater heater | 21.6 | 40.08 | 169.7 | 1193.6 | |
| | | | | | |
| BOILER FEED PUMP TURBINE (Condensing) | | | | | |
| The plant has 1 boiler feed pump turbine in operation | | | | | |
| Stream | (Port) | P | T | h | M |
| | | bar | C | kJ/kg | t/h |
| Turbine inlet from LPT cross | (6) | 6.667 | 294.9 | 3049.8 | 133.4 |
| 1st group inlet | | 5.333 | 293.3 | 3049.8 | 133.4 |
| Exhaust to main condenser | | 0.0716 | 39.5 | 2410.7 | 133.4 |
| | | | | | |
| Boiler feed pump shaft power = | | 23445.0 | | | kW |
| Feed pump turbine power = | | 23681.8 | | | kW |
| Feed pump turbine efficiency = | | 82.16 | | | % |
| Group 1 adjusted nozzle area = | | 0.053 | | | m ² |
| Number of steps in Group 1 = | | 6 | | | |

| HP casing - Group 1 | | |
|--------------------------------|--------|-------------------|
| Number of governing stage rows | 1 | |
| Governing stage pitch diameter | 1.165 | m |
| Number of paths | 1 | |
| Number of stages | 1 | |
| Dry step efficiency | 75.57 | % |
| Group efficiency | 68.47 | % |
| Group inlet mass flow | 1831.7 | t/h |
| Shaft speed | 3000 | RPM |
| Before Valve | | |
| Pressure | 276 | bar |
| Temperature | 604 | C |
| Enthalpy | 3478 | kJ/kg |
| Blading Inlet | | |
| Pressure | 269.1 | bar |
| Temperature | 601.9 | C |
| Enthalpy | 3478 | kJ/kg |
| Volume flow | 6.629 | m ³ /s |
| Nozzle area | 0.0273 | m ² |
| Blading Exit | | |
| Pressure | 212.3 | bar |
| Temperature | 562.3 | C |
| Enthalpy | 3416 | kJ/kg |
| Volume flow | 8.057 | m ³ /s |

| | | |
|----------------------------|--------|-------------------|
| HP casing - Group 2 | | |
| Number of paths | 1 | |
| Number of stages | 9 | |
| Dry step efficiency | 87.34 | % |
| Group efficiency | 88.79 | % |
| Group inlet mass flow | 1831.7 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 212.3 | bar |
| Temperature | 562.3 | C |
| Enthalpy | 3416 | kJ/kg |
| Volume flow | 8.057 | m ³ /s |
| Nozzle area | 0.0218 | m ² |
| Blading Exit | | |
| Pressure | 64.3 | bar |
| Temperature | 374.5 | C |
| Enthalpy | 3104 | kJ/kg |
| Volume flow | 21.09 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 64.3 | bar |
| Temperature | 374.5 | C |
| Enthalpy | 3104 | kJ/kg |
| Extraction mass flow | 128.6 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 3 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 86.77 | % |
| Group efficiency | 82.61 | % |
| Group inlet mass flow (per path) | 859.9 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 58.8 | bar |
| Temperature | 602.2 | C |
| Enthalpy | 3662 | kJ/kg |
| Volume flow (per path) | 15.94 | m ³ /s |
| Nozzle area (per path) | 0.0554 | m ² |
| Blading Exit | | |
| Pressure | 42.67 | bar |
| Temperature | 549.7 | C |
| Enthalpy | 3555 | kJ/kg |
| Volume flow (per path) | 20.69 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 42.67 | bar |
| Temperature | 549.7 | C |
| Enthalpy | 3555 | kJ/kg |
| Extraction mass flow (per path) | 59.82 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 4 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 4 | |
| Dry step efficiency | 88.56 | % |
| Group efficiency | 89.22 | % |
| Group inlet mass flow (per path) | 800 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 42.67 | bar |
| Temperature | 549.7 | C |
| Enthalpy | 3555 | kJ/kg |
| Volume flow (per path) | 19.25 | m ³ /s |
| Nozzle area (per path) | 0.0562 | m ² |
| Blading Exit | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Volume flow (per path) | 31.82 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Extraction mass flow (per path) | 31.95 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 5 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 89.64 | % |
| Group efficiency | 90.06 | % |
| Group inlet mass flow (per path) | 768.1 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Volume flow (per path) | 30.55 | m ³ /s |
| Nozzle area (per path) | 0.0972 | m ² |
| Blading Exit | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Volume flow (per path) | 47.99 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Extraction mass flow (per path) | 37.27 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 6 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 90.51 | % |
| Group efficiency | 90.92 | % |
| Group inlet mass flow (per path) | 730.8 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Volume flow (per path) | 45.66 | m ³ /s |
| Nozzle area (per path) | 0.1496 | m ² |
| Blading Exit | | |
| Pressure | 7 | bar |
| Temperature | 296.5 | C |
| Enthalpy | 3052 | kJ/kg |
| Volume flow (per path) | 74.9 | m ³ /s |

| | | |
|-----------------------------------|--------|-------------------|
| LP casing - Group 7 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 91.11 | % |
| Group efficiency | 91.8 | % |
| Group inlet mass flow (per path) | 630 | t/h |
| Shaft speed | 3000 | RPM |
| Port upstream of LP casing | | |
| Pressure | 7 | bar |
| Temperature | 296.5 | C |
| Enthalpy | 3052 | kJ/kg |
| Extraction mass flow | 210.5 | t/h |
| Blading Inlet | | |
| Pressure | 7 | bar |
| Temperature | 296.7 | C |
| Enthalpy | 3053 | kJ/kg |
| Volume flow (per path) | 64.59 | m ³ /s |
| Nozzle area (per path) | 0.2119 | m ² |
| Blading Exit | | |
| Pressure | 3.083 | bar |
| Temperature | 205.1 | C |
| Enthalpy | 2875.4 | kJ/kg |
| Volume flow (per path) | 123.3 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 3.083 | bar |
| Temperature | 205.1 | C |
| Enthalpy | 2875.4 | kJ/kg |
| Extraction mass flow (per path) | 36.72 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 8 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 92.41 | % |
| Group efficiency | 92.85 | % |
| Group inlet mass flow (per path) | 593.2 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 3.083 | bar |
| Temperature | 205.1 | C |
| Enthalpy | 2875.4 | kJ/kg |
| Volume flow (per path) | 116.1 | m ³ /s |
| Nozzle area (per path) | 0.4031 | m ² |
| Blading Exit | | |
| Pressure | 1.167 | bar |
| Temperature | 113 | C |
| Enthalpy | 2700.4 | kJ/kg |
| Volume flow (per path) | 247.8 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 1.167 | bar |
| Temperature | 113 | C |
| Enthalpy | 2700.4 | kJ/kg |
| Extraction mass flow (per path) | 34.53 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 9 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 93.17 | % |
| Group efficiency | 92.57 | % |
| Group inlet mass flow (per path) | 558.7 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 1.167 | bar |
| Temperature | 113 | C |
| Enthalpy | 2700.4 | kJ/kg |
| Volume flow (per path) | 233.4 | m ³ /s |
| Nozzle area (per path) | 0.8777 | m ² |
| Blading Exit | | |
| Pressure | 0.363 | bar |
| Temperature | 73.57 | C |
| Enthalpy | 2526.1 | kJ/kg |
| Volume flow (per path) | 647.6 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 0.363 | bar |
| Temperature | 73.57 | C |
| Enthalpy | 2526.1 | kJ/kg |
| Extraction mass flow (per path) | 29.21 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 10 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 95 | % |
| Group efficiency | 80.4 | % |
| Group inlet mass flow (per path) | 529.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 0.363 | bar |
| Temperature | 73.57 | C |
| Enthalpy | 2526.1 | kJ/kg |
| Volume flow (per path) | 613.7 | m ³ /s |
| Nozzle area (per path) | 2.409 | m ² |
| Blading Exit | | |
| Pressure | 0.0716 | bar |
| Temperature | 39.45 | C |
| Enthalpy | 2323.4 | kJ/kg |
| Volume flow (per path) | 2648.7 | m ³ /s |
| Annulus area (per path) | 10.73 | m ² |
| Annulus velocity | 246.9 | m/s |
| Pitch Diameter | 2983.5 | mm |
| Bucket Length | 1144.5 | mm |
| Pitch Speed | 468.7 | m/s |
| Tip Speed | 648.4 | m/s |
| After leaving loss | | |
| Pressure | 0.0716 | bar |
| Temperature | 39.45 | C |
| Enthalpy | 2344.7 | kJ/kg |

STEAM PRO 26.1 GHD GHD Pty Ltd
 588 04-21-2017 16:13:26 G:\41\30763\Tech\HELE documentation\Model\USC model_wet cooling.stp
 Program revision date: February 16, 2017
 Steam source: Conventional boiler
 Steam turbine: Single reheat condensing turbine 3000+3000/3000
 Feedwater heaters: SDDDCDDP, single LP FWH train & double HP FWH train
 Cooling system: Water cooling with natural draft cooling tower
 Steam Property Formulation: IFC-67

THERMAL OUTPUT

FWH1: Pump Forward

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|------|-------|--------|-------------------|--------|------|--------|-------|------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 21.6 | 40.1 | 169.7 | 1193.6 | LPT1 port (9) | 0.363 | 73.6 | 2526.1 | 58.43 | |
| | | | | | Steam in | 0.3458 | 72.4 | 2523.7 | 58.43 | 72.4 |
| | | | | | Flash back | | | 314.9 | 219.6 | |
| Feedwater out | 19.62 | 69.6 | 293.0 | 1193.6 | SSR seal steam | | | 3163.6 | 5.222 | |
| | | | | | Drain before pump | 0.3458 | 72.4 | 303.1 | 283.3 | |
| | | | | | Drain to FWH2 | 19.62 | | 305.6 | 283.3 | |
| Terminal temperature difference = | | | 2.77 | C | | | | | | |

FWH2: Flash Back with Drain Cooler

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|------|-------|--------|---------------|-------|-------|--------|-------|-------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| | | | | | LPT1 port (8) | 1.167 | 113.0 | 2700.4 | 69.06 | |
| FWH1 drain | | | 305.6 | 283.3 | | | | | | |
| Feedwater in | 19.62 | 70.2 | 295.4 | 1476.8 | Steam in | 1.112 | 111.6 | 2698.1 | 69.06 | 102.6 |
| | | | | | Flash back | | | 439.6 | 150.5 | |
| Feedwater out | 17.71 | 99.8 | 419.6 | 1476.8 | Drain to FWH1 | 1.112 | 75.2 | 314.9 | 219.6 | |
| Terminal temperature difference = | | | 2.78 | C | | | | | | |
| Drain cooler approach = | | | 5.00 | C | | | | | | |

FWH3: Flash Back with Drain Cooler

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|-------|-------|--------|---------------|-------|-------|--------|-------|-------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| | | | | | LPT1 port (7) | 3.083 | 205.1 | 2875.4 | 73.43 | |
| Feedwater in | 17.71 | 99.8 | 419.6 | 1476.8 | Steam in | 2.936 | 203.6 | 2873.0 | 73.43 | 132.8 |
| | | | | | Flash back | | | 568.0 | 77.12 | |
| Feedwater out | 16.18 | 130.0 | 547.3 | 1476.8 | Drain to FWH2 | 2.936 | 104.8 | 439.6 | 150.5 | |
| Terminal temperature difference = | | | 2.78 | C | | | | | | |
| Drain cooler approach = | | | 5.00 | C | | | | | | |

| FWH4: Flash Back with Drain Cooler | | | | | | | | | | |
|------------------------------------|----------|--------|------------|----------|--------------------|----------|--------|------------|----------|-----------|
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 16.18 | 130.0 | 547.3 | 1476.8 | LPT cross port (6) | 7 | 296.5 | 3052.2 | 77.12 | |
| Feedwater out | 14.9 | 160.2 | 676.9 | 1476.8 | Steam in | 6.667 | 294.9 | 3049.8 | 77.12 | 163.0 |
| | | | | | Drain to FWH3 | 6.667 | 135.0 | 568.0 | 77.12 | |
| Terminal temperature difference = | | | 2.78 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |
| FWH5: Deaerator | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 12.66 | 160.3 | 676.9 | 1476.8 | IPT1 port (5) | 13.04 | 375.4 | 3206.9 | 74.55 | |
| Feedwater out | 12.66 | 190.4 | 809.2 | 1863.6 | Steam in | 12.66 | 374.0 | 3204.6 | 74.55 | 190.4 |
| Booster pump in | 14.9 | 190.4 | 809.2 | 1863.6 | Flash back | | | 863.3 | 312.2 | |
| FW pump in | 22.38 | 190.5 | 810.3 | 1863.6 | | | | | | |
| FW pump out | 308.6 | 197.4 | 854.1 | 1863.6 | | | | | | |
| FWH6: Flash Back with Drain Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 308.6 | 197.4 | 854.1 | 1863.6 | IPT1 port (4) | 22.9 | 454.3 | 3363.3 | 63.91 | |
| Feedwater out | 308 | 220.1 | 953.7 | 1863.6 | Steam in | 22.24 | 452.8 | 3360.9 | 63.91 | 217.8 |
| | | | | | Flash back | | | 967.5 | 248.3 | |
| | | | | | Drain to FWH5 | 22.24 | 202.4 | 863.3 | 312.2 | |
| Terminal temperature difference = | | | -2.28 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |
| FWH7: Flash Back with Drain Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 308 | 220.1 | 953.7 | 1863.6 | Sup. cooler exit | 41.42 | 302.4 | 2963.9 | 119.6 | |
| Feedwater out | 307.4 | 250.7 | 1091.9 | 1863.6 | Steam in | 41.42 | 302.4 | 2963.9 | 119.6 | 252.4 |
| | | | | | Flash back | | | 1113.7 | 128.6 | |
| | | | | | Drain to FWH6 | 41.42 | 225.1 | 967.5 | 248.3 | |
| Terminal temperature difference = | | | 1.67 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |

| FWH8: Flash Back with Drain Cooler | | | | | | | | | | |
|------------------------------------|-------|-------|--------|--------|-------------------|-------|-------|--------|-------|-------|
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 307.4 | 250.7 | 1091.9 | 1863.6 | HPT exit port (1) | 64.3 | 374.5 | 3104.0 | 128.6 | |
| Feedwater out | 306.8 | 279.9 | 1229.2 | 1863.6 | Steam in | 62.42 | 372.1 | 3101.7 | 128.6 | 278.1 |
| | | | | | Drain to FWH7 | 62.42 | 255.7 | 1113.7 | 128.6 | |
| Terminal temperature difference = | | | -1.78 | C | | | | | | |
| Drain cooler approach = | | | 5.00 | C | | | | | | |
| FWH9: Superheat Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 306.8 | 279.9 | 1229.2 | 1863.6 | IPT1 port (3) | 42.67 | 549.7 | 3555.2 | 119.6 | |
| Feedwater out | 306.7 | 287.7 | 1267.0 | 1863.6 | Steam in | 41.42 | 548.2 | 3552.9 | 119.6 | 252.4 |
| To boiler | 306.7 | 287.7 | 1267.0 | 1863.6 | Drain to FWH7 | 41.42 | 302.4 | 2963.9 | 119.6 | |
| Total bleed steam for FWH system = | | | 664.8 | t/h | 572024 | kJ/s | | | | |

| DESIGN PARAMETERS OF FEEDWATER HEATERS | | | |
|---|--|--------|---------------------|
| FWH1: Pump Forward | | | |
| 1. Heat transfer rate Q | | 40910 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 2717 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 0 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 | m ² |
| 6. Condensing section heat transfer area | | 1250 | m ² |
| 7. Drain cooler heat transfer area | | 0 | m ² |
| 8. Total heat transfer area | | 1250 | m ² |
| 9. Water velocity | | 2.90 | m/s |
| 10. Tube outer diameter | | 15.875 | mm |
| 11. Tube wall thickness | | 1.245 | mm |
| 12. Tube length per pass | | 15.2 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 1648 | |
| 15. Tube material | | TP 304 | |
| 16. Terminal temperature difference (TTD) | | 2.774 | C |
| 17. Drain cooler approach (DCA) | | N/A | |
| FWH2: Flash Back with Drain Cooler | | | |
| 1. Heat transfer rate Q | | 50934 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3092 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1452 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 | m ² |
| 6. Condensing section heat transfer area | | 1291 | m ² |
| 7. Drain cooler heat transfer area | | 386 | m ² |
| 8. Total heat transfer area | | 1677 | m ² |
| 9. Water velocity | | 2.90 | m/s |
| 10. Tube outer diameter | | 15.875 | mm |
| 11. Tube wall thickness | | 1.245 | mm |
| 12. Tube length per pass | | 16.2 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 2076 | |
| 15. Tube material | | TP 304 | |
| 16. Terminal temperature difference (TTD) | | 2.775 | C |
| 17. Drain cooler approach (DCA) | | 5 | C |

| FWH3: Flash Back with Drain Cooler | | |
|---|--|--------------------------|
| 1. Heat transfer rate Q | | 52389 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3415 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1313 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1211 m ² |
| 7. Drain cooler heat transfer area | | 283 m ² |
| 8. Total heat transfer area | | 1493 m ² |
| 9. Water velocity | | 2.90 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 1.245 mm |
| 12. Tube length per pass | | 18.0 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 1388 |
| 15. Tube material | | TP 304 |
| 16. Terminal temperature difference (TTD) | | 2.777 C |
| 17. Drain cooler approach (DCA) | | 5 C |
| FWH4: Flash Back with Drain Cooler | | |
| 1. Heat transfer rate Q | | 53164 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3644 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1017 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1173 m ² |
| 7. Drain cooler heat transfer area | | 180 m ² |
| 8. Total heat transfer area | | 1353 m ² |
| 9. Water velocity | | 2.90 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 1.245 mm |
| 12. Tube length per pass | | 15.9 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 1426 |
| 15. Tube material | | TP 304 |
| 16. Terminal temperature difference (TTD) | | 2.778 C |
| 17. Drain cooler approach (DCA) | | 5 C |

| FWH5: Deaerator | | |
|---|--|--------------------------|
| 1. Heat transfer rate Q | | 54289 kJ/s |
| FWH6: Flash Back with Drain Cooler (Each of FWH6A, FWH6B) | | |
| 1. Heat transfer rate Q | | 25765 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 511 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3025 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1306 W/m ² -K |
| 5. Desuperheater heat transfer area | | 99 m ² |
| 6. Condensing section heat transfer area | | 891 m ² |
| 7. Drain cooler heat transfer area | | 241 m ² |
| 8. Total heat transfer area | | 1231 m ² |
| 9. Water velocity | | 2.21 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 3.404 mm |
| 12. Tube length per pass | | 9.1 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 2270 |
| 15. Tube material | | Carbon steel |
| 16. Terminal temperature difference (TTD) | | -2.277 C |
| 17. Drain cooler approach (DCA) | | 5 C |
| FWH7: Flash Back with Drain Cooler (Each of FWH7A, FWH7B) | | |
| 1. Heat transfer rate Q | | 35785 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3021 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1115 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1096 m ² |
| 7. Drain cooler heat transfer area | | 318 m ² |
| 8. Total heat transfer area | | 1414 m ² |
| 9. Water velocity | | 2.21 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 3.404 mm |
| 12. Tube length per pass | | 10.0 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 2354 |
| 15. Tube material | | Carbon steel |
| 16. Terminal temperature difference (TTD) | | 1.667 C |
| 17. Drain cooler approach (DCA) | | 5 C |

| FWH8: Flash Back with Drain Cooler (Each of FWH8A, FWH8B) | | | |
|---|--|--------------|---------------------|
| 1. Heat transfer rate Q | | 35517 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 911 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3008 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 877 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 95 | m ² |
| 6. Condensing section heat transfer area | | 1109 | m ² |
| 7. Drain cooler heat transfer area | | 187 | m ² |
| 8. Total heat transfer area | | 1391 | m ² |
| 9. Water velocity | | 2.21 | m/s |
| 10. Tube outer diameter | | 19.050 | mm |
| 11. Tube wall thickness | | 3.404 | mm |
| 12. Tube length per pass | | 9.4 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 2468 | |
| 15. Tube material | | Carbon steel | |
| 16. Terminal temperature difference (TTD) | | -1.781 | C |
| 17. Drain cooler approach (DCA) | | 5 | C |
| FWH9: Superheat Cooler (Each of FWH9A, FWH9B) | | | |
| 1. Heat transfer rate Q | | 9789 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 490 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 0 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 0 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 209 | m ² |
| 6. Condensing section heat transfer area | | 0 | m ² |
| 7. Drain cooler heat transfer area | | 0 | m ² |
| 8. Total heat transfer area | | 209 | m ² |
| 9. Water velocity | | 2.21 | m/s |
| 10. Tube outer diameter | | 22.225 | mm |
| 11. Tube wall thickness | | 4.191 | mm |
| 12. Tube length per pass | | 3.0 | m |
| 13. No. of passes | | 1 | |
| 14. No. of tubes | | 999 | |
| 15. Tube material | | Carbon steel | |
| 16. Terminal temperature difference (TTD) | | N/A | |
| 17. Drain cooler approach (DCA) | | N/A | |

| FWH Hardware | FWH 1 | FWH 2 | FWH 3 | FWH 4 | FWH 5 | FWH 6 | FWH 7 | FWH 8 | FWH 9 |
|---|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| 1. Type | P | D | D | D | C | D | D | D | S |
| 2. Tube material | TP 304 | TP 304 | TP 304 | TP 304 | | Carbon steel | Carbon steel | Carbon steel | Carbon steel |
| 3. Tube outer diameter [mm] | 15.88 | 15.88 | 19.05 | 19.05 | | 19.05 | 19.05 | 19.05 | 22.23 |
| 4. Tube length (per pass) [m] | 15.21 | 16.2 | 17.98 | 15.86 | | 9.058 | 10.04 | 9.417 | 2.993 |
| 5. Number of tubes | 1648 | 2076 | 1388 | 1426 | | 2270 | 2354 | 2468 | 999 |
| 6. Total heat transfer area [m ²] | 1250.1 | 1677.5 | 1493.5 | 1353.4 | | 1230.6 | 1414.1 | 1390.9 | 208.7 |
| 7. Number of passes | 2 | 2 | 2 | 2 | | 2 | 2 | 2 | 1 |
| 8. Tube wall thickness [mm] | 1.245 | 1.245 | 1.245 | 1.245 | | 3.404 | 3.404 | 3.404 | 4.191 |
| 9. Tube pitch [mm] | 23.02 | 23.02 | 27.62 | 27.62 | | 23.81 | 25.72 | 23.81 | 30 |
| 10. Tube thermal cond. @ 300 F [W/m-C] | 16.61 | 16.61 | 16.61 | 16.61 | | 49.5 | 49.5 | 49.5 | 49.5 |
| 11. Tube thermal conductivity slope [W/m-C ²] | 0.0125 | 0.0125 | 0.0125 | 0.0125 | | -0.0249 | -0.0249 | -0.0249 | -0.0249 |
| 12. Fouling resistance [m ² -C/W] | 0 | 0 | 0 | 0 | | 0 | 0 | 0 | 0 |
| 13. Desuperheater heat transfer area [m ²] | 0 | 0 | 0 | 0 | | 98.93 | 0 | 95.03 | 208.7 |
| 14. Condensing heat transfer area [m ²] | 1250.1 | 1291.2 | 1210.9 | 1173.5 | | 890.6 | 1096.5 | 1109 | 0 |
| 15. Drain cooler heat transfer area [m ²] | 0 | 386.3 | 282.5 | 179.9 | | 241 | 317.6 | 186.9 | 0 |

| FWH 1 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Pump Forward Heater | | | | |
| Saturation temperature | | 72.42 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 9 | 0.36 | 73.6 | 2526.1 | 58.430 |
| Heating steam into heater (after piping) | 0.35 | 72.4 | 2523.7 | 58.430 |
| Flash in | | | 314.9 | 219.600 |
| Steam from Sealing Steam Regulator | | | 3164.0 | 5.222 |
| Exit Drain | | | | |
| FWH 1 drain to FWH 2 | 0.35 | 72.4 | 303.1 | 283.300 |
| Feedwater | | | | |
| Feedwater into heater | 21.60 | 40.1 | 169.7 | 1193.600 |
| Feedwater leaving heater | 19.62 | 69.7 | 293.0 | 1193.600 |

| FWH 2 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 102.6 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 8 | 1.17 | 113.0 | 2700.4 | 69.060 |
| Heating steam into heater (after piping) | 1.11 | 111.6 | 2698.1 | 69.060 |
| Flash in | | | 439.6 | 150.500 |
| Exit Drain | | | | |
| FWH 2 drain to FWH 1 | 1.11 | 75.2 | 314.9 | 219.600 |
| Feedwater | | | | |
| Drain from FWH1 | | | 305.6 | 283.300 |
| Feedwater into heater | 19.62 | 70.2 | 295.4 | 1476.800 |
| Feedwater leaving heater | 17.71 | 99.8 | 419.6 | 1476.800 |

| FWH 3 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 132.8 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 7 | 3.08 | 205.1 | 2875.4 | 73.430 |
| Heating steam into heater (after piping) | 2.94 | 203.6 | 2873.0 | 73.430 |
| Flash in | | | 568.0 | 77.120 |
| Exit Drain | | | | |
| FWH 3 drain to FWH 2 | 2.94 | 104.8 | 439.6 | 150.500 |
| Feedwater | | | | |
| Feedwater into heater | 17.71 | 99.8 | 419.6 | 1476.800 |
| Feedwater leaving heater | 16.18 | 130.0 | 547.3 | 1476.800 |

| FWH 4 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 163 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT cross - Port 6 | 7.00 | 296.5 | 3052.0 | 77.120 |
| Heating steam into heater (after piping) | 6.67 | 294.9 | 3050.0 | 77.120 |
| Exit Drain | | | | |
| FWH 4 drain to FWH 3 | 6.67 | 135.0 | 568.0 | 77.120 |
| Feedwater | | | | |
| Feedwater into heater | 16.18 | 130.0 | 547.3 | 1476.800 |
| Feedwater leaving heater | 14.90 | 160.2 | 676.9 | 1476.800 |

| FWH 5 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Contact Heater | | | | |
| Saturation temperature | | 190.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 5 | 13.04 | 375.4 | 3207.0 | 74.550 |
| Heating steam into heater (after piping) | 12.66 | 374.0 | 3205.0 | 74.550 |
| Flash in | | | 863.3 | 312.200 |
| Feedwater | | | | |
| Feedwater into heater | 12.66 | 160.3 | 676.9 | 1476.800 |
| Feedwater leaving heater | 12.66 | 190.4 | 809.2 | 1863.600 |
| Boiler feedpump delivery | 308.60 | 197.4 | 854.1 | 1863.600 |

| FWH 6 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 6A & 6B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 217.8 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 4 | 22.90 | 454.3 | 3363.0 | 63.910 |
| Heating steam into heater (after piping) | 22.24 | 452.8 | 3361.0 | 63.910 |
| Flash in | | | 967.5 | 248.300 |
| Exit Drain | | | | |
| FWH 6 drain to FWH 5 | 22.24 | 202.4 | 863.3 | 312.200 |
| Feedwater | | | | |
| Feedwater into heater | 308.60 | 197.4 | 854.1 | 1863.600 |
| Feedwater leaving heater | 308.00 | 220.1 | 953.7 | 1863.600 |

| FWH 7 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 7A & 7B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 252.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Steam from superheat cooler exit | 41.42 | 302.4 | 2963.9 | 119.600 |
| Heating steam into heater (after piping) | 41.42 | 302.4 | 2963.9 | 119.600 |
| Flash in | | | 1113.7 | 128.600 |
| Exit Drain | | | | |
| FWH 7 drain to FWH 6 | 41.42 | 225.1 | 967.5 | 248.300 |
| Feedwater | | | | |
| Feedwater into heater | 308.00 | 220.1 | 953.7 | 1863.600 |
| Feedwater leaving heater | 307.40 | 250.7 | 1091.9 | 1863.600 |

| FWH 8 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 8A & 8B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 278.1 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from HPT exit - Port 1 | 64.30 | 374.5 | 3104.0 | 128.600 |
| Heating steam into heater (after piping) | 62.42 | 372.1 | 3102.0 | 128.600 |
| Exit Drain | | | | |
| FWH 8 drain to FWH 7 | 62.42 | 255.7 | 1113.7 | 128.600 |
| Feedwater | | | | |
| Feedwater into heater | 307.40 | 250.7 | 1091.9 | 1863.600 |
| Feedwater leaving heater | 306.80 | 279.9 | 1229.2 | 1863.600 |

| FWH 9 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 9A & 9B) | | | | |
| Type: External Desuperheater | | | | |
| Saturation temperature | | 252.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 3 | 42.67 | 549.7 | 3555.0 | 119.600 |
| Heating steam into heater (after piping) | 41.42 | 548.2 | 3553.0 | 119.600 |
| Exit Drain | | | | |
| FWH 9 drain to FWH 7 | 41.42 | 302.4 | 2963.9 | 119.600 |
| Feedwater | | | | |
| Feedwater into heater | 306.80 | 279.9 | 1229.2 | 1863.600 |
| Feedwater leaving heater | 306.70 | 287.7 | 1267.0 | 1863.600 |
| Feedwater to boiler | 306.70 | 287.7 | 1267.0 | 1863.600 |

| CONDENSER: Water cooling with natural draft cooling tower | | | | | |
|---|--------|-------|-----------|--------|-------|
| | P | T | h | M | |
| | bar | C | kJ/kg | t/h | |
| LPT exhaust | 0.0716 | 39.45 | 2344.7 | 1059 | |
| LPT SS to condenser | | | 3163.6 | 0.5443 | |
| FPT exhaust | 0.0716 | 39.45 | 2410.7 | 133.4 | |
| Drain from GSC | 0.827 | 94.47 | 395.5 | 0.6349 | |
| Condenser in | 0.0716 | 39.45 | 2351.4 | 1193.6 | |
| Condensate | 0.3707 | 39.45 | 165.2 | 1193.6 | |
| Cooling water in | 3.366 | 26.13 | 109.8 | 53678 | |
| Cooling water out | 2.495 | 37.79 | 158.4 | 53678 | |
| Cooled water from cooling tower | 1 | 26.12 | 109.5 | 53678 | |
| Before cooling water pump | 1 | 26.12 | | 53678 | |
| After cooling water pump | 3.366 | 26.13 | 109.8 | 53678 | |
| Hot cooling water mixed from all condensers | 2.495 | 37.79 | 158.4 | 53678 | |
| Hot water to cooling tower | 1.897 | 37.80 | 158.4 | 53678 | |
| Condenser cooling water pump power = | 4435 | | kW | | |
| Main condenser heat rejection = | 724868 | | kJ/s | | |
| COOLING TOWER (Natural Draft) | | | | | |
| | P | T | Twet bulb | M | RH |
| | bar | C | C | t/h | % |
| Air in | 1.00 | 25.00 | 19.45 | 38092 | 60.0 |
| Air out | 1.00 | 34.47 | 34.47 | 38990 | 100.0 |
| Hot water in | 1.90 | 37.80 | | 53678 | |
| Cold water out | 1.00 | 26.12 | | 53678 | |
| Makeup | | | | 1122.5 | |
| Blowdown | | | | 224.5 | |
| Cooling tower heat rejection = | 728999 | | kJ/s | | |
| Range = | 11.68 | | C | | |
| Approach = | 6.667 | | C | | |
| Cycles of concentration = | 5 | | | | |

| | | |
|---|-----------------------|---------|
| WCC | | |
| Heat Balance | | |
| Condenser pressure | 0.0716 | bar |
| Condenser saturation temperature | 39.45 | C |
| Heat rejection | 724868 | kW |
| Number of units | 1 | |
| Inlet Steam | | |
| Pressure | 0.0716 | bar |
| Temperature | 39.45 | C |
| Mass flow | 1193.6 | t/h |
| Enthalpy | 2351.4 | kJ/kg |
| Condensate @ bottom of hotwell | | |
| Pressure | 0.3707 | bar |
| Temperature | 39.45 | C |
| Mass flow | 1193.6 | t/h |
| Enthalpy | 165.2 | kJ/kg |
| Inlet Cooling Water | | |
| Pressure | 3.366 | bar |
| Temperature | 26.13 | C |
| Mass flow | 53678 | t/h |
| Enthalpy | 109.8 | kJ/kg |
| Exit Cooling Water | | |
| Pressure | 2.495 | bar |
| Temperature | 37.79 | C |
| Mass flow | 53678 | t/h |
| Enthalpy | 158.4 | kJ/kg |
| Flash-in Stream | | |
| Temperature | 15 | C |
| Mass flow | 0 | t/h |
| Enthalpy | 62.8 | kJ/kg |
| Heat Transfer Data | | |
| Fouling factor | 0.026 * 10^-3 | m^2-C/W |
| Cleanliness factor | 90 | % |
| Water velocity | 1.999 | m/s |
| Water Reynolds number | 54033 | |
| Water Prandtl number | 5.173 | |
| Water Nusselt number | 271.2 | |
| Condensing heat transfer coefficient | 14200 | W/m^2-C |
| Water-side heat transfer coefficient | 8063 | W/m^2-C |
| Single tube overall heat transfer coefficient from hardware | 3604 | W/m^2-C |
| Tube bundle h.t.c. / Single tube h.t.c. | 0.875 | |
| Tube bundle overall heat transfer coefficient from hardware | 3154 | W/m^2-C |
| Condenser heat transfer calculation | Hardware model | |
| Tube bundle overall heat transfer coefficient from HEI method | N/A | |
| Overall UA | 129390 | kW/C |
| Water pressure drop in tubes/water box | 0.8707 | bar |
| Hardware | | |
| Condenser type | Shell & tube | |
| Number of units | 1 | |
| 1. Condenser Tube Description | | |
| Effective surface area | 41031 | m^2 |
| Number of condenser passes | 2 | |
| Tube material | Stainless steel (304) | |
| Number of tubes in condenser | 44113 | |
| Tube length | 13.3 | m |
| Tube outside diameter (O.D.) | 22.23 | mm |
| Tube inside diameter (I.D.) | 20.8 | mm |
| Tube wall thickness | 0.7112 | mm |
| Tube weight, dry | 226,800 | kg |
| Tube pitch | 35.56 | mm |
| 2. Condenser Shell Description | | |
| Shell material | Carbon steel | |
| Nominal shell thickness | 15.88 | mm |
| Number tube support plates | 23 | |
| Tube support plate spacing | 0.55 | m |
| Hotwell depth | 0.87 | m |
| Total dry weight | 695,200 | kg |
| Overall footprint area | 168.7 | m^2 |
| Overall length | 19.4 | m |
| Overall width | 8.7 | m |
| Overall height | 13.9 | m |

| Design Point Heat Balance Results | | |
|--|--------|----------------|
| Water temperature range | 11.68 | C |
| Cold water approach to inlet wet bulb | 6.667 | C |
| Hot water approach to exit wet bulb | 3.333 | C |
| Air wet bulb temperature rise | 15.02 | C |
| Heat rejection | 728999 | kW |
| Inlet Water | | |
| Pressure | 1.897 | bar |
| Temperature | 37.8 | C |
| Mass flow | 53678 | t/h |
| Enthalpy | 158.4 | kJ/kg |
| Exit Water | | |
| Pressure | 1 | bar |
| Temperature | 26.12 | C |
| Mass flow | 53678 | t/h |
| Enthalpy | 109.5 | kJ/kg |
| Inlet Air | | |
| Pressure | 1 | bar |
| Dry bulb temperature | 25 | C |
| Relative humidity | 60 | % |
| Wet bulb temperature | 19.45 | C |
| Mass flow | 38092 | t/h |
| Exit Air | | |
| Pressure | 1 | bar |
| Dry bulb temperature | 34.47 | C |
| Relative humidity | 100 | % |
| Wet bulb temperature | 34.47 | C |
| Mass flow | 38990 | t/h |
| Plume visibility index (Plume invisible) | 0 | |
| Makeup & Blowdown | | |
| Water evaporated | 898 | t/h |
| Blowdown | 224.5 | t/h |
| Blowdown temperature | 26.35 | C |
| Makeup water flow | 1122.5 | t/h |
| Makeup water temperature | 15 | C |
| Cycles of concentration | 5 | |
| Water flow in / Air flow in (L/G ratio) | 1.409 | |
| Hardware | | |
| 1. Estimated Major Dimensions | | |
| Height | | |
| Overall - ground to top | 208.8 | m |
| Throat - ground to throat | 148.2 | m |
| Above fill - top of fill to exit | 199.6 | m |
| Below fill - ground to top of fill | 9.144 | m |
| Diameter | | |
| Base | 93.85 | m |
| Throat | 52.14 | m |
| Exit | 61.11 | m |
| Basin area | 6918 | m ² |
| Average shell thickness | 457.2 | mm |
| Tower includes flue gas connection | | |
| 2. Concrete | | |
| Shell | 23,770 | m ³ |
| Basin | 2,180 | m ³ |
| Ring foundation | 1,040 | m ³ |
| Total | 26,990 | m ³ |

| Emissions | kg/hr | metric ton/year | kg/MWhr (gross) |
|---|----------------------|---------------------|--------------------|
| Furnace Emissions | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2228.6 | 18051 | 3.299 |
| CO2 (net) | 505287 | 4092822 | 748 |
| Particulate | 15093 | 122256 | 22.34 |
| Mercury as Hg | 0 | 0 | 0 |
| Electrostatic Precipitator Exit | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2228.6 | 18051 | 3.299 |
| CO2 (net) | 505287 | 4092822 | 748 |
| Particulate | 75.47 | 611.3 | 0.1117 |
| Mercury as Hg | 0 | 0 | 0 |
| Plant Total Emissions | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2228.6 | 18051 | 3.299 |
| CO2 (net) | 505287 | 4092822 | 748 |
| Particulate | 75.47 | 611.3 | 0.1117 |
| Mercury as Hg | 0 | 0 | 0 |
| Stack Levels | | | |
| | ng/J HHV @25C | mg/Nm³ | ppmv |
| NOx as NO2 | 0 | 0 @ 6% O2, dry | 0 @ 6% O2, dry |
| SOx as SO2 | 393.9 | 1169.3 @ 6% O2, dry | 409.1 @ 6% O2, dry |
| Particulate | 13.34 | 39.59 @ 6% O2, dry | |
| Mercury as Hg | 0 | 0 @ 6% O2, dry | 0 @ 6% O2, dry |
| Nm3 at 0 C, 101.325 kPa (32 F, 14.696 psia) | | | |
| Note: | | | |
| Boiler NOx emission is computed from the user-specified generation rate input on the Environment topic. | | | |
| The program DOES NOT predict NOx emissions. | | | |
| Therefore, it is incumbent on the user to input OEM-provided data consistent with equipment operation at this specific running condition. | | | |

| Plant Water/Steam Mass Flow Balance | | Mass flow | |
|--|--|---------------|------------|
| Mass Flow In | | 1233.1 | t/h |
| Steam cycle makeup | | 0 | t/h |
| Cooling tower makeup | | 1122.5 | t/h |
| Wet air-cooled condenser makeup | | 0 | t/h |
| Auxiliary cooling tower makeup | | 0 | t/h |
| Total boiler desuperheating water from makeup | | 0 | t/h |
| Total process steam desuperheating water from makeup | | 0 | t/h |
| Total steam addition | | 0 | t/h |
| Total water addition | | 0 | t/h |
| Total external steam | | 0 | t/h |
| Total process return | | 0 | t/h |
| FGD makeup/cake wash | | 0 | t/h |
| FGD water from reagent | | 0 | t/h |
| FGD water from oxidation air | | 0 | t/h |
| CO2 capture makeup | | 0 | t/h |
| Water in combustion air | | 28.47 | t/h |
| Water in fuel | | 9.387 | t/h |
| Water from combustion of hydrogen in fuel | | 72.74 | t/h |
| Seawater FGD evaporation | | 0 | t/h |
| Mass Flow Out | | 1233.1 | t/h |
| Cooling tower blowdown | | 224.5 | t/h |
| Cooling tower water evaporation | | 898 | t/h |
| Wet air-cooled condenser blowdown | | 0 | t/h |
| Wet air-cooled condenser water evaporation | | 0 | t/h |
| Auxiliary cooling tower blowdown | | 0 | t/h |
| Auxiliary cooling tower water evaporation | | 0 | t/h |
| Boiler blowdown to external sink | | 0 | t/h |
| Total process steam | | 0 | t/h |
| Total water extraction | | 0 | t/h |
| FGD blowdown/stacking water | | 0 | t/h |
| FGD water in byproduct | | 0 | t/h |
| CO2 capture drain | | 0 | t/h |
| CO2 capture water evaporation | | 0 | t/h |
| CO2 capture water removed with CO2 stream | | 0 | t/h |
| ST leakage to external sink | | 0 | t/h |
| Water in flue gas at stack exit | | 110.6 | t/h |
| Seawater FGD condensation | | 0 | t/h |

| Plant Water Accounting | | Current flow | % included | | |
|--|--|--------------|------------|---------------|------------|
| Total Water Consumption | | | | 1122.5 | t/h |
| Steam cycle makeup | | 0 | 100 | 0 | t/h |
| Cooling tower makeup | | 1122.5 | 100 | 1122.5 | t/h |
| Wet air-cooled condenser makeup | | 0 | 100 | 0 | t/h |
| Auxiliary cooling tower makeup | | 0 | 100 | 0 | t/h |
| FGD makeup/cake wash | | 0 | 100 | 0 | t/h |
| CO2 capture makeup | | 0 | 100 | 0 | t/h |
| Water addition 1 | | 0 | 0 | 0 | t/h |
| Water addition 2 | | 0 | 0 | 0 | t/h |
| Water addition 3 | | 0 | 0 | 0 | t/h |
| Process steam desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Superheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Reheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| LP reheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Seawater FGD evaporation | | 0 | 0 | 0 | t/h |
| Total Water Discharge | | | | 224.5 | t/h |
| Cooling tower blowdown | | 224.5 | 100 | 224.5 | t/h |
| Wet air-cooled condenser blowdown | | 0 | 100 | 0 | t/h |
| Auxiliary cooling tower blowdown | | 0 | 100 | 0 | t/h |
| Boiler blowdown to external sink | | 0 | 100 | 0 | t/h |
| FGD blowdown/stacking water | | 0 | 100 | 0 | t/h |
| CO2 capture drain | | 0 | 100 | 0 | t/h |
| Water extraction 1 | | 0 | 0 | 0 | t/h |
| Water extraction 2 | | 0 | 0 | 0 | t/h |
| Water extraction 3 | | 0 | 0 | 0 | t/h |
| Seawater FGD condensation | | 0 | 0 | 0 | t/h |

| | | |
|---|--------------|--|
| ESP | | |
| Heat Balance | | |
| Flue Gas | | |
| Flue gas inlet temperature | 137.8 | C |
| Flue gas outlet temperature | 137.8 | C |
| Flue gas mass flow (excluding particulate flow) | 2,570 | t/h |
| Flue gas volume flow | 3,009,000 | m ³ /hr |
| Flue gas velocity | 1.365 | m/s |
| Performance | | |
| Particulate collection efficiency | 99.5 | % |
| Inlet particulate load per energy input | 2667.8 | ng/J |
| Inlet particulate load per gas flow | 7919 | mg/Nm ³ @ 6% O ₂ , dry |
| Outlet particulate load per energy input | 13.34 | ng/J |
| Outlet particulate load per gas flow | 39.59 | mg/Nm ³ @ 6% O ₂ , dry |
| Inlet particulate flow | 15.09 | t/h |
| Particulate removal | 15.02 | t/h |
| Outlet particulate flow | 0.0755 | t/h |
| Pressure drop (including ductwork) | 8.095 | millibar |
| Electricity consumption | 1566.7 | kW |
| Flue gas SO ₂ | 402.7 | ppm |
| Flue gas SO ₃ at inlet | 2,014 | ppm |
| Injected sulfur trioxide (SO ₃) for flue gas conditioning | 0.1244 | t/h |
| Flue gas SO ₃ after conditioning | 20 | ppm |
| Flue gas SO ₃ at exit | 15 | ppm |
| Heat loss | 0 | kW |
| Modified Deutsch-Anderson Equation | | |
| Specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Particulate resistivity | 1.739188E+08 | ohm-cm |
| Effective migration velocity | 0.3062 | m/s |
| Dimensionless K | 0.5032 | |
| Hardware | | |
| Design collection efficiency | 99.5 | % |
| Design inlet temperature | 137.8 | C |
| Design flue gas mass flow | 2,570 | t/h |
| Design flue gas volume flow | 3,009,000 | m ³ /hr |
| Design flue gas velocity | 1.372 | m/s |
| Overall Dimensions | | |
| Number of chambers | 3 | |
| Number of fields | 4 | |
| Total length | 30.8 | m |
| Total width | 68.67 | m |
| Total height | 20.58 | m |
| Total weight | 1,905,000 | kg |
| Collecting Plates | | |
| Design specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Total collection surface area | 75,050 | m ² |
| Number of plates per chamber | 62 | |
| Collecting plates height | 10.97 | m |
| Collecting plates spacing | 304.8 | mm |
| Collecting plates bundle width per chamber | 18.59 | m |
| Collecting plates depth per field | 4.671 | m |
| Collecting length | 18.68 | m |
| Aspect ratio (Collecting length / Plate height) | 1.703 | |

| Heat Balance Results | | |
|---|---------------|-------------------|
| Boiler Feed Pump | | |
| Type | Variable RPM | |
| Number per Boiler | 1 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 22.38 | bar |
| Temperature | 190.5 | C |
| Mass flow | 1863.6 | t/h |
| Enthalpy | 810.3 | kJ/kg |
| Density | 876.2 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 308.6 | bar |
| Temperature | 197.4 | C |
| Mass flow | 1863.6 | t/h |
| Enthalpy | 854.1 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 286.2 (3331) | bar (m) |
| Pressure rise after valve pressure drop | 286.2 (3331) | bar (m) |
| Pump shaft speed | 3000 | RPM |
| Pump isentropic efficiency | 74.45 | % |
| Pump apparent isentropic efficiency | 74.45 | % |
| Pump hydraulic work | 22715 | kW |
| Pump mechanical efficiency | 96.89 | % |
| Pump shaft work | 23445 | kW |
| Boiler Feed Booster Pump | | |
| Type | Fixed RPM | |
| Number per Boiler | 1 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 14.9 | bar |
| Temperature | 190.4 | C |
| Mass flow | 1863.6 | t/h |
| Enthalpy | 809.2 | kJ/kg |
| Density | 875.8 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 22.38 | bar |
| Temperature | 190.5 | C |
| Mass flow | 1863.6 | t/h |
| Enthalpy | 810.3 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 7.473 (87.01) | bar (m) |
| Pressure rise after valve pressure drop | 7.473 (87.01) | bar (m) |
| Pump shaft speed | 600 | RPM |
| Pump isentropic efficiency | 83.55 | % |
| Pump apparent isentropic efficiency | 83.55 | % |
| Pump hydraulic work | 528.6 | kW |
| Pump mechanical efficiency | 96.93 | % |
| Pump shaft work | 545.3 | kW |
| Recirculation ratio | 0 | |
| Recirculation cooling load | 0 | kW |
| Motor efficiency | 96.12 | % |
| Electricity consumption | 567.3 | kW |
| Condenser C.W. Pump | | |
| Type | Fixed RPM | |
| Number per ST | 8 | |
| Number operating | 8 | |
| Suction Side (each) | | |
| Pressure | 1 | bar |
| Temperature | 26.12 | C |
| Mass flow | 6710 | t/h |
| Enthalpy | 109.5 | kJ/kg |
| Density | 996.9 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 3.366 | bar |
| Temperature | 26.13 | C |
| Mass flow | 6710 | t/h |
| Enthalpy | 109.8 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 2.366 (24.2) | bar (m) |
| Pressure rise after valve pressure drop | 2.366 (24.2) | bar (m) |
| Pump shaft speed | 500 | RPM |
| Pump isentropic efficiency | 85.65 | % |
| Pump apparent isentropic efficiency | 85.65 | % |

| Heat Balance Results | | |
|---|---------------|-------------------|
| Pump hydraulic work | 516.5 | kW |
| Pump mechanical efficiency | 96.93 | % |
| Pump shaft work | 532.9 | kW |
| Recirculation ratio | 0 | |
| Recirculation cooling load | 0 | kW |
| Motor efficiency | 96.11 | % |
| Electricity consumption | 554.4 | kW |
| Condensate Forwarding Pump | | |
| Type | Fixed RPM | |
| Number per ST | 2 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 0.3707 | bar |
| Temperature | 39.45 | C |
| Mass flow | 1193.6 | t/h |
| Enthalpy | 165.2 | kJ/kg |
| Density | 992.5 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 21.6 | bar |
| Temperature | 39.72 | C |
| Mass flow | 1193.6 | t/h |
| Enthalpy | 168.2 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 25.09 (257.7) | bar (m) |
| Pressure rise after valve pressure drop | 21.23 (218.1) | bar (m) |
| Pump shaft speed | 1500 | RPM |
| Pump isentropic efficiency | 83.55 | % |
| Pump apparent isentropic efficiency | 70.71 | % |
| Pump hydraulic work | 1003 | kW |
| Pump mechanical efficiency | 96.93 | % |
| Pump shaft work | 1034.7 | kW |
| Recirculation ratio | 0 | |
| Recirculation cooling load | 0 | kW |
| Motor efficiency | 96.5 | % |
| Electricity consumption | 1072.2 | kW |
| District Heating Pump | | |
| | None | |

| PIPES | |
|--|---------------|
| Pipe name | Pressure loss |
| | bar |
| BLR to HPT | 4.14 |
| Cold Reheat | 1.26 |
| Hot Reheat | 1.20 |
| Main Circulating Water | 0.60 |
| FWH 1 Heating | 0.02 |
| FWH 2 Heating | 0.06 |
| FWH 3 Heating | 0.15 |
| FWH 4 Heating | 0.33 |
| Deaerator (FWH 5) Heating | 0.38 |
| FWH 6 Heating | 0.67 |
| FWH 8 Heating | 1.87 |
| FWH 9 Heating | 1.24 |
| FPT Main Steam | 0.33 |
| FPT Exhaust (to condenser) | 0.00 |
| * Non-heat balance pipes are shown in PEACE output | |

| Project Cost Summary | Reference Cost | Estimated Cost | |
|--|----------------------|----------------------|-------------------|
| Power Plant: | | | |
| I Specialized Equipment | 341,908,000 | 444,481,000 | USD |
| II Other Equipment | 110,414,000 | 143,538,000 | USD |
| III Civil | 63,370,000 | 102,339,000 | USD |
| IV Mechanical | 183,610,000 | 321,495,000 | USD |
| V Electrical Assembly & Wiring | 12,894,000 | 24,219,000 | USD |
| VI Buildings & Structures | 18,708,000 | 31,103,000 | USD |
| VII Engineering & Plant Startup | 53,757,000 | 54,590,000 | USD |
| CO2 Capture Plant | NA | NA | |
| Desalination Plant | NA | NA | |
| Subtotal - Contractor's Internal Cost | 784,661,000 | 1,121,765,000 | USD |
| VIII Contractor's Soft & Miscellaneous Costs | 129,622,000 | 211,664,000 | USD |
| Contractor's Price | 914,283,000 | 1,333,429,000 | USD |
| IX Owner's Soft & Miscellaneous Costs | 182,857,000 | 266,686,000 | USD |
| Total - Owner's Cost (1 USD per US Dollar) | 1,097,140,000 | 1,600,115,000 | USD |
| Nameplate Net Plant Output | 650 | 650 | MW |
| Cost per kW - Contractor's | 1406.6 | 2051.5 | USD per kW |
| Cost per kW - Owner's | 1687.9 | 2461.8 | USD per kW |
| * Cost estimates as of August 2016. | | | |
| ** Land cost, utility connection cost, and spare parts costs are zero. | | | |
| The user may want to edit those inputs for better cost estimates. | | | |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|------------|--------------------|-----------|--------------------|--------------------|
| I Specialized Equipment (USD) | | | | 341,908,000 | 444,481,000 |
| 1. Boiler | | 179,784,000 | 1 | 179,784,000 | 233,719,000 |
| Furnace (incl. radiant platens) | 62,750,000 | | | | |
| Convective Elements (incl. interconnecting piping) | 66,902,000 | | | | |
| Additional Waterwall | 5,513,000 | | | | |
| Soot Blowers | 5,129,000 | | | | |
| Desuperheaters and Controls | 7,458,000 | | | | |
| Air and Flue Gas Ducts | 5,633,000 | | | | |
| Coal Pulverisers and Feeders | 17,145,000 | | | | |
| FD Fan, PA Fan, ID Fan | 1,671,000 | | | | |
| Structural Steel, Ladders, Walkways | 3,235,000 | | | | |
| Steam Air Heater | | | | | |
| Rotary Air Heaters | 4,349,000 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 2. Steam Turbine Package | | 94,021,000 | 1 | 94,021,000 | 122,227,000 |
| Turbine | incl. | | | | |
| Generator | incl. | | | | |
| Exhaust System | incl. | | | | |
| Electrical/Control/Instrumentation Package | incl. | | | | |
| Lube Oil Package w/ main, auxiliary & emergency pump | incl. | | | | |
| High Voltage Generator | | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 3. Feedwater Heaters | | | 13 | 9,230,000 | 11,999,000 |
| Feedwater Heater 1-P | 701,700 | | 1 | | |
| Feedwater Heater 2 | 647,700 | | 1 | | |
| Feedwater Heater 3 | 586,100 | | 1 | | |
| Feedwater Heater 4 | 536,500 | | 1 | | |
| Feedwater Heater 5-DA | 960,600 | | 1 | | |
| Feedwater Heater 6 (6A, 6B) | 687,400 | | 2 | | |
| Feedwater Heater 7 (7A, 7B) | 811,900 | | 2 | | |
| Feedwater Heater 8 (8A, 8B) | 822,600 | | 2 | | |
| Feedwater Heater 9-S (9A, 9B) | 576,800 | | 2 | | |
| Feedwater Heater 10 | | | | | |
| Feedwater Heater 11 | | | | | |
| Feedwater Heater 12 | | | | | |
| 4. Water-cooled Condensers | | | 1 | 8,679,000 | 11,283,000 |
| Water-cooled Condenser 1 | 8,679,000 | | 1 | | |
| Water-cooled Condenser 2 | | | | | |
| Water-cooled Condenser 3 | | | | | |
| Water-cooled Condenser 4 | | | | | |
| Water-cooled Condenser 5 | | | | | |
| Water-cooled Condenser 6 | | | | | |
| Feed Pump Turbine Water-cooled Condenser | | | | | |
| 5. Air-cooled Condenser | | | | | |
| Tube Bundles | | | | | |
| Fans, Gears, and Motors | | | | | |
| Steam Duct & Condenser | | | | | |
| Turbine Exhaust Transition | | | | | |
| Steam Jet Air Ejector | | | | | |
| Condensate Receiver Tank | | | | | |
| Support Structures | | | | | |
| Approximate shipping to typical US site | | | | | |
| 6. Particulate and Mercury Control | | 18,158,000 | 1 | 18,158,000 | 23,605,000 |
| Electrostatic Precipitator (ESP) | incl. | | | | |
| Active Carbon Injection Equipment | | | | | |
| Ductwork | incl. | | | | |
| Instruments & Controls | incl. | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 7. Flue Gas Desulfurization | | | | | |
| Reagent Feed System | | | | | |
| Absorber Tower & Ancillaries | | | | | |
| Active Carbon Injection Equipment | | | | | |
| Slurry Pumps | | | | | |
| Flue Gas Handling System | | | | | |
| Flue Gas Reheater | | | | | |
| Waste/Byproduct Handling System | | | | | |
| Support Equipment | | | | | |
| 8. Nitrogen Oxide Control (SCR) | | | | | |
| 9. Stack | | 10,997,000 | 1 | 10,997,000 | 14,296,000 |
| 10. Continuous Emissions Monitoring System | | 373,300 | 1 | 373,300 | 485,300 |
| Enclosures | incl. | | | | |
| Electronics, Display Units, Printers & Sensors | incl. | | | | |
| 11. Distributed Control System | | 1,442,000 | 1 | 1,442,000 | 1,875,000 |
| Enclosures | incl. | | | | |
| Electronics, Display Units, Printers & Sensors | incl. | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 12. Transmission Voltage Equipment | | 11,316,000 | 1 | 11,316,000 | 14,710,000 |
| Transformers | 9,816,000 | | | | |
| Circuit Breakers | 961,000 | | | | |
| Miscellaneous Equipment | 538,800 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 13. Generating Voltage Equipment | | 7,908,000 | 1 | 7,908,000 | 10,280,000 |
| Generator Buswork | 4,452,000 | | | | |
| Circuit Breakers | 3,079,000 | | | | |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| Current Limiting Reactors | | | | | |
| Miscellaneous Equipment | 376,550 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 14. User-defined | | | | 0 | 0 |

| | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-------------------|----------|--------------------|--------------------|
| II Other Equipment (USD) | | | 110,414,000 | 143,538,000 |
| 1. Pumps | | | 11,478,000 | 14,922,000 |
| Boiler Feed Pump (turbine included) | 7,330,000 | 1 | 7,330,000 | 9,529,000 |
| Boiler Feed Booster Pump | 125,450 | 1 | 125,450 | 163,100 |
| Condenser C.W. Pump | 290,350 | 8 | 2,323,000 | 3,020,000 |
| Condensate Forwarding Pump | 219,950 | 2 | 439,900 | 571,800 |
| Condenser Vacuum Pump | 164,600 | 2 | 329,200 | 427,950 |
| Fuel Oil Unloading Pump | 8,490 | 1 | 8,490 | 11,030 |
| Fuel Oil Forwarding Pump | 5,670 | 2 | 11,340 | 14,740 |
| Aux Cooling Water Pump (closed loop) | 18,970 | 2 | 37,950 | 49,330 |
| Treated Water Pump | 5,900 | 1 | 5,900 | 7,660 |
| Diesel Fire Pump | 72,800 | 3 | 218,450 | 284,000 |
| Electric Fire Pump | | | | |
| Jockey Fire Pump | 4,220 | 1 | 4,220 | 5,490 |
| ST+Generator Lube Oil Coolant Pump | | | | |
| ST Generator Coolant Pump | | | | |
| Demin Water Pump | 5,840 | 2 | 11,670 | 15,170 |
| Raw Water Pump 1 | 5,600 | 1 | 5,600 | 7,280 |
| Raw Water Pump 2 | 5,600 | 1 | 5,600 | 7,280 |
| Raw Water Pump 3 | | | | |
| District Heating Pump | | | | |
| Aux Cooling Water Pump (open loop) | 18,970 | 2 | 37,950 | 49,330 |
| FGD Slurry Pump | elsewhere | | | |
| Startup Boiler Feed Pump | 584,300 | 1 | 584,300 | 759,500 |
| 2. Tanks | | 7 | 523,700 | 680,800 |
| Fuel Oil | 183,000 | 1 | 183,000 | 237,900 |
| Hydrous Ammonia | | | | |
| Demineralized Water | 49,570 | 1 | 49,570 | 64,450 |
| Raw Water | 49,570 | 1 | 49,570 | 64,450 |
| Neutralized Water | 34,280 | 1 | 34,280 | 44,570 |
| Acid Storage | 7,150 | 1 | 7,150 | 9,290 |
| Caustic Storage | 7,150 | 1 | 7,150 | 9,290 |
| Waste Water | | | | |
| Dedicated Fire Protection Water Storage | 193,000 | 1 | 193,000 | 250,900 |
| 3. Cooling Tower | 41,948,000 | 1 | 41,948,000 | 54,533,000 |
| 4. Auxiliary Heat Exchangers | | | 129,800 | 168,750 |
| Auxiliary Cooling Water Heat Exchanger | 129,800 | 1 | 129,800 | 168,750 |
| Auxiliary Cooling Tower | | | | |
| Primary Air Fan Fin Fan Cooler | | | | |
| Induced Draft Fan Fin Fan Cooler | | | | |
| Miscellaneous Heat Exchangers | | | | |
| 5. District Heaters | | | | |
| District Heater 1 | | | | |
| District Heater 2 | | | | |
| 6. Auxiliary Boiler | | | | |
| 7. Makeup Water Treatment System | 1,299,000 | 1 | 1,299,000 | 1,688,000 |
| 8. Waste Water Treatment System | 165,800 | 1 | 165,800 | 215,550 |
| 9. Bridge Crane(s) | 1,838,000 | 1 | 1,838,000 | 2,390,000 |
| Steam Turbine Crane | | | | |
| 10. Station/Instrument Air Compressors | 156,400 | 5 | 782,100 | 1,017,000 |
| 11. Reciprocating Engine Genset(s) | | 6 | 13,551,000 | 17,616,000 |
| Emergency Generator | 810,700 | 1 | 810,700 | 1,054,000 |
| Black Start Generator | 2,548,000 | 5 | 12,740,000 | 16,562,000 |
| 12. General Plant Instrumentation | 370,650 | 1 | 370,650 | 481,850 |
| 13. Medium Voltage Equipment | 4,462,000 | 1 | 4,462,000 | 5,801,000 |
| Transformers | 584,300 | | | |
| Circuit Breakers | 132,850 | | | |
| Switchgear | 1,393,000 | | | |
| Motor Control Centers | 2,139,000 | | | |
| Miscellaneous | 212,450 | | | |
| 14. Low Voltage Equipment | 719,100 | 1 | 719,100 | 934,800 |
| Transformers | 246,250 | | | |
| Circuit Breakers | 240,450 | | | |
| Switchgear | | | | |
| Motor Control Centers | 198,200 | | | |
| Miscellaneous | 34,240 | | | |
| 15. Coal Handling Equipment | 23,590,000 | 1 | 23,590,000 | 30,666,000 |
| 16. Ash Handling Equipment | 4,299,000 | 1 | 4,299,000 | 5,588,000 |
| 17. Miscellaneous Equipment | 5,258,000 | | 5,258,000 | 6,835,000 |
| 18. User-defined | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-------------------|----------------|--------------|--------------|-------------------|-------------------|--------------------|
| III Civil (USD) | | | | | | 63,370,000 | 102,339,000 |
| 1. Site Work | 8,479,000 | 145,250 | 36 | | | 13,708,000 | 21,611,000 |
| Site Clearing | incl. | incl. | | | | | |
| Demolition | incl. | incl. | | | | | |
| Culverts & Drainage | incl. | incl. | | | | | |
| Erosion Control | incl. | incl. | | | | | |
| Fencing, Controlled Access Gates | incl. | incl. | | | | | |
| Finish Grading | incl. | incl. | | | | | |
| Finish Landscaping | incl. | incl. | | | | | |
| Material (Dirt, Sand, Stone) | incl. | incl. | | | | | |
| Waste Material Removal | incl. | incl. | | | | | |
| Obstacles R&R | incl. | incl. | | | | | |
| Miscellaneous | incl. | incl. | | | | | |
| 2. Excavation & Backfill | 1,706,000 | 36,960 | 36 | 67.73 | 44,840 m^3 | 3,037,000 | 4,913,000 |
| Steam Turbine | 162,250 | 3,550 | 36 | 67.36 | 4,310 m^3 | 290,050 | 469,750 |
| Boiler | 852,900 | 18,770 | 36 | 68.98 | 22,160 m^3 | 1,529,000 | 2,477,000 |
| Stack | elsewhere | elsewhere | | | | | |
| Water Cooled Condenser(s) | 138,200 | 2,980 | 36 | 63.63 | 3,860 m^3 | 245,650 | 397,200 |
| Cooling Tower | | | | | | | |
| Air Cooled Condenser | | | | | | | |
| Particulate and Mercury Control | 76,050 | 1,690 | 36 | 71.42 | 1,910 m^3 | 136,750 | 221,750 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Feedwater Heaters | 23,100 | 663 | 36 | 64.5 | 728 m^3 | 46,950 | 78,350 |
| District Heater(s) | | | | | | | |
| Underground Piping | 261,250 | 4,890 | 36 | 67.33 | 6,490 m^3 | 437,250 | 696,000 |
| Switchyard | 5,130 | 113 | 36 | 90.63 | 102 m^3 | 9,220 | 14,950 |
| Miscellaneous | 187,350 | 4,300 | 36 | 64.98 | 5,270 m^3 | 342,350 | 557,400 |
| 3. Concrete | 24,909,000 | 580,100 | 36 | 1,370 | 33,420 m^3 | 45,793,000 | 74,671,000 |
| Steam Turbine | 2,781,000 | 57,400 | 36 | 2,090 | 2,310 m^3 | 4,848,000 | 7,801,000 |
| Laydown pads: | 55,050 | 1,570 | 36 | | 77.86 m^3 | 111,650 | 186,250 |
| Steam Turbine | 55,050 | 1,570 | 36 | 1,430 | 77.86 m^3 | 111,650 | 186,250 |
| Boiler | 10,939,000 | 250,600 | 36 | 1,380 | 14,430 m^3 | 19,962,000 | 32,491,000 |
| Stack | elsewhere | elsewhere | | | | | |
| Water Cooled Condenser(s) | 1,090,000 | 27,550 | 36 | 1,440 | 1,440 m^3 | 2,082,000 | 3,425,000 |
| Cooling Tower | | | | | | | |
| Air Cooled Condenser | | | | | | | |
| Particulate and Mercury Control | 490,300 | 11,440 | 36 | 1,150 | 788 m^3 | 902,100 | 1,471,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Underground Piping: | 197,800 | 6,520 | 36 | | 246 m^3 | 432,550 | 732,500 |
| Circulating Water | 197,800 | 6,520 | 36 | 1,760 | 246 m^3 | 432,550 | 732,500 |
| Miscellaneous | | | | | | | |
| Makeup Water Treatment System | 18,580 | 574 | 36 | 1,780 | 22.02 m^3 | 39,230 | 65,950 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | 1,074,000 | 27,170 | 36 | 1,390 | 1,470 m^3 | 2,052,000 | 3,377,000 |
| Feedwater Heaters | 186,000 | 7,140 | 36 | 901 | 492 m^3 | 442,950 | 762,100 |
| Pumps | 658,100 | 19,260 | 36 | 1,740 | 778 m^3 | 1,352,000 | 2,260,000 |
| Auxiliary Heat Exchangers | | | | | | | |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 87,400 | 2,250 | 36 | 2,800 | 60.13 m^3 | 168,400 | 277,700 |
| Bridge Crane(s) | | | | | | | elsewhere |
| Reciprocating Engine Genset(s) | 498,600 | 13,350 | 36 | 1,470 | 664 m^3 | 979,400 | 1,622,000 |
| Tanks: | 340,250 | 10,310 | 36 | | 558 m^3 | 711,300 | 1,194,000 |
| Fuel Oil | 139,400 | 4,020 | 36 | 1,100 | 258 m^3 | 284,050 | 474,150 |
| Hydrous Ammonia | | | | | | | |
| Deminerlized Water | 29,270 | 930 | 36 | 1,620 | 38.65 m^3 | 62,750 | 105,850 |
| Raw Water | 29,270 | 930 | 36 | 1,620 | 38.65 m^3 | 62,750 | 105,850 |
| Neutralized Water | 19,810 | 652 | 36 | 2,200 | 19.65 m^3 | 43,270 | 73,250 |
| Acid Storage | 4,360 | 146 | 36 | 2,460 | 3.921 m^3 | 9,630 | 16,330 |
| Caustic Storage | 4,360 | 146 | 36 | 2,460 | 3.921 m^3 | 9,630 | 16,330 |
| Waste Water | | | | | | | |
| Dedicated Fire Protection Water Storage | 113,800 | 3,480 | 36 | 1,220 | 196 m^3 | 239,250 | 401,950 |
| Switchyard | 52,350 | 1,560 | 36 | 1,350 | 80.41 m^3 | 108,400 | 181,600 |
| Fuel Handling System | 4,177,000 | 90,650 | 36 | 1,070 | 6,960 m^3 | 7,440,000 | 12,037,000 |
| Miscellaneous | 2,264,000 | 52,750 | 36 | 1,370 | 3,040 m^3 | 4,163,000 | 6,788,000 |
| 4. Roads, Parking, Walkways | 747,500 | 2,270 | 37.65 | | | 832,800 | 1,144,000 |
| Pavement, Curbing, Striping | 612,900 | 1,640 | 36 | 4.2 | 14854 | 672,000 | 916,400 |
| Lighting | 134,650 | 623 | 42 | 5,740 | 28 | 160,800 | 228,000 |
| 5. User-defined | | | | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|-------------------|------------------|------------|--------------|-----------------|--------------------|--------------------|
| IV Mechanical (USD) | | | | | | 183,610,000 | 321,495,000 |
| 1. On-Site Transportation & Rigging | 9,856,000 | | | | | 9,856,000 | 16,386,000 |
| 2. Equipment Erection & Assembly | 16,486,000 | 2,236,000 | 41 | | | 108,150,000 | 207,052,000 |
| Steam Turbine Package | 469,200 | 64,050 | 41 | 3,095,000 | 1 | 3,095,000 | 5,927,000 |
| Boiler | 10,324,000 | 1,409,000 | 41 | 68,094,000 | 1 | 68,094,000 | 130,406,000 |
| Feedwater Heaters | 70,100 | 9,570 | 41 | | | 462,400 | 885,500 |
| Condenser(s) | 92,000 | 12,560 | 41 | | | 606,900 | 1,162,000 |
| Cooling Tower | elsewhere | elsewhere | | | | | |
| Particulate and Mercury Control | 2,147,000 | 293,100 | 41 | 14,164,000 | 1 | 14,164,000 | 27,125,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Coal Handling System | 914,400 | 124,800 | 41 | 6,032,000 | 1 | 6,032,000 | 11,551,000 |
| Ash Handling System | 868,600 | 118,550 | 41 | 5,729,000 | 1 | 5,729,000 | 10,972,000 |
| Makeup Water Treatment System | 145,050 | 6,340 | 41 | | | 404,800 | 714,600 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | 174,200 | 23,780 | 41 | | | 1,149,000 | 2,201,000 |
| Pumps | 67,850 | 9,260 | 41 | | | 447,600 | 857,200 |
| Tanks + Auxiliary Heat Exchangers | 42,270 | 5,770 | 41 | | | 278,800 | 533,900 |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 5,900 | 805 | 41 | | | 38,900 | 74,500 |
| Bridge Crane(s) | 9,620 | 1,310 | 41 | | | 63,450 | 121,450 |
| Reciprocating Engine Genset(s) | 6,000 | 819 | 41 | | | 39,580 | 75,800 |
| Miscellaneous | 1,150,000 | 156,000 | 41 | | | 7,545,000 | 14,445,000 |
| 3. Piping | 46,586,000 | 413,450 | 41 | 2,860 | 22,210 m | 63,537,000 | 94,889,000 |
| High Pressure Steam | 8,336,000 | 22,820 | 41 | 43,330 | 214 m | 9,272,000 | 12,732,000 |
| Cold Reheat Steam | 2,111,000 | 19,580 | 41 | 16,340 | 178 m | 2,914,000 | 4,370,000 |
| Hot Reheat Steam | 5,272,000 | 33,030 | 41 | 28,610 | 232 m | 6,626,000 | 9,596,000 |
| FWH Heating Steam | 1,873,000 | 20,420 | 41 | 5,090 | 532 m | 2,710,000 | 4,131,000 |
| Other Steam & Heating | 3,329,000 | 18,500 | 41 | 34,210 | 119 m | 4,088,000 | 5,864,000 |
| Feedwater | 8,906,000 | 40,740 | 41 | 18,160 | 582 m | 10,576,000 | 14,960,000 |
| Circulating Water | 3,563,000 | 19,790 | 41 | 3,630 | 1,200 m | 4,374,000 | 6,275,000 |
| Auxiliary Cooling Water | 439,950 | 11,950 | 41 | 967 | 961 m | 929,900 | 1,564,000 |
| Other Water | 21,360 | 1,370 | 41 | 217 | 358 m | 77,550 | 141,550 |
| Raw Water | 138,150 | 5,590 | 41 | 518 | 710 m | 367,300 | 643,600 |
| Service Water | 267,700 | 10,240 | 41 | 566 | 1,210 m | 687,700 | 1,199,000 |
| Fuel Gas | | | | | | | |
| Fuel Oil | | | | | | | |
| Service Air | 169,650 | 5,190 | 41 | 420 | 910 m | 382,250 | 651,100 |
| Vacuum Air | 111,700 | 2,310 | 41 | 1,980 | 104 m | 206,300 | 336,750 |
| Ammonia | | | | | | | |
| Boiler & Equipment Drain | 4,954,000 | 126,350 | 41 | 908 | 11,160 m | 10,134,000 | 16,929,000 |
| Boiler Blowdown | | | | | | | |
| Steam Blowoff | 243,500 | 2,600 | 41 | 7,000 | 49.99 m | 349,950 | 532,100 |
| Fire Protection | 3,599,000 | 44,150 | 41 | 2,550 | 2,120 m | 5,409,000 | 8,344,000 |
| Miscellaneous | 3,250,000 | 28,850 | 41 | 2,860 | 1,550 m | 4,433,000 | 6,620,000 |
| 4. Steel | 1,398,000 | 16,270 | 41 | 4,950 | 417 | 2,065,000 | 3,169,000 |
| Racks, Supports, Ladders, Walkways, Platforms | 1,398,000 | 16,270 | 41 | 4,950 | 417 | 2,065,000 | 3,169,000 |
| 5. User-defined | | | | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|------------------|----------------|------------|-----------|----------|-------------------|-------------------|
| V Electrical Assembly & Wiring (USD) | | | | | | 12,894,000 | 24,219,000 |
| 1. Controls | 568,200 | 194,400 | 42 | | | 8,732,000 | 17,271,000 |
| Steam Turbine Package | 77,250 | 27,450 | 42 | 1,230,000 | 1 | 1,230,000 | 2,435,000 |
| Boiler | 344,850 | 122,550 | 42 | 5,491,000 | 1 | 5,491,000 | 10,869,000 |
| Feedwater Heaters | 2,180 | 776 | 42 | | | 34,770 | 68,800 |
| Condenser(s) | 6,240 | 2,220 | 42 | | | 99,300 | 196,600 |
| Cooling Tower | elsewhere | elsewhere | | | | | |
| Particulate and Mercury Control | 43,410 | 15,430 | 42 | 691,300 | 1 | 691,300 | 1,368,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Coal Handling System | 28,480 | 10,120 | 42 | 453,500 | 1 | 453,500 | 897,700 |
| Ash Handling System | 27,050 | 9,610 | 42 | 430,800 | 1 | 430,800 | 852,700 |
| Makeup Water Treatment System | 3,570 | 1,270 | 42 | | | 56,800 | 112,400 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | | | | | | | |
| Pumps | 11,170 | 3,970 | 42 | | | 177,900 | 352,100 |
| Tanks + Auxiliary Heat Exchangers | | | | | | | |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 8,090 | 345 | 42 | | | 22,580 | 39,860 |
| Bridge Crane(s) | 7,700 | 328 | 42 | | | 21,480 | 37,910 |
| Reciprocating Engine Genset(s) | 8,230 | 351 | 42 | | | 22,970 | 40,550 |
| 2. Assembly & Wiring | 2,041,000 | 50,500 | 42 | | | 4,162,000 | 6,948,000 |
| Switchgear | 37,330 | 2,680 | 42 | 25,000 | 6 | 150,000 | 276,700 |
| Motor Control Centers | 62,650 | 2,780 | 42 | 3,990 | 45 | 179,500 | 318,050 |
| Feeders | 395,150 | 11,020 | 42 | 8,940 | 96 | 857,800 | 1,451,000 |
| Medium/Low Voltage Cable Bus | 813,300 | 13,420 | 42 | 25,980 | 53 | 1,377,000 | 2,198,000 |
| Cable Tray | 201,800 | 4,260 | 42 | 380,550 | 1 | 380,550 | 624,300 |
| General Plant Instrumentation | 178,300 | 3,190 | 42 | 1,380 | 227 | 312,400 | 503,400 |
| Generator to Step-up Transformer Bus | 40,650 | 722 | 42 | 71,000 | 1 | 71,000 | 114,250 |
| Transformers | 134,650 | 7,180 | 42 | 87,200 | 5 | 436,100 | 785,500 |
| Circuit Breakers | 76,450 | 2,720 | 42 | 27,230 | 7 | 190,600 | 330,500 |
| Miscellaneous | 100,850 | 2,530 | 42 | 207,250 | 1 | 207,250 | 346,600 |
| 3. User-defined | | | | | | 0 | 0 |

| | Area | Cost/Unit Area | Ref. Cost | Est. Cost |
|---|--------|----------------|-------------------|-------------------|
| VI Buildings (USD) | | | 18,708,000 | 31,103,000 |
| 1. Boiler House and Turbine Hall | 9357 | 1811.29 | 16,948,000 | 28,176,000 |
| 2. Administration, Control Room, Machine Shop / Warehouse | 1486.5 | 1150.46 | 1,710,000 | 2,843,000 |
| 3. Water Treatment System | 23.21 | 1200.49 | 27,860 | 46,320 |
| 4. Guard House | 18.58 | 1200.48 | 22,310 | 37,080 |
| 5. Fuel Barn | | | | |
| 6. User-defined | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|------------------|---------------|--------------|------------------|----------|-------------------|-------------------|
| VII Engineering & Plant Startup (USD) | | | | | | 53,757,000 | 54,590,000 |
| 1. Engineering | | | | | | 44,037,000 | 44,037,000 |
| 2. Start-Up | 2,778,000 | 76,200 | 91.07 | 9,720,000 | | 9,720,000 | 10,553,000 |
| 3. User-defined | | | | | | 0 | 0 |

| | Ref. Cost | Est. Cost |
|---|--------------------|--------------------|
| VIII Soft & Miscellaneous Costs (USD) | | |
| 1. Contractor's Soft Costs | 129,622,000 | 211,664,000 |
| Contingency: | 39,034,000 | 67,496,000 |
| Labor | 23,106,000 | 46,789,000 |
| Specialized Equipment | 6,838,000 | 8,890,000 |
| Other Equipment | 3,312,000 | 4,306,000 |
| Commodity | 5,778,000 | 7,511,000 |
| Profit: | 59,201,000 | 99,297,000 |
| Labor | 30,807,000 | 62,385,000 |
| Specialized Equipment | 17,095,000 | 22,224,000 |
| Other Equipment | 5,521,000 | 7,177,000 |
| Commodity | 5,778,000 | 7,511,000 |
| Permits, Licenses, Fees, Miscellaneous | 0 | 0 |
| Bonds and Insurance | 7,847,000 | 11,218,000 |
| Spare Parts & Materials | 0 | 0 |
| Contractor's Fee | 23,540,000 | 33,653,000 |
| 2. Owner's Soft Costs | 182,857,000 | 266,686,000 |
| Permits, Licenses, Fees, Miscellaneous | 18,286,000 | 26,669,000 |
| Land Cost | 0 | 0 |
| Utility Connection Cost | 0 | 0 |
| Legal & Financial Costs | 18,286,000 | 26,669,000 |
| Escalation and Interest During Construction | 137,142,000 | 200,014,000 |
| Spare Parts & Materials | 0 | 0 |
| Project Administration & Developer's Fee | 9,143,000 | 13,334,000 |
| 3. Total of all user-defined costs displayed on each account | 0 | 0 |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| CO2 Capture Plant (USD) | | | | 0 | 0 |
| 1. CO2 Capture | | | | | |
| Absorbers | | | | | |
| Strippers | | | | | |
| CO2 compressors and dehydrators | | | | | |
| Heat exchangers | | | | | |
| Pumps | | | | | |
| Piping | | | | | |
| Electrical & Controls | | | | | |
| Engineering & Design | | | | | |
| Miscellaneous | | | | | |
| Approximate shipping to typical US site | | | | | |
| 2. User-defined | | | | 0 | 0 |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| Desalination Plant (USD) | | | | 0 | 0 |
| 1. Desalination | | | | | |
| MSF System | | | | | |
| - Evaporators | | | | | |
| - Brine Heater | | | | | |
| - Deaerator | | | | | |
| - Pumps | | | | | |
| - Piping | | | | | |
| - Electrical & Controls | | | | | |
| - Intake System & Distillate Delivery | | | | | |
| - Engineering & Design | | | | | |
| - Platform/ladder/walkway | | | | | |
| - Miscellaneous | | | | | |
| RO System | | | | | |
| - Intake & Outfall | | | | | |
| - Pre-treatment System | | | | | |
| - Pumps | | | | | |
| - Energy Recovery Device | | | | | |
| - RO Membrane Assembly | | | | | |
| - Post-treatment System | | | | | |
| - Miscellaneous | | | | | |
| Approximate shipping to typical US site | | | | | |
| 2. User-defined | | | | 0 | 0 |

| Estimated Site Plan Data | | |
|---|-------|----------------|
| 1. Site Plot Plan | | |
| Length | 428 | m |
| Width | 392 | m |
| Area | 16.79 | hectare |
| 2. Boiler House and Turbine Hall | | |
| Area | 9,360 | m ² |
| 3. Switchyard | | |
| Length | 117 | m |
| Width | 74.9 | m |
| Area | 8,760 | m ² |
| 4. Water Treatment Facility | | |
| Length | 6.8 | m |
| Width | 3.4 | m |
| Area | 23.21 | m ² |
| 5. Administration, Shop & Warehouse Building | | |
| Length | 35.2 | m |
| Width | 14.1 | m |
| Area | 1,490 | m ² |
| Number of Floors | 3 | |
| 6. Road | | |
| Length | 847 | m |
| Width | 7.6 | m |
| Area | 6,460 | m ² |
| 7. Parking Lot | | |
| Number of Parking Spaces | 16 | |
| Total Width | 48.8 | m |
| Depth of Parking Space | 6.1 | m |
| Total Area | 297 | m ² |
| 8. Walkways | | |
| Area | 8,400 | m ² |
| 9. Guard House | | |
| Area | 18.58 | m ² |

| Estimated Piping Data | ID x No. | Nom. D [mm] | Length [m] | Schedule | Material | Fittings | M [t/h] | Design Flow | Design Vel. [m/s] |
|--|------------|-------------|------------|----------|--------------|----------|---------|--------------------------|-------------------|
| 1. High Pressure Steam Piping | | | | | | | | | |
| BLR to HPT | HP0 x 1 | 450.9 | 169.5 | Custom | TP347HFG | 8 | 1863.6 | 6.491 m ³ /s | 41.22 m/s |
| HP Bypass | HPBP x 1 | 450.9 | 44.5 | Custom | TP347HFG | 3 | 1863.6 | 6.491 m ³ /s | 41.22 m/s |
| 2. Cold Reheat Steam Piping | | | | | | | | | |
| Cold Reheat | CRH0 x 1 | 717.6 | 178.3 | Custom | P-22 | 8 | 1689.2 | 19.45 m ³ /s | 48.99 m/s |
| 3. Hot Reheat Steam Piping | | | | | | | | | |
| Hot Reheat | HRH0 x 1 | 800.1 | 187.1 | Custom | TP347HFG | 8 | 1689.2 | 30.18 m ³ /s | 61.17 m/s |
| IP Bypass | IPBP x 1 | 800.1 | 44.5 | Custom | TP347HFG | 3 | 1689.2 | 30.18 m ³ /s | 61.17 m/s |
| 4. FWH Heating Steam Piping | | | | | | | | | |
| FWH 1 Heating | FWHHS1 x 1 | 914.4 | 12.19 | 10 | A-106 | 4 | 58.43 | 71.7 m ³ /s | 117.3 m/s |
| FWH 2 Heating | FWHHS2 x 1 | 762 | 24.08 | 10 | A-106 | 6 | 69.06 | 28.85 m ³ /s | 67.16 m/s |
| FWH 3 Heating | FWHHS3 x 1 | 508 | 35.97 | 40 | A-106 | 8 | 73.43 | 14.38 m ³ /s | 83.44 m/s |
| FWH 4 Heating | FWHHS4 x 1 | 406.4 | 47.85 | 40 | A-106 | 10 | 77.12 | 7.903 m ³ /s | 71.93 m/s |
| Deaerator (FWH 5) Heating | FWHHS5 x 1 | 406.4 | 101.8 | 40 | A-106 | 19 | 74.55 | 4.657 m ³ /s | 41.77 m/s |
| FWH 6 Heating | FWHHS6 x 2 | 203.2 | 41.76 | 40 | P-11 | 9 | 31.95 | 1.271 m ³ /s | 39.84 m/s |
| FWH 8 Heating | FWHHS8 x 2 | 203.2 | 53.65 | 60 | P-22 | 11 | 64.32 | 0.7407 m ³ /s | 24.08 m/s |
| FWH 9 Heating | FWHHS9 x 2 | 203.2 | 59.74 | 60 | P-91 | 12 | 59.82 | 1.44 m ³ /s | 47.56 m/s |
| 5. Other Steam & Heating Piping | | | | | | | | | |
| FPT Main Steam | FPTMS1 x 1 | 508 | 72.85 | 40 | A-106 | 9 | 133.4 | 13.67 m ³ /s | 79.75 m/s |
| FPT Exhaust (to condenser) | FPTX1 x 1 | 3658 | 46.63 | 20 | A-106 | 5 | 133.4 | 752.1 m ³ /s | 75.22 m/s |
| 6. Feedwater Piping | | | | | | | | | |
| FWH 1 Exit Feedwater | FWFW1 x 1 | 457.2 | 19.81 | 20 | A-106 | 2 | 1193.6 | 20325 lpm | 2.214 m/s |
| FWH 2 Exit Feedwater | FWFW2 x 1 | 508 | 21.34 | 20 | A-106 | 2 | 1476.8 | 25665 lpm | 2.278 m/s |
| FWH 3 Exit Feedwater | FWFW3 x 1 | 609.6 | 23.17 | 20 | A-106 | 2 | 1476.8 | 26318 lpm | 1.601 m/s |
| FWH 4 Exit Feedwater | FWFW4 x 1 | 609.6 | 101.8 | 20 | A-106 | 11 | 1476.8 | 27121 lpm | 1.65 m/s |
| Deaerator (FWH 5) Exit Feedwater | FWFW5 x 1 | 609.6 | 101.8 | 20 | A-106 | 11 | 1863.6 | 35377 lpm | 2.151 m/s |
| FWH 6 Exit Feedwater | FWFW6 x 2 | 406.4 | 13.72 | Custom | A-106 | 2 | 931.8 | 17988 lpm | 2.311 m/s |
| FWH 7 Exit Feedwater | FWFW7 x 2 | 419.1 | 14.94 | Custom | A-106 | 2 | 931.8 | 18809 lpm | 2.272 m/s |
| FWH 8 Exit Feedwater | FWFW8 x 2 | 431.8 | 14.33 | Custom | A-106 | 2 | 931.8 | 19797 lpm | 2.253 m/s |
| FWH 9 Exit Feedwater | FWFW9 x 2 | 431.8 | 7.62 | Custom | A-106 | 2 | 931.8 | 20107 lpm | 2.289 m/s |
| Feedwater to Boiler | FW3 x 1 | 609.6 | 173.4 | Custom | A-106 | 14 | 1863.6 | 40215 lpm | 2.297 m/s |
| Condensate | FW1 x 1 | 457.2 | 39.93 | 20 | A-106 | 14 | 1193.6 | 20030 lpm | 2.182 m/s |
| 7. Circulating Water Piping | | | | | | | | | |
| Main Circulating Water | CW0 x 3 | 1524 | 401.4 | 150psi | Ductile iron | 12 | 18050 | 302888 lpm | 2.72 m/s |
| 8. Auxiliary Cooling Water Piping | | | | | | | | | |
| CW for ST+Generator Lube Oil | CW7 x 1 | 152.4 | 177.1 | 40 | A-106 | 20 | 152.1 | 2541.1 lpm | 2.272 m/s |
| CW for ST Generator | CW8 x 1 | 254 | 177.1 | 40 | A-106 | 20 | 318.3 | 5319 lpm | 1.743 m/s |
| Main Auxiliary CW | CW1 x 1 | 304.8 | 607.2 | 40 | A-106 | 5 | 470.4 | 7860 lpm | 1.814 m/s |
| 9. Other Water Piping | | | | | | | | | |
| Makeup from Water Treatment System | FW2 x 1 | 63.5 | 358.1 | 40 | A-106 | 14 | 22.26 | 371.3 lpm | 2.003 m/s |
| 10. Raw Water Piping | | | | | | | | | |
| Raw Water | RW0 x 1 | 88.9 | 709.6 | 40 | A-106 | 118 | 22.26 | 371.6 lpm | 0.971 m/s |
| 11. Service Water Piping | | | | | | | | | |
| Service Water | SW0 x 1 | 76.2 | 1214 | 40 | A-106 | 300 | NA | NA | 0.9541 m/s |
| 12. Fuel Gas Piping | | | | | | | | | |
| 13. Fuel Oil Piping | | | | | | | | | |
| 14. Service Air Piping | | | | | | | | | |
| Service Air | SERVA x 1 | 50.8 | 910.4 | 40 | A-106 | 225 | NA | NA | 31.1 m/s |
| 15. Vacuum Air Piping | | | | | | | | | |
| Condenser Air Removal | CAR0 x 1 | 203.2 | 103.9 | 80 | A-106 | 28 | NA | NA | 25.73 m/s |
| 16. Ammonia Piping | | | | | | | | | |
| 17. Boiler & Equipment Drain Piping | | | | | | | | | |
| FWH 1 Drain | FWDW1 x 1 | 254 | 27.43 | 40 | A-106 | 4 | 283.3 | 4833 lpm | 1.572 m/s |
| FWH 2 Drain | FWDW2 x 1 | 203.2 | 27.43 | 40 | A-106 | 4 | 219.6 | 3756 lpm | 1.939 m/s |
| FWH 3 Drain | FWDW3 x 1 | 203.2 | 29.57 | 40 | A-106 | 4 | 150.5 | 2628.3 lpm | 1.357 m/s |
| FWH 4 Drain | FWDW4 x 1 | 127 | 29.26 | 40 | A-106 | 4 | 77.12 | 1381.4 lpm | 1.784 m/s |
| FWH 6 Drain | FWDW6 x 2 | 203.2 | 88.09 | 40 | A-106 | 4 | 156.1 | 3017 lpm | 1.558 m/s |
| FWH 7 Drain | FWDW7 x 2 | 152.4 | 18.9 | 40 | A-106 | 4 | 124.1 | 2476.9 lpm | 2.215 m/s |
| FWH 8 Drain | FWDW8 x 2 | 127 | 19.2 | 80 | A-106 | 4 | 64.32 | 1352 lpm | 1.92 m/s |
| Small Drains | BEDR1 x 36 | 101.6 | 150 | 40 | A-106 | 17 | NA | NA | 0.3452 m/s |
| Medium Drains | BEDR2 x 22 | 152.4 | 150 | 40 | A-106 | 17 | NA | NA | 0.1521 m/s |
| Large Drains | BEDR3 x 14 | 254 | 150 | 40 | A-106 | 17 | NA | NA | 0.0557 m/s |
| 18. Boiler Blowdown Piping | | | | | | | | | |
| 19. Steam Blowoff Piping | | | | | | | | | |
| Steam Blowoff Piping | STBL x 2 | 457.2 | 24.99 | 40 | A-106 | 9 | NA | NA | 2.248 m/s |

| Estimated Piping Data | ID x No. | Nom. D [mm] | Length [m] | Schedule | Material | Fittings | M [t/h] | Design Flow | Design Vel. [m/s] |
|-----------------------------------|----------|-------------|------------|----------|----------|----------|---------|-------------|-------------------|
| 20. Fire Protection Piping | | | | | | | | | |
| Main Fire Protection | FP0 x 1 | 508 | 1062.2 | 20 | A-106 | 88 | 1362 | 22712 lpm | 2.016 m/s |
| Miscellaneous Fire Protection | FP1 x 1 | 406.4 | 1062.2 | 20 | A-106 | 88 | 681 | 11356 lpm | 1.58 m/s |
| | | | | | | | | | |

| Estimated Pump Data | | |
|-----------------------------------|--------------------------|----------|
| Number of Units | | 1 |
| Boiler Feed Pump | | |
| Pump type | Multistage centrifugal | |
| Drive type | Variable RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 2070.6 | t/h |
| Nameplate (unrounded) head | 3155 | m |
| Nameplate volume flow | 41640 | lpm |
| Nameplate head | 3170 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 33000 | hp |
| Pump isentropic efficiency | 75 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 12.72 | m |
| Baseplate width (each) | 4.096 | m |
| Pump weight (each) | 89266 | kg |
| Turbine weight (each) | 85444 | kg |
| Boiler Feed Booster Pump | | |
| Pump type | Vertical canned | |
| Drive type | Fixed RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 2070.6 | t/h |
| Nameplate (unrounded) head | 81.81 | m |
| Nameplate volume flow | 41640 | lpm |
| Nameplate head | 83.82 | m H2O |
| Pump shaft speed | 600 | RPM |
| Shaft power | 800 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.792 | m |
| Baseplate width (each) | 1.792 | m |
| Pump weight (each) | 2042.6 | kg |
| Motor weight (each) | 2022.5 | kg |
| Condenser C.W. Pump | | |
| Pump type | Vertical turbine | |
| Drive type | Fixed RPM | |
| Number per ST | 8 - 12.5% | |
| Nameplate (unrounded) mass flow | 7455 | t/h |
| Nameplate (unrounded) head | 22.77 | m |
| Nameplate volume flow | 124919 | lpm |
| Nameplate head | 24.38 | m H2O |
| Pump shaft speed | 500 | RPM |
| Shaft power | 800 | hp |
| Pump isentropic efficiency | 87 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.784 | m |
| Baseplate width (each) | 1.784 | m |
| Pump weight (each) | 1999.8 | kg |
| Motor weight (each) | 2004.9 | kg |
| Condensate Forwarding Pump | | |
| Pump type | Vertical canned | |
| Drive type | Fixed RPM | |
| Number per ST | 2 - 100% | |
| Nameplate (unrounded) mass flow | 1326.2 | t/h |
| Nameplate (unrounded) head | 242.4 | m |
| Nameplate volume flow | 22712 | lpm |
| Nameplate head | 243.8 | m H2O |
| Pump shaft speed | 1500 | RPM |
| Shaft power | 1500 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 2.066 | m |
| Baseplate width (each) | 2.066 | m |
| Pump weight (each) | 3875 | kg |
| Motor weight (each) | 3334 | kg |
| Condenser Vacuum Pump | | |
| Drive type | Fixed RPM | |
| Number per ST | 2 - 50% | |
| Nameplate Suction Pressure | 53.72 | mmHg |
| Pump shaft speed | 500 | RPM |
| Shaft power | 90 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 3.052 | m |
| Baseplate width (each) | 2.18 | m |
| Pump weight (each) | 5749 | kg |
| Fuel Oil Unloading Pump | | |
| Pump type | Single stage centrifugal | |

| Estimated Pump Data | | |
|---|--------------------------|-------|
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 111.5 | t/h |
| Nameplate (unrounded) head | 45.81 | m |
| Nameplate volume flow | 2271.2 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 23 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.389 | m |
| Baseplate width (each) | 0.4881 | m |
| Pump weight (each) | 247 | kg |
| Motor weight (each) | 122.5 | kg |
| Fuel Oil Forwarding Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 40.29 | t/h |
| Nameplate (unrounded) head | 38.17 | m |
| Nameplate volume flow | 851.7 | lpm |
| Nameplate head | 45.72 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 7 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.067 | m |
| Baseplate width (each) | 0.3725 | m |
| Pump weight (each) | 127.1 | kg |
| Motor weight (each) | 48.44 | kg |
| Aux Cooling Water Pump (closed loop) | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 470.4 | t/h |
| Nameplate (unrounded) head | 24.43 | m |
| Nameplate volume flow | 8517 | lpm |
| Nameplate head | 27.43 | m H2O |
| Pump shaft speed | 1500 | RPM |
| Shaft power | 55 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.659 | m |
| Baseplate width (each) | 0.5858 | m |
| Pump weight (each) | 386.8 | kg |
| Motor weight (each) | 246.4 | kg |
| Treated Water Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.26 | t/h |
| Nameplate (unrounded) head | 57.55 | m |
| Nameplate volume flow | 378.5 | lpm |
| Nameplate head | 60.96 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 6 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.025 | m |
| Baseplate width (each) | 0.3575 | m |
| Pump weight (each) | 114.9 | kg |
| Motor weight (each) | 40.3 | kg |
| Diesel Fire Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 3 - 100% | |
| Nameplate (unrounded) mass flow | 449.1 | t/h |
| Nameplate (unrounded) head | 70.44 | m |
| Nameplate volume flow | 7571 | lpm |
| Nameplate head | 76.2 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 140 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 2.071 | m |
| Baseplate width (each) | 0.7358 | m |
| Pump weight (each) | 1692.9 | kg |
| Electric Fire Pump (P13) | | |
| Number of Pumps per Plant | None | |

| Estimated Pump Data | | |
|---|--------------------------|-------|
| Jockey Fire Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 10.25 | t/h |
| Nameplate (unrounded) head | 30.54 | m |
| Nameplate volume flow | 170.3 | lpm |
| Nameplate head | 38.1 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 1.5 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.753 | m |
| Baseplate width (each) | 0.2604 | m |
| Pump weight (each) | 52.71 | kg |
| Motor weight (each) | 15.19 | kg |
| ST+Generator Lube Oil Coolant Pump (P21) | | |
| Number of Pumps per ST+Generator Lube Oil | None | |
| ST Generator Coolant Pump (P22) | | |
| Number of Pumps per ST Generator | None | |
| Demin Water Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 22.26 | t/h |
| Nameplate (unrounded) head | 55.24 | m |
| Nameplate volume flow | 378.5 | lpm |
| Nameplate head | 60.96 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 5.5 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.016 | m |
| Baseplate width (each) | 0.3542 | m |
| Pump weight (each) | 112.3 | kg |
| Motor weight (each) | 39.04 | kg |
| Raw Water Pump 1 | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.26 | t/h |
| Nameplate (unrounded) head | 46.04 | m |
| Nameplate volume flow | 378.5 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 4.75 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.9764 | m |
| Baseplate width (each) | 0.34 | m |
| Pump weight (each) | 101.6 | kg |
| Motor weight (each) | 33.91 | kg |
| Raw Water Pump 2 | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.26 | t/h |
| Nameplate (unrounded) head | 46.04 | m |
| Nameplate volume flow | 378.5 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 4.75 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.9764 | m |
| Baseplate width (each) | 0.34 | m |
| Pump weight (each) | 101.6 | kg |
| Motor weight (each) | 33.91 | kg |
| Raw Water Pump 3 (P28) | | |
| Number of Pumps per Plant | None | |
| District Heating Pump (P29) | | |
| Number of Pumps per DHC | None | |
| Aux Cooling Water Pump (open loop) | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 470.4 | t/h |

| Estimated Pump Data | | |
|---------------------------------|------------------------|-------|
| Nameplate (unrounded) head | 24.43 | m |
| Nameplate volume flow | 8517 | lpm |
| Nameplate head | 27.43 | m H2O |
| Pump shaft speed | 1500 | RPM |
| Shaft power | 55 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.659 | m |
| Baseplate width (each) | 0.5858 | m |
| Pump weight (each) | 386.8 | kg |
| Motor weight (each) | 246.4 | kg |
| FGD Slurry Pump (P31) | | |
| Number of Pumps per FGD | None | |
| Startup Boiler Feed Pump | | |
| Pump type | Multistage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 517.7 | t/h |
| Nameplate (unrounded) head | 3334 | m |
| Nameplate volume flow | 10410 | lpm |
| Nameplate head | 3353 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 9000 | hp |
| Pump isentropic efficiency | 75 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 5.114 | m |
| Baseplate width (each) | 1.862 | m |
| Pump weight (each) | 23585 | kg |
| Motor weight (each) | 19654 | kg |

| Estimated Electric Load Data | Number in plant | Nameplate kW (each) | Nominal kW Operating | Nominal kW Standby | Nominal kWe Operating | Nominal kWe Standby | Voltage | Heat Balance Aux. kWe |
|---|-----------------|---------------------|----------------------|--------------------|-----------------------|---------------------|---------|-----------------------|
| 1. Pump Motors | | | | | | | | |
| Boiler Feed Booster Pump | 1 | 597 | 597 | 0 | 600 | 0 | 6600 V | 567.3 |
| Condenser C.W. Pump | 8 | 597 | 4,770 | 0 | 4,800 | 0 | 6600 V | 4435 |
| Condensate Forwarding Pump | 2 | 1,120 | 1,120 | 1,120 | 1,100 | 1,100 | 6600 V | 1072.2 |
| Condenser Vacuum Pump | 2 | 67.11 | 134 | 0 | 140 | 0 | 415 V | 140 |
| Fuel Oil Unloading Pump | 1 | 15.66 | 0 | 15.66 | 0 | 19 | 415 V | 0 |
| Fuel Oil Forwarding Pump | 2 | 4.847 | 4.847 | 4.847 | 6 | 6 | 415 V | 6 |
| Aux Cooling Water Pump (closed loop) | 2 | 41.01 | 41.01 | 41.01 | 45 | 45 | 415 V | 45 |
| Treated Water Pump | 1 | 3.729 | 3.729 | 0 | 5 | 0 | 415 V | 5 |
| Jockey Fire Pump | 1 | 1.119 | 1.119 | 0 | 1.25 | 0 | 415 V | 1.25 |
| Demin Water Pump | 2 | 3.542 | 3.542 | 3.542 | 4.75 | 4.75 | 415 V | 4.75 |
| Raw Water Pump 1 | 1 | 2.983 | 2.983 | 0 | 4 | 0 | 415 V | 4 |
| Raw Water Pump 2 | 1 | 2.983 | 2.983 | 0 | 4 | 0 | 415 V | 4 |
| Aux Cooling Water Pump (open loop) | 2 | 41.01 | 41.01 | 41.01 | 45 | 45 | 415 V | 45 |
| Startup Boiler Feed Pump | 1 | 6,710 | 0 | 6,710 | 0 | 7,000 | 6600 V | 0 |
| FWH 1 Drain Water Pump | 3 | 130 | 261 | 130 | 260 | 130 | 415 V | 215.7 |
| 2. Auxiliary Cooling Fan Motors | | | | | | | | |
| 3. Cooling Tower Fan Motors | | | | | | | | |
| Main Cooling Tower Fan | 1 | 0 | 0 | 0 | 0 | 0 | 415 V | 0 |
| 4. Air Compressor Motors | | | | | | | | |
| Station Air Compressor | 5 | 205 | 1,030 | 0 | 1,120 | 0 | 6600 V | 1025.3 |
| 5. Water Treatment System Motors | | | | | | | | |
| Misc. Water Treatment Auxiliary Loads | 18 | 52.2 | 313 | 626 | 330 | 660 | 415 V | 270.2 |
| 6. Bridge Crane Motors | | | | | | | | |
| ST bridge crane hoist motor | 1 | 104 | 0 | 104 | 0 | 110 | 415 V | 0 |
| ST bridge crane bridge motor | 2 | 7.457 | 0 | 14.91 | 0 | 17 | 415 V | 0 |
| ST bridge crane trolley motor | 2 | 7.084 | 0 | 14.17 | 0 | 16 | 415 V | 0 |
| 7. Boiler Fans | | | | | | | | |
| Boiler Forced Draft Fan | 3 | 746 | 2,240 | 0 | 2,400 | 0 | 6600 V | 1868.7 |
| Boiler Induced Draft Fan | 3 | 1,040 | 3,130 | 0 | 3,300 | 0 | 6600 V | 2593.6 |
| Primary Air Fan | 3 | 597 | 1,790 | 0 | 2,100 | 0 | 6600 V | 1395.3 |
| 8. Pollution Control | | | | | | | | |
| Electrostatic Precipitator | 1 | 1,860 | 1,860 | 0 | 2,000 | 0 | 6600 V | 1566.7 |
| Ash Handling | 3 | 522 | 1,040 | 522 | 1,000 | 500 | 6600 V | 831.9 |
| 9. Fuel Delivery Motors | | | | | | | | |
| Fuel Handling | 6 | 895 | 5,370 | 0 | 5,400 | 0 | 6600 V | 4311 |
| 10. ST Auxiliary Loads | | | | | | | | |
| ST Lube Oil Pumps | 2 | 1,300 | 1,300 | 1,300 | 1,300 | 1,300 | 6600 V | 1013.3 |
| Misc. ST Aux Loads | 18 | 18.64 | 336 | 0 | 360 | 0 | 415 V | 354.7 |
| 11. Miscellaneous Plant Loads | | | | | | | | |
| HVAC Loads | 1 | 104 | 104 | 0 | 110 | 0 | 415 V | 110 |
| Lighting Loads | 1 | 298 | 298 | 0 | 275 | 0 | 415 V | 275 |
| Misc. Plant Aux Loads 1 | 8 | 205 | 1,230 | 410 | 1,200 | 400 | 6600 V | 1182.2 |
| Misc. Plant Aux Loads 2 | 9 | 55.93 | 503 | 0 | 540 | 0 | 415 V | 506.6 |
| Total Plant Motors & Loads | 117 | | 36,930 | 14,840 | 28,460 | 11,350 | | 23850.7 |
| Total 6600 V Motors & Loads | | | | | 26,320 | 10,300 | | |
| Total 415 V Motors & Loads | | | | | 2,130 | 1,050 | | |

| Estimated Main Electrical Data | | |
|---|--------------------|-------|
| 1. Steam Turbine Step-up Transformer | | |
| Count | 1 | |
| Nominal Rating | 788 | MVA |
| Cooling Configuration | OA/FA/FA | |
| High-side Voltage | 500 | kV |
| Low-side Voltage | 20 | kV |
| Length | 27.86 | m |
| Width | 9.285 | m |
| Weight | 625,000 | kg |
| Unit Mechanical Installation hours | 6,270 | hours |
| Unit Electrical Installation hours | 6,270 | hours |
| Unit Reference Cost | 9,816,000 | USD |
| 2. Medium Voltage Step-down Transformer | | |
| Count | 2 | |
| Nominal Rating | 20.35 | MVA |
| High-side Voltage | 20 | kV |
| Low-side Voltage | 6.6 | kV |
| Length | 2.418 | m |
| Width | 1.934 | m |
| Weight | 12,350 | kg |
| Unit Mechanical Installation hours | 310 | hours |
| Unit Electrical Installation hours | 310 | hours |
| Unit Reference Cost | 292,150 | USD |
| 3. Low Voltage Step-down Transformer | | |
| Count | 2 | |
| Nominal Rating | 1.768 | MVA |
| High-side Voltage | 20 | kV |
| Low-side Voltage | 0.415 | kV |
| Length | 2.198 | m |
| Width | 1.758 | m |
| Weight | 5,730 | kg |
| Unit Mechanical Installation hours | 144 | hours |
| Unit Electrical Installation hours | 144 | hours |
| Unit Reference Cost | 123,100 | USD |
| 4. Steam Turbine Generator Circuit Breaker | | |
| Count | 1 | |
| Voltage | 20 | kV |
| Amperage | 22,750 | Amps |
| Unit Mechanical Installation hours | 319 | hours |
| Unit Electrical Installation hours | 637 | hours |
| Unit Reference Cost | 3,079,000 | USD |
| 5. Utility Interconnect Circuit Breaker | | |
| Count | 1 | |
| Voltage | 500 | kV |
| Amperage | 859 | Amps |
| Unit Mechanical Installation hours | 182 | hours |
| Unit Electrical Installation hours | 364 | hours |
| Unit Reference Cost | 961,000 | USD |
| 6. Auxiliary Bus Feeder Circuit Breaker | | |
| Count | 1 | |
| Voltage | 20 | kV |
| Amperage | 1,280 | Amps |
| Unit Mechanical Installation hours | 155 | hours |
| Unit Electrical Installation hours | 310 | hours |
| Unit Reference Cost | 35,070 | USD |
| 7. Medium Voltage Circuit Breaker | | |
| Count | 2 | |
| Voltage | 6.6 | kV |
| Amperage | 1,780 | Amps |
| Unit Mechanical Installation hours | 169 | hours |
| Unit Electrical Installation hours | 337 | hours |
| Unit Reference Cost | 48,890 | USD |
| 8. Low Voltage Circuit Breaker | | |
| Count | 2 | |
| Voltage | 0.415 | kV |
| Amperage | 2,460 | Amps |
| Unit Mechanical Installation hours | 183 | hours |
| Unit Electrical Installation hours | 366 | hours |
| Unit Reference Cost | 120,200 | USD |
| 9. Generator to Step-up Transformer Bus | | |
| Steam Turbine Generator Bus Type | Isolated phase bus | |
| Number generators | 1 | |
| Length (per generator) | 73.41 | m |
| Mechanical installation hours (per generator) | 1,440 | hours |
| Electrical installation hours (per generator) | 722 | hours |

| Estimated Main Electrical Data | | |
|--|-----------|-------|
| Reference Cost (per generator) | 4,452,000 | USD |
| 10. Plant Buswork | | |
| Low Voltage | | |
| Total length (all runs) | 4,720 | m |
| Total Electrical Installation hours | 7,380 | hours |
| Total Reference Equipment Cost | 463,800 | USD |
| Medium Voltage | | |
| Total length (all runs) | 6,650 | m |
| Total Electrical Installation hours | 6,040 | hours |
| Total Reference Equipment Cost | 294,850 | USD |
| 11. Switch Gear | | |
| Low Voltage | | |
| Number sections in plant | 0 | |
| Medium Voltage | | |
| Number sections in plant | 6 | |
| Total weight | 10,400 | kg |
| Total Mechanical Installation hours | 805 | hours |
| Total Electrical Installation hours | 2,680 | hours |
| Total Reference Equipment Cost | 1,393,000 | USD |
| 12. Motor Control Centers | | |
| Low Voltage | | |
| Number sections in plant | 21 | |
| Total number of starters | 53 | |
| Total load on all starters | 2,710 | kW |
| Total weight | 9,530 | kg |
| Total Mechanical Installation hours | 289 | hours |
| Total Electrical Installation hours | 964 | hours |
| Total Reference Equipment cost | 198,200 | USD |
| Medium Voltage | | |
| Number sections in plant | 24 | |
| Total number of starters | 44 | |
| Total load on all starters | 32,940 | kW |
| Total weight | 33,680 | kg |
| Total Mechanical Installation hours | 545 | hours |
| Total Electrical Installation hours | 1,820 | hours |
| Total Reference Equipment cost | 2,139,000 | USD |
| 13. Motor & Load Feeders | | |
| Low Voltage | | |
| Number runs in plant | 52 | |
| Total length (all runs) | 3,720 | m |
| Total Electrical Installation hours | 5,490 | hours |
| Total Reference Equipment Cost | 160,800 | USD |
| Medium Voltage | | |
| Number runs in plant | 44 | |
| Total length (all runs) | 3,140 | m |
| Total Electrical Installation hours | 5,520 | hours |
| Total Reference Equipment Cost | 207,800 | USD |
| 14. Cable Tray | | |
| Total length (all runs) | 2,270 | m |
| Total Mechanical Installation hours | 12,160 | hours |
| Total Electrical Installation hours | 4,260 | hours |
| Total Reference Equipment Cost | 201,800 | USD |
| 15. General Plant Instrumentation | | |
| Instrument Count | 69.19 | |
| Total Electrical Installation hours | 3,190 | hours |
| Total Reference Equipment Cost | 370,650 | USD |

| Estimated Tank Data | Number | Volume [l] | Diameter [m] | Height [m] |
|---------------------|--------|------------|--------------|------------|
| Fuel Oil | 1 | 2,701,000 | 17.7 | 11.0 |
| Deminerlized Water | 1 | 383,850 | 8.1 | 7.5 |
| Raw Water | 1 | 383,850 | 8.1 | 7.5 |
| Neutralized Water | 1 | 191,950 | 5.7 | 7.5 |
| Acid Storage | 1 | 23,030 | 2.4 | 5.1 |
| Caustic Storage | 1 | 23,030 | 2.4 | 5.1 |
| Fire Protection | 1 | 2,725,000 | 17.8 | 11 |

| Estimated Water Treatment System Data | | |
|--|---------|--------------------|
| 1. Clarifier-Reactivator | | None |
| 2. Pressure Filter | | None |
| 3. Softener | | 1 Twin Unit |
| Design Flow (8 hr continuous operation running one unit) | 261 | lpm |
| Exchange Capacity (each) | 72,000 | ppm per min. |
| Weight (twin unit) | 32,860 | kg |
| Cost (twin unit), Reference Basis | 403,950 | USD |
| 4. Reverse Osmosis System | | None |
| 5. Two-Bed Demineralizer | | 1 Train |
| Design Flow (each) | 261 | lpm |
| Weight (each) | 2,360 | kg |
| Cost (each), Reference Basis | 894,800 | USD |

| Estimated Boiler Data | | |
|--|-------------|------------------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| 1. Boiler System Summary | | |
| Boiler Type | | Conventional, Two Pass |
| Overall Length | 40.28 | m |
| Overall Width | 18.72 | m |
| Overall Height | 66.45 | m |
| Total Weight (wet) | 13,768,000 | kg |
| Total Weight (dry) | 13,581,000 | kg |
| Includes: | | |
| - Furnace incl. burners & waterwall | | |
| - Pulverizers & feeders | | |
| - Boiler casing & refractory | | |
| - Convective HX incl. waterwall | | |
| - Desuperheaters and controls | | |
| - Air & flue gas ducts | | |
| - Burner piping & fittings | | |
| - Soot blowers | | |
| - Structural steel incl. walkways & ladders | | |
| - Rotary air heater | | |
| - Fans | | |
| - Miscellaneous | | |
| Overall Heat Transfer Surface Area | 84,000 | m ² |
| - Water Wall effective projected surface | 5,120 | m ² |
| - Economiser | 46,760 | m ² |
| - Superheater (convective & radiant) | 13,010 | m ² |
| - Reheater (convective & radiant) | 19,120 | m ² |
| Total Number of Tubes (in convective elements) | 10,900 | |
| Total Boiler Cost, Reference Basis | 179,784,000 | USD |
| Includes: | | |
| - Furnace (incl. radiant platens) | | |
| - Convective Elements (incl. interconnecting piping) | | |
| - Additional Waterwall | | |
| - Soot Blowers | | |
| - Desuperheaters and Controls | | |
| - Air and Flue Gas Ducts | | |
| - Coal Pulverisers and Feeders | | |
| - FD Fan, PA Fan, ID Fan | | |
| - Supporting Steel Structure, Ladders, Walkways | | |
| - Rotary Air Heater | | |
| 2. Furnace | | |
| Furnace height (including hopper height if it exists) | 66.45 | m |
| Furnace width | 18.72 | m |
| Furnace depth | 18.34 | m |
| Aperture height | 18.72 | m |
| Hopper height | 11.01 | m |
| Furnace volume | 20,930 | m ³ |
| Furnace effective projected radiant surface | 6,950 | m ² |
| Water wall effective projected surface | 5,120 | m ² |
| Radiant superheater | 1,830 | m ² |
| 3. Horizontal Pass | | |
| Height (tube length) | 18.72 | m |
| Width (boiler width) | 18.72 | m |
| Depth (duct length) | 3.368 | m |
| Gas flow frontal area | 350 | m ² |
| 4. Second Vertical Downward Pass | | |
| Height (duct length) | 6.604 | m |
| Width (boiler width) | 18.72 | m |
| Depth (tube length) | 18.27 | m |
| Gas flow frontal area | 342 | m ² |
| 5. Rotary Air Heater | | |
| Matrix heat transfer surface | 45,420 | m ² |
| Total flow cross section area | 55.88 | m ² |
| Total frontal surface | 94.44 | m ² |
| - Gas surface | 50 | % |
| - Secondary air surface | 45.62 | % |
| - Primary air surface | 4.384 | % |
| Unit height | 5.975 | m |
| Unit side dimension | 12.56 | m |
| Unit foot area | 158 | m ² |

| Estimated Steam Turbine Data | | |
|--|--------------------|----------------|
| Number of Units | 1 | |
| Displayed quantities in this table are on a per unit basis | | |
| 1. Steam Turbine Description | | |
| Nameplate Capacity | 788.1 | MVA |
| Power Factor | 0.9 | |
| Steam Turbine Type | Condensing, Reheat | |
| Nameplate Throttle Pressure | 289.8 | bar |
| Nameplate Throttle Temperature | 604 | C |
| Nameplate Throttle Massflow | 1863.6 | t/h |
| Exhaust End Type | Down Draft | |
| Number of LPT Exhaust Annuli | 2 | |
| Last Stage Bucket Length | 1144.5 | mm |
| Last Stage Pitch Diameter | 2983.5 | mm |
| Number of Ports | 12 | |
| Number of Auto-Extraction Ports | 0 | |
| 2. Estimated Weights, Dimensions & Cost | | |
| Steam Turbine Length | 38.2 | m |
| Steam Turbine Width | 6.605 | m |
| Steam Turbine Weight | 977,900 | kg |
| Generator Length (Including Exciter) | 15.93 | m |
| Generator Width | 4.39 | m |
| Generator Weight | 618,200 | kg |
| Overall ST and Generator Length | 54.12 | m |
| Overall ST and Generator Width | 6.605 | m |
| Overall ST and Generator Weight | 1,596,000 | kg |
| Equipment Cost per Unit, Reference Basis | 94,021,000 | USD |
| Foundation Length | 58.94 | m |
| Foundation Width | 7.926 | m |
| Foundation Concrete per Unit | 2315 | m ³ |

| Estimated Feedwater Heater Data | | |
|---|-----------------------|----------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| FWH 1-P | | |
| Feedwater heater configuration: Includes condensing section only | | |
| Nameplate steam pressure | 0.3458 | bar |
| Shell material | Carbon Steel | |
| Shell length | 15.21 | m |
| Shell inner diameter | 1.424 | m |
| Shell wall thickness | 7.938 | mm |
| Tube sheet thickness | 60.33 | mm |
| Nameplate water pressure | 21.6 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 824 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1648 | |
| Tube length per pass | 15.21 | m |
| Tube outer diameter (O.D.) | 15.88 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 23.02 | mm |
| Total heat transfer area (outside tubes) | 1,250 | m ² |
| Tube weight, dry | 11,600 | kg |
| Overall length | 17.5 | m |
| Overall outer diameter | 1.4 | m |
| Heater total dry weight | 20,820 | kg |
| Heater total operating (wet) weight | 26,650 | kg |
| FWH 2-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 1.112 | bar |
| Shell material | Carbon Steel | |
| Shell length | 16.2 | m |
| Shell inner diameter | 1.598 | m |
| Shell wall thickness | 9.525 | mm |
| Tube sheet thickness | 63.5 | mm |
| Nameplate water pressure | 19.62 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 1038 | |
| Number of passes | 2 | |
| Number of tubes in heater | 2076 | |
| Tube length per pass | 16.2 | m |
| Tube outer diameter (O.D.) | 15.88 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 23.02 | mm |
| Total heat transfer area (outside tubes) | 1,680 | m ² |
| Tube weight, dry | 15,570 | kg |
| Overall length | 18.7 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 29,350 | kg |
| Heater total operating (wet) weight | 37,140 | kg |
| FWH 3-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 2.936 | bar |
| Shell material | Carbon Steel | |
| Shell length | 17.98 | m |
| Shell inner diameter | 1.568 | m |
| Shell wall thickness | 7.938 | mm |
| Tube sheet thickness | 57.15 | mm |
| Nameplate water pressure | 17.71 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 694 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1388 | |
| Tube length per pass | 17.98 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 27.62 | mm |
| Total heat transfer area (outside tubes) | 1,490 | m ² |
| Tube weight, dry | 14,040 | kg |
| Overall length | 20.5 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 26,580 | kg |
| Heater total operating (wet) weight | 34,880 | kg |

| Estimated Feedwater Heater Data | | |
|---|-----------------------|----------------|
| FWH 4-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 6.667 | bar |
| Shell material | Carbon Steel | |
| Shell length | 15.86 | m |
| Shell inner diameter | 1.589 | m |
| Shell wall thickness | 9.525 | mm |
| Tube sheet thickness | 44.45 | mm |
| Nameplate water pressure | 16.18 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 713 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1426 | |
| Tube length per pass | 15.86 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 27.62 | mm |
| Total heat transfer area (outside tubes) | 1,350 | m ² |
| Tube weight, dry | 12,710 | kg |
| Overall length | 18.4 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 24,920 | kg |
| Heater total operating (wet) weight | 32,470 | kg |
| FWH 5-DA | | |
| DA type | HH | |
| Nameplate feedwater exit flow | 1863563 | kg/hr |
| Total storage volume | 248306 | l |
| Total storage capacity | 7 | Min |
| Number of units | 1 | |
| Overall height | 7.955 | m |
| Overall length | 18.24 | m |
| Storage tank | | |
| -Thickness | 25.4 | mm |
| -Outside diameter | 4.572 | m |
| -Total length | 18.24 | m |
| Heater | | |
| -Thickness | 15.88 | mm |
| -Outside diameter | 2.773 | m |
| -Total length | 16.59 | m |
| Dry weight | 83017 | kg |
| Operating weight | 322174 | kg |
| Flooded weight | 407794 | kg |
| Structure weight | 90837 | kg |
| FWH 6-D (6A, 6B) | | |
| Feedwater heater configuration: Includes desuperheating section, condensing section, drain cooler | | |
| Nameplate steam pressure | 22.24 | bar |
| Shell material | Carbon Steel | |
| Shell length | 9.058 | m |
| Shell inner diameter | 1.728 | m |
| Shell wall thickness | 22.22 | mm |
| Tube sheet thickness | 460 | mm |
| Nameplate water pressure | 309 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 1135 | |
| Number of passes | 2 | |
| Number of tubes in heater | 2270 | |
| Tube length per pass | 9.058 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 3.404 | mm |
| Tube pitch | 23.81 | mm |
| Total heat transfer area (outside tubes) | 1,230 | m ² |
| Tube weight, dry | 29,720 | kg |
| Overall length | 12.0 | m |
| Overall outer diameter | 1.8 | m |
| Heater total dry weight | 69,750 | kg |
| Heater total operating (wet) weight | 73,500 | kg |
| FWH 7-D (7A, 7B) | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 41.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 10.04 | m |
| Shell inner diameter | 1.901 | m |
| Shell wall thickness | 50.8 | mm |

| Estimated Feedwater Heater Data | | |
|---|--------------|----------------|
| Tube sheet thickness | 362 | mm |
| Nameplate water pressure | 308 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 1177 | |
| Number of passes | 2 | |
| Number of tubes in heater | 2354 | |
| Tube length per pass | 10.04 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 3.404 | mm |
| Tube pitch | 25.72 | mm |
| Total heat transfer area (outside tubes) | 1,410 | m ² |
| Tube weight, dry | 33,230 | kg |
| Overall length | 13.1 | m |
| Overall outer diameter | 2 | m |
| Heater total dry weight | 99,050 | kg |
| Heater total operating (wet) weight | 103,450 | kg |
| FWH 8-D (8A, 8B) | | |
| Feedwater heater configuration: Includes desuperheating section, condensing section, drain cooler | | |
| Nameplate steam pressure | 62.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 9.417 | m |
| Shell inner diameter | 1.802 | m |
| Shell wall thickness | 69.85 | mm |
| Tube sheet thickness | 410 | mm |
| Nameplate water pressure | 307 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 1234 | |
| Number of passes | 2 | |
| Number of tubes in heater | 2468 | |
| Tube length per pass | 9.417 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 3.404 | mm |
| Tube pitch | 23.81 | mm |
| Total heat transfer area (outside tubes) | 1,390 | m ² |
| Tube weight, dry | 33,140 | kg |
| Overall length | 12.5 | m |
| Overall outer diameter | 1.9 | m |
| Heater total dry weight | 102,300 | kg |
| Heater total operating (wet) weight | 106,300 | kg |
| FWH 9-S (9A, 9B) | | |
| Feedwater heater configuration: Shell heating with vapor only fluid | | |
| Please Note: | | |
| Design based on condensing FWH methods - may be less accurate for single-phase fluid in shell | | |
| Nameplate steam pressure | 41.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 2.993 | m |
| Shell inner diameter | 1.445 | m |
| Shell wall thickness | 38.1 | mm |
| Tube sheet thickness | 276 | mm |
| Nameplate water pressure | 307 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 999 | |
| Number of passes | 1 | |
| Number of tubes in heater | 999 | |
| Tube length per pass | 2.993 | m |
| Tube outer diameter (O.D.) | 22.22 | mm |
| Tube wall thickness | 4.191 | mm |
| Tube pitch | 30 | mm |
| Total heat transfer area (outside tubes) | 209 | m ² |
| Tube weight, dry | 6,590 | kg |
| Overall length | 6.6 | m |
| Overall outer diameter | 1.5 | m |
| Heater total dry weight | 39,200 | kg |
| Heater total operating (wet) weight | 40,710 | kg |

| Estimated Water Cooled Condenser Data | | |
|--|-----------------------|----------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| WCC | | |
| Condenser type | | Shell & tube |
| Number of units | | 1 |
| 1. Condenser Tube Description | | |
| Effective surface area | 41031 | m ² |
| Number of condenser passes | 2 | |
| Tube material | Stainless steel (304) | |
| Number of tubes in condenser | 44113 | |
| Tube length | 13.3 | m |
| Tube outside diameter (O.D.) | 22.23 | mm |
| Tube inside diameter (I.D.) | 20.8 | mm |
| Tube wall thickness | 0.7112 | mm |
| Tube weight, dry | 226,800 | kg |
| Tube pitch | 35.56 | mm |
| 2. Condenser Shell Description | | |
| Shell material | Carbon steel | |
| Nominal shell thickness | 15.88 | mm |
| Number tube support plates | 23 | |
| Tube support plate spacing | 0.55 | m |
| Hotwell depth | 0.87 | m |
| Total dry weight | 695,200 | kg |
| Overall footprint area | 168.7 | m ² |
| Overall length | 19.4 | m |
| Overall width | 8.7 | m |
| Overall height | 13.9 | m |

| Estimated Cooling Tower Data | | |
|--|--------|----------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| Natural Draft CT | | |
| 1. Estimated Major Dimensions | | |
| Height | | |
| Overall - ground to top | 208.8 | m |
| Throat - ground to throat | 148.2 | m |
| Above fill - top of fill to exit | 199.6 | m |
| Below fill - ground to top of fill | 9.144 | m |
| Diameter | | |
| Base | 93.85 | m |
| Throat | 52.14 | m |
| Exit | 61.11 | m |
| Basin area | 6918 | m ² |
| Average shell thickness | 457.2 | mm |
| Tower includes flue gas connection | | |
| 2. Concrete | | |
| Shell | 23,770 | m ³ |
| Basin | 2,180 | m ³ |
| Ring foundation | 1,040 | m ³ |
| Total | 26,990 | m ³ |

| Estimated Flue Gas Treatment Data | | |
|--|------------|------------------------------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| ESP | | |
| Design collection efficiency | 99.5 | % |
| Design inlet temperature | 137.8 | C |
| Design flue gas mass flow | 2,570 | t/h |
| Design flue gas volume flow | 3,009,000 | m ³ /hr |
| Design flue gas velocity | 1.372 | m/s |
| Overall Dimensions | | |
| Number of chambers | 3 | |
| Number of fields | 4 | |
| Total length | 30.8 | m |
| Total width | 68.67 | m |
| Total height | 20.58 | m |
| Total weight | 1,905,000 | kg |
| Collecting Plates | | |
| Design specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Total collection surface area | 75,050 | m ² |
| Number of plates per chamber | 62 | |
| Collecting plates height | 10.97 | m |
| Collecting plates spacing | 304.8 | mm |
| Collecting plates bundle width per chamber | 18.59 | m |
| Collecting plates depth per field | 4.671 | m |
| Collecting length | 18.68 | m |
| Aspect ratio (Collecting length / Plate height) | 1.703 | |
| 2. Stack | | |
| Type | Concrete | |
| Concrete Shell Diameter at Base Level | 17.63 | m |
| Concrete Shell Diameter at Top Level | 14.03 | m |
| Steel Liner Diameter | 7.603 | m |
| Height | 155.4 | m |
| Total Reference Cost (Installation included) | 10,997,000 | USD |

| Estimated Desalination Plant Data: MSF System | | |
|---|--|-----------------------|
| Multi-Stage Flash Desalination | | |
| 1. General | | |
| Number of units | | 1 |
| Number of stages per unit | | 21 |
| Number of stages in heat recovery section (HGS) | | 0 |
| Number of stages in heat rejection section (HRS) | | 0 |
| Nominal desalinated water flow per unit | | 0 t/h |
| Nominal desalinated water flow per unit (MIGD) | | 0 MIGD |
| Nominal desalinated water flow per unit (m ³ /day) | | 0 m ³ /day |
| 2. Overall dimensions and total weight (per unit, excluding seawater supply circuit) | | |
| Length | | 0 m |
| Width | | 0 m |
| Height | | 0 m |
| Dry weight | | 0 tonne |
| 3. Brine heater (per unit) | | |
| Tube material | | CuNi 70-30 |
| Heat transfer area | | 3,747 m ² |
| Tube outside diameter | | 38.1 mm |
| Tube wall thickness | | 1 mm |
| Tube length | | 15.24 m |
| Number of tubes | | 2054 |
| 4. Evaporator (per unit) | | |
| Length | | 0 m |
| Width | | 0 m |
| Height | | 0 m |
| Dry weight | | 0 tonne |
| HGS Stage Condensers | | |
| - Tube material | | CuNi 90-10 |
| - Heat transfer area per stage | | 3747 m ² |
| - HGS total heat transfer area | | 0 m ² |
| - Tube outside diameter | | 38.1 mm |
| - Tube wall thickness | | 1 mm |
| - Tube length | | 15.24 m |
| - Number of tubes per stage | | 2054 |
| HRS Stage Condensers | | |
| - Tube material | | Titanium |
| - Heat transfer area per stage | | 3122 m ² |
| - HRS total heat transfer area | | 0 m ² |
| - Tube outside diameter | | 31.75 mm |
| - Tube wall thickness | | 0.7 mm |
| - Tube length | | 15.24 m |
| - Number of tubes per stage | | 2054 |


| Estimated Desalination Plant Data: MED System | | |
|--|----------|---------------------|
| Multi-Effect Distillation | | |
| 1. General | | |
| Number of units | | 0 |
| Number of effects per unit | | 8 |
| System configuration | MED only | |
| First effect heating steam saturation temperature | -17.78 | C |
| Top brine temperature | -17.78 | C |
| Final effect temperature | -17.78 | C |
| Nameplate capacity | 0 | t/h |
| Nameplate capacity (MIGD) | 0 | MIGD |
| Nameplate capacity (m ³ /day) | 0 | m ³ /day |
| 2. Evaporator island (per unit, incl. main condenser) | | |
| Total heat transfer area | 0 | m ² |
| Length | 0 | m |
| Width | 0 | m |
| Height | 0 | m |
| Dry weight | 0 | tonne |
| Operating weight | 0 | tonne |
| 3. Evaporators (per unit) | | |
| Total heat transfer area | 0 | m ² |
| Number of effects | 8 | |
| Heat transfer area per effect | 0 | m ² |
| Number of tubes per effect | 0 | |
| Tube outside diameter | 0 | mm |
| Tube wall thickness | 0 | mm |
| Tube length | 0 | m |
| Tube material | Titanium | |
| Tube dry weight per effect | 0 | tonne |
| Total shell length of all effects | 0 | m |
| Shell outside diameter | 0 | m |
| Shell wall thickness | 0 | mm |
| Total tube dry weight | 0 | tonne |
| Total dry weight | 0 | tonne |
| Total operating weight | 0 | tonne |
| Total flooding weight | 0 | tonne |
| 4. Main condenser (per unit) | | |
| Overall length | 0 | m |
| Overall width | 0 | m |
| Overall height | 0 | m |
| Heat transfer area | 0 | m ² |
| Number of tubes | 0 | |
| Number of passes | 0 | |
| Tube outside diameter | 0 | mm |
| Tube wall thickness | 0 | mm |
| Tube length | 0 | m |
| Tube material | Titanium | |
| Tube dry weight | 0 | tonne |
| Total dry weight | 0 | tonne |
| Total operating weight | 0 | tonne |

| | | |
|---|----|---------------------|
| Estimated Desalination Plant Data: RO System | | |
| Reverse Osmosis Desalination | | |
| 1. Nameplate Data | | |
| Total number of RO trains in plant | 0 | |
| Desalinated water flow | 0 | t/h |
| Desalinated water flow (MIGD) | 0 | MIGD |
| Desalinated water flow (m ³ /day) | 0 | m ³ /day |
| Inlet water flow | 0 | t/h |
| Inlet water salinity | 0 | % |
| Water recovery ratio | 40 | % |
| Membrane feed pressure | 0 | bar |
| Total power consumption | 0 | kW |

| Estimated Miscellaneous Equipment Data | | |
|---|--------------|-------------|
| 1. Air Compressor | | |
| Number of Air Compressors in plant | 5 - 100% | |
| Capacity (each) | 1529.1 | m³/h |
| Motor Power (each) | 205 | kW |
| Weight (each) | 7,070 | kg |
| Installation Labor (each) | 230 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 156,400 | USD |
| Foundation Concrete (each) | 12.03 | m³ |
| Foundation Labor (each) | 450 | Labor Hours |
| 2. Auxiliary Boiler | | |
| None | | |
| 3. Emergency Generator | | |
| Number of Generators | 1 | |
| Generator Set Type | Medium Speed | |
| Capacity (each) | 1,750 | kW |
| Length | 9.9 | m |
| Width | 2.4 | m |
| Height | 3.3 | m |
| Weight | 34,750 | kg |
| Installation Labor (each) | 195 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 810,700 | USD |
| Foundation Concrete (each) | 57.84 | m³ |
| Foundation Labor (each) | 1,340 | Labor Hours |
| 4. Black Start Generator | | |
| Number of Generators | 5 | |
| Generator Set Type | Medium Speed | |
| Capacity (each) | 5,500 | kW |
| Length | 12.5 | m |
| Width | 2.5 | m |
| Height | 3.9 | m |
| Weight | 73,050 | kg |
| Installation Labor (each) | 195 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 2,548,000 | USD |
| Foundation Concrete (each) | 121 | m³ |
| Foundation Labor (each) | 2,400 | Labor Hours |
| 5. Auxiliary Heat Exchanger | | |
| Number of Cells (per plant) | 1 | |
| Capacity (each) | 7,600 | kW |
| Installation Labor (each) | 125 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 129,800 | USD |
| 6. Bridge Crane (for ST) | | |
| Number of Cranes in Plant | 1 | |
| Span | 39.6 | m |
| Capacity | 156 | Ton |
| Crane Weight | 349,200 | kg |
| Hoist Motor Power | 104 | kW |
| Bridge Motors | 2 - 7.457 | kW |
| Trolley Motor Power | 7.084 | kW |
| Installation Labor | 1,640 | Labor Hours |
| Crane & Support Cost, Reference Basis, (each) | 1,838,000 | USD |


| | | |
|--|---------------|------------------|
| Caution! These results are based on a single set of nameplate plant performance data applied for user-input number of operating hours per year. | | |
| Annual Electricity Exported | 5,260 | 10^6 kWh |
| Annual Heat Exported | 0 | TJ |
| Annual Fuel Imported | 44,200 | TJ LHV |
| Annual Water Imported | 9,200 | 10^6 l |
| Annual CO2 Emission | 4,090 | ktonne |
| Annual Desal Water Exported | 0 | MM imperial gal. |
| Annual Hydrogen Exported | 0 | TJ LHV |
| Annual Syngas Exported | 0 | TJ LHV |
| Annual CO2 Captured | 0 | ktonne |
| Annual Limestone Consumed | 0 | ktonne |
| Annual Lime Consumed | 0 | ktonne |
| Annual CO2 Capture Solvent Consumed | 0 | ktonne |
| Annual Combustion Waste Production | 152 | ktonne |
| Annual FGD Waste/Byproducts Production | 0 | ktonne |
| Annual Activated Carbon Consumed | 0 | ktonne |
| Total Investment | 1,600,115,000 | USD |
| Specific Investment | 2461.8 | USD per kW |
| Initial Equity | 480,035,000 | USD |
| Cumulative Net Cash Flow | 7,702,139,000 | USD |
| Internal Rate of Return on Investment (ROI) | 14.088 | % |
| Internal Rate of Return on Equity (ROE) | 23.528 | % |
| Years for Payback of Equity | 5.119 | years |
| Net Present Value | 1,048,186,000 | USD |
| Break-even Electricity Price @ Input Fuel Price (i.e. Levelised Cost of Electricity) | 0.0436 | USD/kWhr |
| Break-even Fuel LHV Price @ Input Electricity Price | 3.925 | USD/GJ |
| Other | | |
| First Year Combustion Waste Disposal Cost | 0 | USD/tonne |
| First Year FGD Waste/Byproducts Disposal Cost | 0 | USD/tonne |
| First Year Combustion Waste Disposal Expense | 0 | USD |
| First Year FGD Waste/Byproducts Disposal Expense | 0 | USD |
| First Year Total Other Expense | 0 | USD |

| Cash Flow USD | 2040 (21) | 2041 (22) | 2042 (23) | 2043 (24) | 2044 (25) | 2045 (26) | 2046 (27) | 2047 (28) | 2048 (29) | 2049 (30) |
|--|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Escalators | | | | | | | | | | |
| Inflation | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Fuel | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Steam | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Electricity | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Imported Water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| H2 from syngas | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Reagent | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Activated carbon | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Prices | | | | | | | | | | |
| Electricity, USD per kWh | 0.1568 | 0.1638 | 0.1712 | 0.1789 | 0.1869 | 0.1954 | 0.2041 | 0.2133 | 0.2229 | 0.233 |
| Fuel, USD/GJ | 3.304 | 3.453 | 3.608 | 3.77 | 3.94 | 4.117 | 4.303 | 4.496 | 4.699 | 4.91 |
| Steam, USD/GJ | 11.43 | 11.94 | 12.48 | 13.04 | 13.63 | 14.24 | 14.88 | 15.55 | 16.25 | 16.99 |
| Imported Water, USD/m^3 | 0.6371 | 0.6658 | 0.6957 | 0.727 | 0.7598 | 0.794 | 0.8297 | 0.867 | 0.906 | 0.9468 |
| CO2 Emission Penalty, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water, USD per 1000 imperial gallons | 9.647 | 10.08 | 10.53 | 11.01 | 11.5 | 12.02 | 12.56 | 13.13 | 13.72 | 14.34 |
| H2 from syngas, USD/GJ | 18.29 | 19.11 | 19.97 | 20.87 | 21.81 | 22.79 | 23.82 | 24.89 | 26.01 | 27.18 |
| Syngas, USD/GJ | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Limestone, USD/tonne | 53.17 | 55.56 | 58.06 | 60.67 | 63.41 | 66.26 | 69.24 | 72.36 | 75.61 | 79.01 |
| Lime, USD/tonne | 212.7 | 222.2 | 232.2 | 242.7 | 253.6 | 265 | 277 | 289.4 | 302.4 | 316.1 |
| Captured CO2, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent, USD/tonne | 5317 | 5556 | 5806 | 6067 | 6341 | 6626 | 6924 | 7236 | 7561 | 7901 |
| Activated carbon, USD/tonne | 5317 | 5556 | 5806 | 6067 | 6341 | 6626 | 6924 | 7236 | 7561 | 7901 |
| Revenues | | | | | | | | | | |
| Electricity | 825,336,000 | 862,476,000 | 901,287,000 | 941,845,000 | 984,228,000 | 1,028,518,000 | 1,074,802,000 | 1,123,168,000 | 1,173,710,000 | 1,226,527,000 |
| Capacity | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Steam | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 from syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Captured CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 825,336,000 | 862,476,000 | 901,287,000 | 941,845,000 | 984,228,000 | 1,028,518,000 | 1,074,802,000 | 1,123,168,000 | 1,173,710,000 | 1,226,527,000 |
| Operating Expenses | | | | | | | | | | |
| Fuel | 146,048,000 | 152,620,000 | 159,488,000 | 166,664,000 | 174,164,000 | 182,002,000 | 190,192,000 | 198,750,000 | 207,694,000 | 217,040,000 |
| Limestone | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Lime | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Imported Water | 5,860,000 | 6,123,000 | 6,399,000 | 6,687,000 | 6,988,000 | 7,302,000 | 7,631,000 | 7,974,000 | 8,333,000 | 8,708,000 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Activated carbon | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Other | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Inflating O&M | 138,888,000 | 145,138,000 | 151,670,000 | 158,495,000 | 165,627,000 | 173,080,000 | 180,869,000 | 189,008,000 | 197,513,000 | 206,401,000 |
| Book Value O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Constant O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 290,795,000 | 303,881,000 | 317,556,000 | 331,846,000 | 346,779,000 | 362,384,000 | 378,691,000 | 395,732,000 | 413,540,000 | 432,150,000 |
| Operating Income | 534,540,000 | 558,595,000 | 583,731,000 | 609,999,000 | 637,449,000 | 666,134,000 | 696,110,000 | 727,435,000 | 760,170,000 | 794,378,000 |
| -Depreciation | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| -Deductible Interest Exp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Pre-Tax Income | 534,540,000 | 558,595,000 | 583,731,000 | 609,999,000 | 637,449,000 | 666,134,000 | 696,110,000 | 727,435,000 | 760,170,000 | 794,378,000 |
| -Tax | 187,089,000 | 195,508,000 | 204,306,000 | 213,500,000 | 223,107,000 | 233,147,000 | 243,639,000 | 254,602,000 | 266,059,000 | 278,032,000 |
| -Non-Deductible Interest Exp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Net Income | 347,451,000 | 363,086,000 | 379,425,000 | 396,499,000 | 414,342,000 | 432,987,000 | 452,472,000 | 472,833,000 | 494,110,000 | 516,345,000 |
| Debt Principal Payment | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Debt Coverage | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Net Cash Flow | 347,451,000 | 363,086,000 | 379,425,000 | 396,499,000 | 414,342,000 | 432,987,000 | 452,472,000 | 472,833,000 | 494,110,000 | 516,345,000 |
| Cumulative Net Cash Flow | 3,780,037,000 | 4,143,124,000 | 4,522,549,000 | 4,919,049,000 | 5,333,391,000 | 5,766,378,000 | 6,218,850,000 | 6,691,683,000 | 7,185,794,000 | 7,702,139,000 |




- Area 16.79 hectare
 Lx 428 m
 Ly 392 m
- 1 - Boiler
 - 2 - Steam Turbine
 - 4 - Water Treatment
 - 5 - Cooling Tower
 - 6 - Switchyard
 - 7 - Administration, Shop & Warehouse
 - 8 - Fuel Oil Tank
 - 10 - Demineralized Water Tank
 - 11 - Raw Water Tank
 - 12 - Neutralized Water Tank
 - 15 - Road
 - 16 - Parking
 - 21 - Fire Protection Tank
 - 34 - Stack
 - 35 - Coal Storage Area (lx=129, ly=334)
 - 36 - Combustion Waste Storage Area (lx=34, ly=34)
 - 41 - ID Fan
 - 42 - Electrostatic Precipitators
 - 49 - Transformer
 - 51 - Car Dumper
 - 52 - Reclaiming Hopper
 - 53 - Crusher Building

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Site Plan |
| | |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | | | | | | | | | |
|---|---------|---|---|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| - | 18.72 m | - | - | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | BOILER |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | BOILER |
| | ELEVATION VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



SHAPE, DIMENSIONS & SCALE ARE APPROXIMATE

| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|---------|--------|---------|---|---|
| 9.959 m | 13.79 m | 14.45 m | 15.93 m | 58.94 m | 6.605 m | 4.39 m | 7.926 m | - | - |


| | |
|------------------|-----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | STEAM TURBINE PACKAGE |
| | PLAN |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



SHAPE, DIMENSIONS & SCALE ARE APPROXIMATE


| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|--------|---------|---------|---|---|
| 9.959 m | 13.79 m | 14.45 m | 15.93 m | 58.94 m | 5.44 m | 1.566 m | 4.332 m | - | - |

| | |
|------------------|-----------------------|
| Thermostat, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | STEAM TURBINE PACKAGE |
| | ELEV |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| | | | | | | | | | |
|---------|---------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 17.46 m | 15.21 m | 0.7469 m | 1.439 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 1-P |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| | | | | | | | | | |
|---------|--------|---------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 18.72 m | 16.2 m | 0.837 m | 1.617 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 2-D |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



| | | | | | | | | | |
|---------|---------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 20.46 m | 17.98 m | 0.8454 m | 1.584 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 3-D |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |






| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---|---|---|---|---|---|
| 16.59 m | 4.572 m | 2.773 m | 18.24 m | - | - | - | - | - | - |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | STEAM HEATED DEAERATOR |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 11.99 m | 9.058 m | 0.6978 m | 1.773 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 6-D (6A, 6B) |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 13.11 m | 10.04 m | 0.7078 m | 2.002 m | - | - | - | - | - | - |

| | |
|-------------------|----------------------|
| Thermodflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 7-D (7A, 7B) |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 12.49 m | 9.417 m | 0.7237 m | 1.942 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 8-D (8A, 8B) |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| | | | | | | | | | |
|---------|---------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 6.551 m | 2.993 m | 0.7425 m | 1.521 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 9-S (9A, 9B) |
| | PLAN VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |





| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 17.46 m | 15.21 m | 0.7469 m | 1.439 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 1-P |
| | SIDE ELEVATION VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |













| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|---|---|---|---|---|
| 16.59 m | 7.955 m | 2.773 m | 4.572 m | 18.24 m | - | - | - | - | - |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | STEAM HEATED DEAERATOR |
| | ELEVATION VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |











| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 6.551 m | 2.993 m | 0.7425 m | 1.521 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 9-S (9A, 9B) |
| | SIDE ELEVATION VIEW |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | WCC |
| | PLAN |
| Date: 04/11/17 | |
| Drawing No: | |
| | |

| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|--------|---|---|---|---|
| 6.565 m | 10.07 m | 13.32 m | 2.718 m | 8.681 m | 6.95 m | - | - | - | - |




| | |
|----------------|----------------------|
| Thermax, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | WCC |
| | SIDE ELEVATION |
| Date: 04/11/17 | |
| Drawing No: | |
| | |

| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|---------|--------|----------|---|---|
| 19.44 m | 4.077 m | 13.32 m | 2.038 m | 4.309 m | 9.548 m | 6.95 m | 0.8666 m | - | - |



| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|---------|---------|---|---|---|
| 208.8 m | 199.6 m | 9.144 m | 148.2 m | 93.85 m | 52.14 m | 61.11 m | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | ELEVATION |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2070.6 t/h |
| Nameplate head | 3155 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 3170 m |
| Nameplate RPM | 3000 |
| Design flow | 1863.6 t/h |
| Design head | 3331 m |
| Design RPM | 3000 |


| | |
|------------------|-----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Pump (P1) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |

Boiler Feed Booster Pump (P3)




| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2070.6 t/h |
| Nameplate head | 81.81 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 83.82 m |
| Nameplate RPM | 600 |
| Design flow | 1863.6 t/h |
| Design head | 87.01 m |
| Design RPM | 600 |
| Minimum continuous flow | 310.6 t/h |
| Maximum continuous flow | 2795.3 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Booster Pump (P3) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|------------|
| No. per ST | 8 |
| No. operating per ST | 8 |
| Nameplate flow | 7455 t/h |
| Nameplate head | 22.77 m |
| Nameplate flow (nominal) | 124919 lpm |
| Nameplate head (nominal) | 24.38 m |
| Nameplate RPM | 500 |
| Design flow | 6710 t/h |
| Design head | 24.2 m |
| Design RPM | 500 |
| Minimum continuous flow | 1863.8 t/h |
| Maximum continuous flow | 10437 t/h |

| | |
|------------------|--------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Condenser C.W. Pump (P4) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|------------|
| No. per ST | 2 |
| No. operating per ST | 1 |
| Nameplate flow | 1326.2 t/h |
| Nameplate head | 242.4 m |
| Nameplate flow (nominal) | 22712 lpm |
| Nameplate head (nominal) | 243.8 m |
| Nameplate RPM | 1500 |
| Design flow | 1193.6 t/h |
| Design head | 218.1 m |
| Design RPM | 1500 |
| Minimum continuous flow | 198.9 t/h |
| Maximum continuous flow | 1790.4 t/h |

| | |
|------------------|---------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Condensate Forwarding Pump (P6) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | |
|------------------|------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Fuel Oil Unloading Pump (P8) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Fuel Oil Forwarding Pump (P9) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |


Aux Cooling Water Pump (closed loop) (P10)



| | |
|--------------------------|-----------|
| No. per Plant | 2 |
| No. operating per Plant | 1 |
| Nameplate flow | 470.4 t/h |
| Nameplate head | 24.43 m |
| Nameplate flow (nominal) | 8517 lpm |
| Nameplate head (nominal) | 27.43 m |
| Nameplate RPM | 1500 |
| Design flow | 470.4 t/h |
| Design head | 18.32 m |
| Design RPM | 1500 |
| Minimum continuous flow | 94.08 t/h |
| Maximum continuous flow | 564.5 t/h |

| | |
|------------------|--|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Aux Cooling Water Pump (closed loop) (P10) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |






| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 10.25 t/h |
| Nameplate head | 30.54 m |
| Nameplate flow (nominal) | 170.3 lpm |
| Nameplate head (nominal) | 38.1 m |
| Nameplate RPM | 3000 |
| Design flow | 10.25 t/h |
| Design head | 30.54 m |
| Design RPM | 3000 |
| Minimum continuous flow | 2.051 t/h |
| Maximum continuous flow | 12.31 t/h |


| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Jockey Fire Pump (P14) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |

Demin Water Pump (P23)




| | |
|--------------------------|-----------|
| No. per Plant | 2 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.26 t/h |
| Nameplate head | 55.24 m |
| Nameplate flow (nominal) | 378.5 lpm |
| Nameplate head (nominal) | 60.96 m |
| Nameplate RPM | 3000 |
| Design flow | 15.58 t/h |
| Design head | 44.2 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.452 t/h |
| Maximum continuous flow | 26.71 t/h |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Demin Water Pump (P23) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.26 t/h |
| Nameplate head | 46.04 m |
| Nameplate flow (nominal) | 378.5 lpm |
| Nameplate head (nominal) | 53.34 m |
| Nameplate RPM | 3000 |
| Design flow | 15.58 t/h |
| Design head | 34.53 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.452 t/h |
| Maximum continuous flow | 26.71 t/h |


| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Raw Water Pump 1 (P26) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |



| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.26 t/h |
| Nameplate head | 46.04 m |
| Nameplate flow (nominal) | 378.5 lpm |
| Nameplate head (nominal) | 53.34 m |
| Nameplate RPM | 3000 |
| Design flow | 15.58 t/h |
| Design head | 36.83 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.452 t/h |
| Maximum continuous flow | 26.71 t/h |


| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Raw Water Pump 2 (P27) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |

Aux Cooling Water Pump (open loop) (P30)




| | |
|--------------------------|-----------|
| No. per Plant | 2 |
| No. operating per Plant | 1 |
| Nameplate flow | 470.4 t/h |
| Nameplate head | 24.43 m |
| Nameplate flow (nominal) | 8517 lpm |
| Nameplate head (nominal) | 27.43 m |
| Nameplate RPM | 1500 |
| Design flow | 470.4 t/h |
| Design head | 18.32 m |
| Design RPM | 1500 |
| Minimum continuous flow | 94.08 t/h |
| Maximum continuous flow | 564.5 t/h |

| | |
|------------------|--|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Aux Cooling Water Pump (open loop) (P30) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|-----------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 517.7 t/h |
| Nameplate head | 3334 m |
| Nameplate flow (nominal) | 10410 lpm |
| Nameplate head (nominal) | 3353 m |
| Nameplate RPM | 3000 |
| Design flow | 517.7 t/h |
| Design head | 3334 m |
| Design RPM | 3000 |
| Minimum continuous flow | 103.5 t/h |
| Maximum continuous flow | 673 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Startup Boiler Feed Pump (P2) |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|--------------|----------|---------------|----------|
| HPO x 1 | 450.9 mm | 169.5 m | Custom | TP347HFG | 280.1 bar | 606 C | 1863.6 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | HP PIPING |
| | DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|-------------|------------|---------------|----------|
| CRHO x 1 | 717.6 mm | 178.3 m | Custom | P-22 | 64.3 bar | 374.5 C | 1689.2 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | RH PIPING |
| | DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|-------------|------------|---------------|----------|
| HRHO x 1 | 800.1 mm | 187.1 m | Custom | TP347HFG | 61.2 bar | 605.4 C | 1689.2 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | RH PIPING |
| | DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FWHHS1 x 1 | 914.4 | 12.19 | 10 | A-106 | 0.363 | 73.57 | 58.43 | |
| FWHHS2 x 1 | 762 | 24.08 | 10 | A-106 | 1.167 | 113 | 69.06 | |
| FWHHS3 x 1 | 508 | 35.97 | 40 | A-106 | 3.083 | 205.1 | 73.43 | |
| FWHHS4 x 1 | 406.4 | 47.85 | 40 | A-106 | 7 | 296.5 | 77.12 | |
| FWHHS5 x 1 | 406.4 | 101.8 | 40 | A-106 | 13.04 | 375.4 | 74.55 | |
| FWHHS6 x 2 | 203.2 | 41.76 | 40 | P-11 | 22.9 | 454.3 | 31.95 | |
| FWHHS8 x 2 | 203.2 | 53.65 | 60 | P-22 | 64.3 | 374.5 | 64.32 | |
| FWHHS9 x 2 | 203.2 | 59.74 | 60 | P-91 | 42.67 | 549.7 | 59.82 | |
| | mm | m | | | bar | C | t/h | lpm |

| | |
|------------------|---|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH HEATING STEAM PIPING DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-----------|------------|----------|----------|----------|------------|--------------|----------|
| FPTMS1 x 1 | 508 mm | 72.85 m | 40 | A-106 | 7 bar | 296.5 C | 133.4 t/h | lpm |

| | |
|------------------|---|
| Thermostat, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | OTHER HEATING STEAM PIPING DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FW1 x 1 | 457.2 | 39.93 | 20 | A-106 | 21.6 | 40.08 | 1193.6 | 20030 |
| FWF1 x 1 | 457.2 | 19.81 | 20 | A-106 | 19.62 | 69.65 | 1193.6 | 20325 |
| FWF2 x 1 | 508 | 21.34 | 20 | A-106 | 17.71 | 99.84 | 1476.8 | 25665 |
| FWF3 x 1 | 609.6 | 23.17 | 20 | A-106 | 16.18 | 130 | 1476.8 | 26318 |
| FWF4 x 1 | 609.6 | 101.8 | 20 | A-106 | 14.9 | 160.2 | 1476.8 | 27121 |
| FWF5 x 1 | 609.6 | 101.8 | 20 | A-106 | 12.66 | 190.4 | 1863.6 | 35377 |
| FWF6 x 2 | 406.4 | 13.72 | Custom | A-106 | 308 | 220.1 | 931.8 | 17988 |
| FWF7 x 2 | 419.1 | 14.94 | Custom | A-106 | 307.4 | 250.7 | 931.8 | 18809 |
| FWF8 x 2 | 431.8 | 14.33 | Custom | A-106 | 306.8 | 279.9 | 931.8 | 19797 |
| FWF9 x 2 | 431.8 | 7.62 | Custom | A-106 | 306.7 | 287.7 | 931.8 | 20107 |
| FW3 x 1 | 609.6 | 173.4 | Custom | A-106 | 306.7 | 287.7 | 1863.6 | 40215 |
| | mm | m | | | bar | C | t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FEEDWATER PIPING |
| | DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|--------------|----------|----------|----------|----------|
| CW0 x 3 | 1524 | 401.4 | 150psi | Ductile iron | 2.495 | 37.8 | 18050 | 302888 |
| CW1 x 1 | 304.8 | 607.2 | 40 | A-106 | 6.895 | 25 | 470.4 | 7860 |
| CW7 x 1 | 152.4 | 177.1 | 40 | A-106 | 6.895 | 25 | 152.1 | 2541.1 |
| CW8 x 1 | 254 | 177.1 | 40 | A-106 | 6.895 | 25 | 318.3 | 5319 |
| | mm | m | | | bar | C | t/h | lpm |


| | |
|------------------|---------------------------------|
| Thermsflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | COOLING WATER PIPING DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |



| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FP0 x 1 | 508 | 1062.2 | 20 | A-106 | 6.895 | 15 | 1362 | 22712 |
| FP1 x 1 | 406.4 | 1062.2 | 20 | A-106 | 6.895 | 15 | 681 | 11356 |
| | mm | m | | | bar | C | t/h | lpm |

| | |
|------------------|-------------------------------|
| Thermostat, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FIRE PROTECTION PIPING |
| | DIAGRAM |
| Date: 04/11/17 | |
| Drawing No: | |
| | |







| | |
|------------------|----------------------|
| Thermostat, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | WFGD |
| | |
| Date: 04/11/17 | |
| Drawing No: | |
| | |
| | |

NUMBER OF ABSORBER MODULES = 1

| A | B | C | D | E | F | G | H | I |
|---|---|---|---|---|---|---|---|---|
| - | - | - | - | - | - | - | - | - |






Appendix B – PEACE and STEAM PRO Results for the Dry Cooling Case

Plant gross power 678764 kW
 Plant net power 649886 kW
 Number of units 1
 Plant net HR (HHV) 8963 kJ/kWh
 Plant net HR (LHV) 8646 kJ/kWh
 Plant net eff (HHV) 40.16 %
 Plant net eff (LHV) 41.64 %
 Aux. & losses 28878 kW
 Fuel heat input (HHV) 5825 GJ/h
 Fuel heat input (LHV) 5619 GJ/h
 Fuel flow 4832 t/day

Ambient 1 p
 25 T
 60% RH
 19.45 T wet bulb




Double HP Feed Water Heater Train & Single LP Feed Water Heater Train

p [bar] T [C] M [t/h] x [-]

BOILER EFF (HHV/LHV) 89.8% / 93.1%
 NET PLANT EFF (HHV/LHV) 40.2% / 41.6%


NET POWER 649886 kW
 NET PLANT HR (HHV/LHV) 8963 / 8646 kJ/kWh

AUX 28878 kW
 TURBINE HR 7687 kJ/kWh



Fuel chemical LHV input = 1560772 kJ/s
Fuel chemical HHV input = 1618114 kJ/s


Plant Energy Flow Schematic [kJ/s]




Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)

Auxiliaries & Losses [kW]

Total auxiliaries & transformer losses = 28878 kW




Plume not visible




STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
 FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp BOILER SCHEMATIC
 p T m BOILER EFF BOILER FUEL INPUT (kJ/s)
 bar C t/h 89.8 % (HHV) 93.1 % (LHV) 1618114(HHV) 1560772(LHV)


Boiler - TQ Diagram




ECO1 - TQ Diagram




CS1 - TQ Diagram




CS2 - TQ Diagram




CR1 - TQ Diagram




CR2 - TQ Diagram




Furnace - TQ Diagram




Rotary Air Heater - TQ Diagram



Expansion power 686393 kW
 Mechanical loss 1716 kW
 Generator loss 5913 kW
 Generator power 678764 kW





p [bar] T [C] h [kJ/kg] M [t/h] x [-]




p [bar] T [C] h [kJ/kg] M [t/h] x [-]

Steam Turbine Exhaust Loss






p [bar] T [C] M [t/h] x [-]




Double HP Feed Water Heater Train & Single LP Feed Water Heater Train




p [bar] T [C] h [kJ/kg] M [t/h] Q [kJ/s] x [-]

FWH System T-Q Diagram




 STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
 FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp
 p T m Q A
 bar C t/h kJ/s m²


FWH 1 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 2 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 3 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 4 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 5 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 6 T-Q Diagram



FWH 6
26522 Q
1336.1 A

Steam: 32.89 m, 22.24 p, 452.9 Tin, 202.4 Tex
Water: 959.2 m, 308.7 p, 197.4 Tin, 220.1 Tex


FWH 7 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 8 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


FWH 9 T-Q Diagram



STEAM PRO 26.1 GHD 588 04-21-2017 16:19:10 Steam Properties: IFC-67
FILE: G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp

| p | T | m | Q | A |
|-----|---|-----|------|----------------|
| bar | C | t/h | kJ/s | m ² |


| | | |
|--------------------------|--------|------|
| Condenser heat rejection | 763268 | kJ/s |
| Condensate pump power | 1096.9 | kW |
| Fan power | 7014 | kW |



p [bar] T [C] h [kJ/kg] M [t/h] x [-]


Psychrometric Chart

AIR STATES:
A) Ambient or Inlet:
 Pressure = 1 bar
 Dry bulb = 25 C
 Wet bulb = 19.45 C
 RH = 60 %
E) Air Exit:
 Dry bulb = 40.56 C
 Wet bulb = 23.94 C
 RH = 25.01 %
 Plume invisible
 (Plume Visibility index = 0.00)




| | |
|------------------|--------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Dry air-cooled condenser |
| Date: 04/21/17 | |
| Drawing No: | |
| | |

Dry air-cooled condenser - TQ Diagram




Plant Energy In [kJ/s]

Plant energy in = 1658743 kJ/s
Plant fuel chemical LHV input = 1560772 kJ/s, HHV = 1618114 kJ/s



Plant Energy Out [kJ/s]


Plant energy out = 1658748 kJ/s



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)


Boiler Energy In [kJ/s]

Boiler energy in = 1665318 kJ/s
Plant fuel chemical LHV input = 1560772 kJ/s, HHV = 1618114 kJ/s



Boiler Energy Out [kJ/s]


Boiler energy out = 1665323 kJ/s



Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)


Steam Cycle Energy In [kJ/s]

Steam cycle energy in = 1478941 kJ/s




Steam Cycle Energy Out [kJ/s]

Steam cycle energy out = 1478941 kJ/s




Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K)




| | |
|------------------|-----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Pump (P1) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |

Boiler Feed Booster Pump (P3)



| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2131.5 t/h |
| Nameplate head | 81.81 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 83.82 m |
| Nameplate RPM | 600 |
| Design flow | 1918.4 t/h |
| Design head | 87.01 m |
| Design RPM | 600 |
| Minimum continuous flow | 319.7 t/h |
| Maximum continuous flow | 2877.6 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Booster Pump (P3) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |



| | |
|--------------------------|------------|
| No. per ST | 2 |
| No. operating per ST | 1 |
| Nameplate flow | 1383.9 t/h |
| Nameplate head | 237.6 m |
| Nameplate flow (nominal) | 24605 lpm |
| Nameplate head (nominal) | 243.8 m |
| Nameplate RPM | 750 |
| Design flow | 1245.5 t/h |
| Design head | 213.9 m |
| Design RPM | 750 |
| Minimum continuous flow | 207.6 t/h |
| Maximum continuous flow | 1868.2 t/h |

| | |
|------------------|---------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Condensate Forwarding Pump (P6) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |

STEAM PRO 26.1 GHD GHD Pty Ltd
 588 04-21-2017 16:19:10 G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp
 Program revision date: February 16, 2017
 Steam source: Conventional boiler
 Steam turbine: Single reheat condensing turbine 3000+3000/3000
 Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train
 Cooling system: Dry air cooled condenser
 Steam Property Formulation: IFC-67

| SYSTEM SUMMARY | | | | | | |
|--------------------|-------------------|---------------|-------------------|----------------|--------------|-------------|
| | Power Output (kW) | | Fuel Input (kJ/s) | | Fuel Flows | |
| | Gross | Net | LHV | HHV | t/h | t/day |
| Plant Total | 678764 | 649886 | 1560773 | 1618114 | 201.4 | 4832 |

| | | |
|---|---|------|
| Number of units = | 1 | |
| Net process heat output = | 0 | kJ/s |
| as % of total output (net elec. + net heat) = | 0 | % |

| PLANT EFFICIENCY AND HEAT RATE | | | | | | | |
|--------------------------------|--------------|--------------|--------------|--------------|---------------------|--------------|---------------|
| | LHV* | | HHV* | | Boiler Heat Input** | | |
| | Gross | Net | Gross | Net | Gross | Net | |
| Heat rate | 8278 | 8646 | 8582 | 8963 | 8278 | 8646 | kJ/kWh |
| Electric efficiency | 43.49 | 41.64 | 41.95 | 40.16 | 43.49 | 41.64 | % |
| CHP (Total) efficiency | | 41.64 | | 40.16 | | 41.64 | % |
| U.S. PURPA efficiency | | 41.64 | | 40.16 | | 41.64 | % |

* Heat input is based on fuel chemical energy, LHV or HHV, at 77 F/25 C
 ** Boiler heat input includes fuel chemical LHV energy at 77 F/ 25 C, plus enthalpy of supply air (gas) in excess of ambient temperature.
 Total heat input (LHV adjusted) = 1560772 kJ/s
 Fuel input to boiler (LHV adjusted) = 1560768 kJ/s.

| STEAM CYCLE/BOILER PERFORMANCE | |
|---------------------------------------|--------------------|
| Steam cycle heat rate | 7706 kJ/kWh |
| Steam cycle efficiency | 46.72 % |
| Turbine heat rate | 7687 kJ/kWh |
| Boiler LHV adjusted efficiency | 93.09 % |
| Boiler HHV adjusted efficiency | 89.79 % |

| ESTIMATED PLANT AUXILIARIES | | |
|---|----------------|-----------|
| Boiler primary air fan* | 1436.7 | kW |
| Boiler secondary air fan* | 1924.1 | kW |
| Boiler induced draft fan* | 2668.7 | kW |
| Boiler fuel delivery* | 4439.1 | kW |
| Boiler forced circulation pump | 0.0 | kW |
| Electrostatic precipitator (ESP) | 1613.1 | kW |
| Ash handling | 856.5 | kW |
| Condenser cooling water pump | 0.0 | kW |
| Air cooled condenser fan | 7013.7 | kW |
| Condensate pump* | 1096.9 | kW |
| Contact heater feed forward pump(s)* | 0.0 | kW |
| Boiler feed pump* | 0.0 | kW |
| Boiler feed booster pump* | 583.9 | kW |
| FW heater drain pump(s)* | 205.9 | kW |
| Aux. from PEACE running motor/load list | 3289.0 | kW |
| Miscellaneous ST auxiliaries | 356.4 | kW |
| Miscellaneous plant auxiliaries | 1696.9 | kW |
| Constant plant auxiliary load | 0.0 | kW |
| Program estimated overall plant auxiliaries | 27180.7 | kW |
| Actual (user input) overall plant auxiliaries | 27180.7 | kW |
| Transformer losses | 1696.9 | kW |
| Total auxiliaries & transformer losses | 28877.7 | kW |
| * Heat balance related auxiliaries | | |

| PLANT HEAT BALANCE | | |
|---|----------------|------------------|
| Energy In | 1658743 | kW |
| Ambient air sensible | 17421 | kW |
| Ambient air latent | 20369 | kW |
| Fuel enthalpy @ supply | 1620953 | kW |
| External steam | 0 | kW |
| External water | 0 | kW |
| Makeup, process return, and blowdown recovery | 0 | kW |
| FGD water | 0 | kW |
| FGD oxidation air | 0 | kW |
| CO2 capture makeup water | 0 | kW |
| Condensate external heating or cooling | 0 | kW |
| Energy Out | 1658748 | kW |
| Net power output | 649886 | kW |
| Stack gas sensible | 107425 | kW |
| Stack gas latent | 79118 | kW |
| Bottom ash | 1404.6 | kW |
| Fly ash | 399.3 | kW |
| Unburned carbon | 4669 | kW |
| Boiler minor loss | 21794 | kW |
| Fuel delivery energy loss | 887.8 | kW |
| Main condenser | 763268 | kW |
| BFPT condenser | 0 | kW |
| Process steam | 0 | kW |
| Process water | 0 | kW |
| District heat | 0 | kW |
| Discharged seal steam | 0 | kW |
| Blowdown | 0 | kW |
| Steam pipe losses | 4015 | kW |
| ST/generator mech/elec/gear loss | 7629 | kW |
| BFPT mech loss | 243.8 | kW |
| Pumps mech/elec loss | 882.8 | kW |
| Fans mech/elec loss | 602.9 | kW |
| ESP heat loss | 0 | kW |
| FGD energy loss | 0 | kW |
| CO2 capture energy loss | 0 | kW |
| Desal heat | 0 | kW |
| Non-heat balance related auxiliaries | 16523 | kW |
| Other | 0 | kW |
| Energy In - Energy Out | -5.143 | kW |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | -0.0003 % |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|---|----------|--------|------------|----------|----------------|
| Note: This is a fixed format table. Not all streams are applicable to current heat balance. | | | | | H2O: ref @ 32F |
| Zero enthalpy: steam & liquid water at 32 F (273.15 K). | | | | | |
| 1 Feedwater into boiler | 306.7 | 287.7 | 1266.98 | 1918.37 | - |
| 2 Feedwater leaving grate cooling HX | 306.7 | 287.7 | 1266.98 | 1918.37 | - |
| 3 Water leaving 1st economiser | 303.7 | 343.5 | 1568.27 | 1918.37 | - |
| 4 Water entering 2nd economiser | 303.7 | 343.5 | 1568.27 | 1918.37 | - |
| 5 Water leaving 2nd economiser | 303.7 | 343.5 | 1568.27 | 1918.37 | - |
| 6 Boiler blowdown | - | - | - | - | - |
| 7 Steam leaving CEV | - | - | - | - | - |
| 8 Steam leaving REV | 288.5 | 427.6 | 2690.99 | 1918.37 | - |
| 9 Steam leaving CEV+REV | 288.5 | 427.6 | 2690.99 | 1918.37 | - |
| 10 1st superheater inlet | 288.5 | 427.6 | 2690.99 | 1918.37 | - |
| 11 1st superheater exit | 285.9 | 462.5 | 2934.53 | 1918.37 | - |
| 12 2nd superheater inlet | 285.9 | 462.5 | 2934.53 | 1918.37 | - |
| 13 2nd superheater exit | 282.7 | 532.3 | 3236.35 | 1918.37 | - |
| 14 3rd superheater inlet | 282.7 | 532.3 | 3236.35 | 1918.37 | - |
| 15 3rd superheater exit | 280.1 | 606.0 | 3479.90 | 1918.37 | - |
| 16 4th superheater inlet | 280.1 | 606.0 | 3479.90 | 1918.37 | - |
| 17 4th superheater exit | 280.1 | 606.0 | 3479.90 | 1918.37 | - |
| 18 Steam leaving superheater | 280.1 | 606.0 | 3479.89 | 1918.37 | - |
| 19 Cold reheat after pipe | 63.04 | 372.6 | 3101.52 | 1740.25 | - |
| 20 Mixing cold reheat with steam add. | 63.04 | 372.6 | 3101.52 | 1740.25 | - |
| 21 1st reheater inlet | 63.04 | 372.6 | 3101.52 | 1740.25 | - |
| 22 1st reheater exit | 62.12 | 485.2 | 3384.59 | 1740.25 | - |
| 23 2nd reheater inlet | 62.12 | 485.2 | 3384.59 | 1740.25 | - |
| 24 2nd reheater exit | 62.12 | 485.2 | 3384.59 | 1740.25 | - |
| 25 3rd reheater inlet | 62.12 | 485.2 | 3384.59 | 1740.25 | - |
| 26 3rd reheater exit | 61.2 | 605.4 | 3667.67 | 1740.25 | - |
| 27 4th reheater inlet | 61.2 | 605.4 | 3667.67 | 1740.25 | - |
| 28 4th reheater exit | 61.2 | 605.4 | 3667.67 | 1740.25 | - |
| 29 Steam leaving reheater | 61.2 | 605.4 | 3667.67 | 1740.25 | - |
| 30 Cold LP reheat after pipe | - | - | - | - | - |
| 31 Mixing cold LP reheat with steam add. | - | - | - | - | - |
| 32 1st LP reheater inlet | - | - | - | - | - |
| 33 1st LP reheater exit | - | - | - | - | - |
| 34 2nd LP reheater inlet | - | - | - | - | - |
| 35 2nd LP reheater exit | - | - | - | - | - |
| 36 3rd LP reheater inlet | - | - | - | - | - |
| 37 3rd LP reheater exit | - | - | - | - | - |
| 38 4th LP reheater inlet | - | - | - | - | - |
| 39 4th LP reheater exit | - | - | - | - | - |
| 40 Steam leaving LP reheater | - | - | - | - | - |
| 41 HPT inlet, before stop valves | 276 | 604.0 | 3477.57 | 1918.37 | 6.306 |
| 42 HPT inlet, after stop valves | 269.1 | 601.9 | 3477.57 | 1886.48 | - |
| 43 HPT exit | 64.3 | 374.5 | 3103.85 | 1740.25 | 6.402 |
| 44 PIPT inlet, before intercept valve | - | - | - | - | - |
| 45 PIPT exit | - | - | - | - | - |
| 46 IPT inlet, before intercept valve | 60 | 604.0 | 3665.34 | 1740.25 | 7.177 |
| 47 IPT bowl | 58.8 | 602.2 | 3662.10 | 1770.75 | 7.182 |
| 48 LPT crossover | 7 | 296.7 | 3052.60 | 1293.18 | 7.287 |
| 49 LPT exhaust | 0.1181 | 49.1 | 2397.86 | 1096.99 | 7.495 |
| 50 ST group 1 inlet | 269.1 | 601.9 | 3477.57 | 1886.48 | 6.317 |
| 51 ST group 1 blading exit | 212.3 | 562.3 | 3416.45 | 1886.48 | 6.34 |
| 52 ST group 1 addition / extraction | - | - | - | - | - |
| 53 ST group 2 inlet | 212.3 | 562.3 | 3416.45 | 1886.48 | 6.34 |
| 54 ST group 2 blading exit | 64.3 | 374.5 | 3103.85 | 1886.48 | 6.402 |
| 55 ST group 2 addition / extraction | 64.3 | 374.5 | 3103.85 | -132.43 | 6.402 |
| 56 ST group 3 inlet | 58.8 | 602.2 | 3662.10 | 1770.75 | 7.182 |
| 57 ST group 3 blading exit | 42.67 | 549.8 | 3555.30 | 1770.75 | 7.2 |
| 58 ST group 3 addition / extraction | 42.67 | 549.8 | 3555.30 | -123.16 | 7.2 |
| 59 ST group 4 inlet | 42.67 | 549.8 | 3555.30 | 1647.59 | 7.2 |
| 60 ST group 4 blading exit | 22.9 | 454.3 | 3363.31 | 1647.59 | 7.232 |
| 61 ST group 4 addition / extraction | 22.9 | 454.3 | 3363.31 | -65.78 | 7.232 |
| 62 ST group 5 inlet | 22.9 | 454.3 | 3363.31 | 1581.81 | 7.232 |
| 63 ST group 5 blading exit | 13.04 | 375.4 | 3206.92 | 1581.81 | 7.259 |
| 64 ST group 5 addition / extraction | 13.04 | 375.4 | 3206.92 | -76.74 | 7.259 |
| 65 ST group 6 inlet | 13.04 | 375.4 | 3206.92 | 1505.07 | 7.259 |
| 66 ST group 6 blading exit | 7 | 296.5 | 3052.14 | 1505.07 | 7.286 |
| 67 ST group 6 addition / extraction | 7 | 296.5 | 3052.14 | -220.68 | 7.286 |
| 68 ST group 7 inlet | 7 | 296.7 | 3052.60 | 1293.18 | 7.287 |
| 69 ST group 7 blading exit | 3.309 | 212.4 | 2889.47 | 1293.18 | 7.317 |
| 70 ST group 7 addition / extraction | 3.309 | 212.4 | 2889.47 | -70.11 | 7.317 |
| 71 ST group 8 inlet | 3.309 | 212.4 | 2889.47 | 1223.07 | 7.317 |
| 72 ST group 8 blading exit | 1.38 | 127.6 | 2727.87 | 1223.07 | 7.349 |
| 73 ST group 8 addition / extraction | 1.38 | 127.6 | 2727.87 | -66.09 | 7.349 |
| 74 ST group 9 inlet | 1.38 | 127.6 | 2727.87 | 1156.98 | 7.349 |
| 75 ST group 9 blading exit | 0.4907 | 80.9 | 2568.49 | 1156.98 | 7.384 |
| 76 ST group 9 addition / extraction | 0.4907 | 80.9 | 2568.49 | -59.99 | 7.384 |
| 77 ST group 10 inlet | 0.4907 | 80.9 | 2568.49 | 1096.99 | 7.384 |
| 78 ST group 10 blading exit | 0.1181 | 49.1 | 2381.26 | 1096.99 | 7.443 |
| 79 ST group 10 addition / extraction | 0.1181 | 49.1 | 2397.86 | 1096.99 | 7.495 |
| 80 ST group 11 inlet | - | - | - | - | - |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|--|----------|--------|------------|----------|--------------|
| 81 ST_group 11 blading exit | - | - | - | - | - |
| 82 ST_group 11 addition / extraction | - | - | - | - | - |
| 83 ST_group 12 inlet | - | - | - | - | - |
| 84 ST_group 12 blading exit | - | - | - | - | - |
| 85 ST_group 12 addition / extraction | - | - | - | - | - |
| 86 ST_group 13 inlet | - | - | - | - | - |
| 87 ST_group 13 addition / extraction | - | - | - | - | - |
| 88 ST_group 13 blading exit | - | - | - | - | - |
| 89 ST_group 14 inlet | - | - | - | - | - |
| 90 ST_group 14 blading exit | - | - | - | - | - |
| 91 ST_group 14 addition / extraction | - | - | - | - | - |
| 92 ST_group 15 inlet | - | - | - | - | - |
| 93 ST_group 15 blading exit | - | - | - | - | - |
| 94 ST_group 15 addition / extraction | - | - | - | - | - |
| 95 ST_group 16 inlet | - | - | - | - | - |
| 96 ST_group 16 addition / extraction | - | - | - | - | - |
| 97 ST_group 16 blading exit | - | - | - | - | - |
| 98 ST_group 17 inlet | - | - | - | - | - |
| 99 ST_group 17 blading exit | - | - | - | - | - |
| 100 ST_group 17 addition / extraction | - | - | - | - | - |
| 101 ST_group 18 inlet | - | - | - | - | - |
| 102 ST_group 18 blading exit | - | - | - | - | - |
| 103 ST_group 18 addition / extraction | - | - | - | - | - |
| 104 ST_group 19 inlet | - | - | - | - | - |
| 105 ST_group 19 blading exit | - | - | - | - | - |
| 106 ST_group 19 addition / extraction | - | - | - | - | - |
| 107 FW into condensate pump | 0.4064 | 47.2 | 197.63 | 1245.47 | - |
| 108 FW after condensate pump | 21.15 | 47.5 | 200.60 | 1245.47 | - |
| 109 FW after recovery HXs before 1st FWH | 21.15 | 47.8 | 202.01 | 1245.47 | - |
| 110 FW before booster pump | 14.9 | 190.4 | 809.24 | 1918.37 | - |
| 111 FW after booster pump | 22.38 | 190.5 | 810.26 | 1918.37 | - |
| 112 FW into boiler feed pump | 22.38 | 190.5 | 810.26 | 1918.37 | - |
| 113 FW after boiler feed pump | 308.7 | 197.4 | 854.14 | 1918.37 | - |
| 114 FWH1 heating steam | 0.4673 | 79.7 | 2566.17 | 59.99 | - |
| 115 FWH1 feedwater inlet | 21.15 | 47.8 | 202.01 | 1245.47 | - |
| 116 FWH1 feedwater exit | 19.34 | 76.9 | 323.38 | 1245.47 | - |
| 117 FWH1 drain | 0.4673 | 79.7 | 333.52 | 274.79 | - |
| 118 FWH2 heating steam | 1.314 | 126.2 | 2725.54 | 66.09 | - |
| 119 FWH2 feedwater inlet | 19.34 | 77.4 | 325.65 | 1520.26 | - |
| 120 FWH2 feedwater exit | 17.59 | 104.7 | 439.96 | 1520.26 | - |
| 121 FWH2 drain | 1.314 | 82.4 | 345.20 | 209.58 | - |
| 122 FWH3 heating steam | 3.151 | 210.9 | 2887.15 | 70.11 | - |
| 123 FWH3 feedwater inlet | 17.59 | 104.7 | 439.96 | 1520.26 | - |
| 124 FWH3 feedwater exit | 16.14 | 132.4 | 557.60 | 1520.26 | - |
| 125 FWH3 drain | 3.151 | 109.7 | 460.02 | 143.49 | - |
| 126 FWH4 heating steam | 6.667 | 294.9 | 3049.82 | 73.38 | - |
| 127 FWH4 feedwater inlet | 16.14 | 132.4 | 557.60 | 1520.26 | - |
| 128 FWH4 feedwater exit | 14.9 | 160.2 | 676.90 | 1520.26 | - |
| 129 FWH4 drain | 6.667 | 137.4 | 578.33 | 73.38 | - |
| 130 FWH5 heating steam | 12.66 | 374.0 | 3204.60 | 76.74 | - |
| 131 FWH5 feedwater inlet | 12.66 | 160.3 | 676.90 | 1520.26 | - |
| 132 FWH5 feedwater exit | 12.66 | 190.4 | 809.24 | 1520.26 | - |
| 133 FWH5 drain | 12.66 | 190.4 | 809.24 | 398.11 | - |
| 134 FWH6 heating steam | 22.24 | 452.9 | 3360.99 | 65.78 | - |
| 135 FWH6 feedwater inlet | 308.7 | 197.4 | 854.14 | 1918.37 | - |
| 136 FWH6 feedwater exit | 308 | 220.1 | 953.68 | 1918.37 | - |
| 137 FWH6 drain | 22.24 | 202.4 | 863.27 | 321.37 | - |
| 138 FWH7 heating steam | 41.42 | 302.4 | 2963.86 | 123.16 | - |
| 139 FWH7 feedwater inlet | 308 | 220.1 | 953.68 | 1918.37 | - |
| 140 FWH7 feedwater exit | 307.4 | 250.7 | 1091.94 | 1918.37 | - |
| 141 FWH7 drain | 41.42 | 225.1 | 967.53 | 255.59 | - |
| 142 FWH8 heating steam | 62.42 | 372.1 | 3101.52 | 132.43 | - |
| 143 FWH8 feedwater inlet | 307.4 | 250.7 | 1091.94 | 1918.37 | - |
| 144 FWH8 feedwater exit | 306.8 | 279.9 | 1229.16 | 1918.37 | - |
| 145 FWH8 drain | 62.42 | 255.7 | 1113.67 | 132.43 | - |
| 146 FWH9 heating steam | 41.42 | 548.2 | 3552.98 | 123.16 | - |
| 147 FWH9 feedwater inlet | 306.8 | 279.9 | 1229.16 | 1918.37 | - |
| 148 FWH9 feedwater exit | 306.7 | 287.7 | 1266.98 | 1918.37 | - |
| 149 FWH9 drain | 41.42 | 302.4 | 2963.86 | 123.16 | - |
| 150 FWH10 heating steam | - | - | - | - | - |
| 151 FWH10 feedwater inlet | - | - | - | - | - |
| 152 FWH10 feedwater exit | - | - | - | - | - |
| 153 FWH10 drain | - | - | - | - | - |
| 154 FWH11 heating steam | - | - | - | - | - |
| 155 FWH11 feedwater inlet | - | - | - | - | - |
| 156 FWH11 feedwater exit | - | - | - | - | - |
| 157 FWH11 drain | - | - | - | - | - |
| 158 FWH12 heating steam | - | - | - | - | - |
| 159 FWH12 feedwater inlet | - | - | - | - | - |
| 160 FWH12 feedwater exit | - | - | - | - | - |
| 161 FWH12 drain | - | - | - | - | - |
| 162 Condenser inlet steam | 0.1073 | 47.2 | 2403.81 | 1245.47 | 7.554 |
| 163 Condenser condensate exit | 0.4064 | 47.2 | 197.63 | 1245.47 | - |
| 164 Condenser CW inlet | - | - | - | - | - |

| STEAM PRO Streams | P bar | T C | h kJ/kg | M t/h | s kJ/kg-C |
|---|----------|--------|------------|----------|--------------|
| 165 Condenser CW exit | - | - | - | - | - |
| 166 CW into cooling tower | - | - | - | - | - |
| 167 CW leaving cooling tower basin | - | - | - | - | - |
| 168 CW after circulation pump | - | - | - | - | - |
| 169 FPT inlet before valve | 6.667 | 294.9 | 3049.82 | 147.30 | 7.304 |
| 170 FPT 1st group inlet | 5.333 | 293.3 | 3049.82 | 147.30 | 7.406 |
| 171 FPT extraction 1 | 0.1073 | 47.2 | 2453.93 | 147.30 | 7.71 |
| 172 FPT 2nd group inlet | - | - | - | - | - |
| 173 FPT extraction 2 | - | - | - | - | - |
| 174 FPT 3rd group inlet | - | - | - | - | - |
| 175 FPT extraction 3 | - | - | - | - | - |
| 176 FPT condenser condensate exit | - | - | - | - | - |
| 177 FPT condenser CW inlet | - | - | - | - | - |
| 178 FPT condenser CW exit | - | - | - | - | - |
| 179 External steam source 1 | - | - | - | - | - |
| 180 External steam source 2 | - | - | - | - | - |
| 181 Process stream 1 | - | - | - | - | - |
| 182 Process stream 2 | - | - | - | - | - |
| 183 Process stream 3 | - | - | - | - | - |
| 184 Process stream 4 | - | - | - | - | - |
| 185 Process stream 5 | - | - | - | - | - |
| 186 Steam addition 1 | - | - | - | - | - |
| 187 Steam addition 2 | - | - | - | - | - |
| 188 Steam addition 3 | - | - | - | - | - |
| 189 Water extraction 1 | - | - | - | - | - |
| 190 Water extraction 2 | - | - | - | - | - |
| 191 Water extraction 3 | - | - | - | - | - |
| 192 Water addition 1 | - | - | - | - | - |
| 193 Water addition 2 | - | - | - | - | - |
| 194 Water addition 3 | - | - | - | - | - |
| 195 DHW return | - | - | - | - | - |
| 196 DHTR1 heating steam | - | - | - | - | - |
| 197 DHTR1 DHW inlet | - | - | - | - | - |
| 198 DHTR1 DHW exit | - | - | - | - | - |
| 199 DHTR1 drain | - | - | - | - | - |
| 200 DHTR2 heating steam | - | - | - | - | - |
| 201 DHTR2 DHW inlet | - | - | - | - | - |
| 202 DHTR2 DHW exit | - | - | - | - | - |
| 203 DHTR2 drain | - | - | - | - | - |
| 204 SSR inlet steam | 1.241 | 344.4 | 3163.56 | 6.40 | 8.267 |
| 205 GSC inlet steam | 0.8274 | 344.0 | 3163.56 | 0.63 | - |
| 206 SAH1 heating steam | - | - | - | - | - |
| 207 SAH1 drain | - | - | - | - | - |
| 208 SAH2 heating steam | - | - | - | - | - |
| 209 SAH2 drain | - | - | - | - | - |
| 210 Fuel heater heating stream | - | - | - | - | - |
| 211 Fuel heater drain | - | - | - | - | - |
| 212 CO2 capture first steam after pipe | - | - | - | - | - |
| 213 CO2 capture first condensate after pump | - | - | - | - | - |
| 214 CO2 capture second steam after pipe | - | - | - | - | - |
| 215 CO2 capture second condensate after pump | - | - | - | - | - |
| 216 CO2 capture CW inlet | - | - | - | - | - |
| 217 CO2 capture CW exit | - | - | - | - | - |
| 218 Total desalinated water from desalination plant | - | - | - | - | - |
| 219 Desalinated water from MSF plant | - | - | - | - | - |
| 220 MSF plant heating steam before pipe | - | - | - | - | - |
| 221 MSF plant heating steam after pipe | - | - | - | - | - |
| 222 MSF plant vacuum steam | - | - | - | - | - |
| 223 MSF plant condensate return | - | - | - | - | - |
| 224 Seawater supply to MSF plant | - | - | - | - | - |
| 225 Seawater discharge from MSF plant | - | - | - | - | - |
| 226 Brine discharge from MSF plant | - | - | - | - | - |
| 227 Desalinated water from RO plant | - | - | - | - | - |
| 228 Seawater supply to RO plant | - | - | - | - | - |
| 229 Brine discharge from RO plant | - | - | - | - | - |

| Warning Messages | |
|-------------------|---|
| | No warning messages |
| Advisory Messages | |
| | No advisory messages |
| Remarks | |
| 1. | FWH 6 exit water temperature has been cut-off at minimum pinch of 1.667 C. Desired = 220.6 C, Actual = 220.1 C |
| 2. | FWH 8 exit water temperature has been cut-off at minimum pinch of 1.667 C. Desired = 280.9 C, Actual = 279.9 C |
| 3. | CS2: The user-defined water-side pressure drop (0.9264 % or 2.595 bar) is much higher than the pressure drop determined by the HX hardware (0.0834 % or 0.2338 bar). The water-side pressure drop correction factor which will be used for off-design has been set to the maximum value (1.922). When converted to off-design, your computed pressure drop may be lower than the present value. |

| STEAM PRO 26.1 GHD GHD Pty Ltd | | | | | | |
|---|---|-------------------------|-----------------------------------|---------------------------|-------------------------|------------------------|
| 588 04-21-2017 16:19:10 G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp | | | | | | |
| Program revision date: February 16, 2017 | | | | | | |
| Steam source: Conventional boiler | | | | | | |
| Steam turbine: Single reheat condensing turbine 3000+3000/3000 | | | | | | |
| Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train | | | | | | |
| Cooling system: Dry air cooled condenser | | | | | | |
| Steam Property Formulation: IFC-67 | | | | | | |
| BOILER HEAT BALANCE | | | | | | |
| Energy in = | 1665319 | kJ/s | | | | |
| Fuel enthalpy to boiler | Heat from Steam/Water Air Heater | Sorbent Sensible | Energy Gain from Sulfation | Inlet Air Sensible | Inlet Air Latent | Other* |
| 1620953 | 0 | 0 | 0 | 17421 | 20369 | 6576 |
| Energy out = | 1665323 | kJ/s | | | | |
| Water & Steam | Bottom Ash Sensible | Fly Ash Sensible | Calcination of Sorbent | Exhaust Gas | Minor Losses | Unburned Carbon |
| 1452916 | 1405 | 399 | 0 | 184140 | 21794 | 4669 |
| * 'Others' includes energy of fan (excluding ID fan) and fuel delivery power. | | | | | | |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | | | | | |
| Heat Balance Error (In - Out) = | -4.4 | kJ/s | = | -0.0003 | % | |

| BOILER AIR/GAS ZONE SUMMARY | | | | | | | | | | | | | |
|-----------------------------|-----------|--------|-----------------|-----------|----------|-------|-------|-------|----------------------|------|------|------|--------------------------|
| Zone | Name | T C | Dp millibar | Q kJ/s | M t/h | M.W. | N2 | O2 | Mole Composition [%] | | | | Ash t/h |
| | | | | | | | | | CO2 | H2O | Ar | SO2 | |
| | | 25.0 | | | 2084.3 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| 1 | FD Fan | 27.9 | 30.517 | 1732 | 2084.3 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | 25 | | | | | | | | | | | |
| 3 | PA Fan | 37.06 | 129.506 | 1293 | 379.2 | | | | | | | | |
| | | | | | -173.7 | | | | | | | | Pulverizer tempering air |
| | | | | | | | | | | | | | |
| | | | | | -17.86 | | | | | | | | Cold end leakage |
| 3 | PA Heater | 37.06 | 4.873 | 7747 | | | | | | | | | |
| | | 182.2 | | | 187.6 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | | | -8.932 | | | | | | | | Hot end leakage |
| | | | | | 173.7 | | | | | | | | Pulverizer tempering air |
| | | | | | | | | | | | | | |
| | | | | | -132.6 | | | | | | | | Cold end leakage |
| 3 | SA Heater | 27.94 | 6.212 | 137411 | | | | | | | | | |
| | | 273.9 | | | 1951.7 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | | | -56.85 | | | | | | | | Hot end leakage |
| | | | | | | | | | | | | | |
| 4 | Burner | 248.6 | 12.463 | 1560773 | 2247.2 | 28.76 | 76.60 | 20.55 | 0.03 | 1.90 | 0.92 | 0.00 | |
| | | | Adiabatic flame | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 19.43 |
| | | | | | | | | | | | | | |
| 5 | Furnace | | 0.000 | 778790 | | | | | | | | | |
| | | 1176.7 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |
| | | | | | | | | | | | | | |
| 7 | CS2 | 1176.7 | 0.129 | 123422 | | | | | | | | | |
| | | 1036.3 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |
| | | | | | | | | | | | | | |
| 8 | CR2 | 1036.3 | 0.176 | 138893 | | | | | | | | | |
| | | 875.1 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |
| | | | | | | | | | | | | | |
| 10 | CS1 | 875.1 | 0.247 | 131731 | | | | | | | | | |
| | | 718.5 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |
| | | | | | | | | | | | | | |
| 11 | CR1 | 718.5 | 0.572 | 138893 | | | | | | | | | |
| | | 548.0 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |
| | | | | | | | | | | | | | |
| 14 | ECO1 | 548.0 | 0.699 | 162962 | | | | | | | | | |
| | | 338.4 | | | 2429.1 | 29.84 | 73.65 | 3.29 | 14.55 | 7.59 | 0.89 | 0.04 | 15.54 |

| | | | | | | | | | | | | | |
|--|--------------------------|-------|--------|---------|--------|----------------------------|-------|------|-------|------|------|------|-------|
| | | | | | 56.85 | Secondary air hot leakage | | | | | | | |
| | | | | | 8.932 | Primary air hot leakage | | | | | | | |
| | | 336.5 | | | | | | | | | | | |
| 16 | Air Heater (gas side) | 144.1 | 9.111 | -145157 | | | | | | | | | |
| | | | | | 2494.9 | 29.81 | 73.73 | 3.76 | 14.15 | 7.43 | 0.89 | 0.04 | 15.54 |
| | | | | | 132.6 | Secondary air cold leakage | | | | | | | |
| | | | | | 17.86 | Primary air cold leakage | | | | | | | |
| | | 137.8 | | | | | | | | | | | |
| 19 | ESP | 137.8 | 8.101 | 0 | | | | | | | | | |
| | | | | | 2645.4 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 137.8 | | | | | | | | | | | |
| 20 | ID Fan | 140.9 | 24.303 | 2402 | | | | | | | | | |
| | | | | | 2645.4 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 140.9 | | | | | | | | | | | |
| 30 | STK | 140.9 | -2.832 | 0 | | | | | | | | | |
| | | | | | 2645.4 | 29.74 | 73.90 | 4.75 | 13.32 | 7.11 | 0.89 | 0.04 | 0.08 |
| | | 140.9 | | | | | | | | | | | |
| Excess Air = | | | | | 20 | % | | | | | | | |
| Adiabatic flame temperature is greater than | | | | | 1093.3 | C | | | | | | | |
| Miscellaneous & ducts air-side pressure drop = | | | | | 12.45 | millibar | | | | | | | |
| Miscellaneous & ducts gas-side pressure drop = | | | | | 7.472 | millibar | | | | | | | |

| BOILER HEAT EXCHANGER SUMMARY | | | | | | | | | |
|-------------------------------|-------------|-------------|--------------|--------------|--------------|---------|---------|------|------|
| Zone | Tg | Tw | DT | Afrn | DP | Mg | Qg | Vg | Tube |
| /path | C | C | C | m^2 | millibar | t/h | kJ/s | m/s | rows |
| 5 | 1176.7 | 427.6 | 749.1 | | | | | | |
| | REV | | | | 0.0 | 2429.1 | 607256 | 10.0 | |
| | 1176.7 | 343.5 | 833.2 | | | | | | |
| 6 | 1176.7 | 532.3 | 644.3 | | | | | | |
| | RSH | | | | 0.0 | 2429.1 | 163245 | 10.0 | |
| | 1176.7 | 462.5 | 714.2 | | | | | | |
| 7 | 1176.7 | 532.3 | 644.3 | | | | | | |
| 0 | CS2 | | | 362.9 | 0.1 | 2444.7 | 123422 | 10.4 | 14.0 |
| | 1036.3 | 606.0 | 430.3 | | | | | | |
| 8 | 1036.3 | 485.2 | 551.0 | | | | | | |
| 0 | CR2 | | | 362.9 | 0.2 | 2444.7 | 138893 | 9.6 | 20.0 |
| | 875.1 | 605.4 | 269.7 | | | | | | |
| 10 | 875.1 | 462.5 | 412.7 | | | | | | |
| 0 | CS1 | | | 353.4 | 0.2 | 2444.7 | 131734 | 10.3 | 16.0 |
| | 718.5 | 427.6 | 290.9 | | | | | | |
| 11 | 718.5 | 485.2 | 233.3 | | | | | | |
| 0 | CR1 | | | 353.4 | 0.6 | 2444.7 | 138893 | 10.5 | 24.0 |
| | 548.0 | 372.6 | 175.4 | | | | | | |
| 14 | 548.0 | 343.5 | 204.5 | | | | | | |
| 0 | ECO1 | | | 353.4 | 0.7 | 2444.7 | 162960 | 7.5 | 20.0 |
| | 338.4 | 287.7 | 50.7 | | | | | | |
| Totals | | | | | 1.8 | | 1466402 | | 94.0 |
| Note: g = gas + ash | | | | | | | | | |
| BOILER HEAT TRANSFER SURFACES | | | | | | | | | |
| | Economizers | Evaporators | Superheaters | HP Reheaters | LP Reheaters | TOTAL | | | |
| Q | 160553 | 598281 | 420401 | 273680 | 0 | 1452916 | kJ/s | | |
| A | 48090 | 5270 | 13383 | 19679 | 0 | 86423 | m^2 | | |

| BOILER WATER/STEAM SUMMARY | | | | | | | | |
|----------------------------|----------|--------|------------|----------|--------------|--------------|-----------|---------------------|
| Stream | P bar | T C | h kJ/kg | M t/h | s kJ/kg-K | UA kJ/s-K | Q kJ/s | A m ² |
| ECO1 inlet | 306.75 | 287.7 | 1267.0 | 1918.4 | 3.0652 | | | |
| ECO1 exit | 303.71 | 343.5 | 1568.3 | 1918.4 | 3.5772 | 1455.8 | 160552 | 48092 |
| REV exit | 288.54 | 427.6 | 2691.0 | 1918.4 | 5.2705 | | 598281 | 5270 |
| CS1 inlet | 288.54 | 427.6 | 2691.0 | 1918.4 | 5.2705 | | | |
| CS1 exit | 285.95 | 462.5 | 2934.5 | 1918.4 | 5.6130 | 372.7 | 129787 | 7169 |
| RSH inlet | 285.95 | 462.5 | 2934.5 | 1918.4 | 5.6130 | | | |
| RSH exit | 282.74 | 532.3 | 3236.3 | 1918.4 | 6.0099 | | 160810 | 1884.9 |
| CS2 inlet | 282.74 | 532.3 | 3236.3 | 1918.4 | 6.0099 | | | |
| CS2 exit | 280.14 | 606.0 | 3479.9 | 1918.4 | 6.3032 | 244.6 | 129784 | 4330 |
| HP steam | 280.14 | 606.0 | 3479.9 | 1918.4 | 6.3032 | | | |
| Cold RH steam | 63.04 | 372.6 | 3101.5 | 1740.2 | 6.4062 | | | |
| CR1 inlet | 63.04 | 372.6 | 3101.5 | 1740.2 | 6.4062 | | | |
| CR1 exit | 62.12 | 485.2 | 3384.6 | 1740.2 | 6.8173 | 674.2 | 136840 | 13140 |
| CR2 inlet | 62.12 | 485.2 | 3384.6 | 1740.2 | 6.8173 | | | |
| CR2 exit | 61.20 | 605.4 | 3667.7 | 1740.2 | 7.1705 | 347.5 | 136840 | 6540 |
| Hot RH steam | 61.20 | 605.4 | 3667.7 | 1740.2 | 7.1705 | | | |

| FUEL - 'Hunter Valley' (Solid) | | |
|--------------------------------------|------------|-------------------|
| Fuel Name: Hunter Valley | | |
| Thermoflow library fuel | | |
| Coal, High-volatile B bituminous | | |
| Fuel supply temp. | 25.00 | C |
| Heating Values | | |
| LHV | 27904.8 | kJ/kg |
| HHV | 28930.0 | kJ/kg |
| Ultimate Analysis (weight %) | | |
| Moisture | 4.80 | % |
| Ash | 9.40 | % |
| Carbon | 70.72 | % |
| Hydrogen | 4.16 | % |
| Nitrogen | 1.53 | % |
| Chlorine | 0.04 | % |
| Sulfur | 0.57 | % |
| Oxygen | 8.78 | % |
| Total | 100.00 | % |
| Proximate Analysis (weight %) | | |
| Moisture | 4.80 | % |
| Ash | 9.40 | % |
| Volatile Matter | 31.70 | % |
| Fixed Carbon | 54.10 | % |
| Total | 100.00 | % |
| Ash Analysis (weight %) | | |
| SiO2 | 63.90 | % |
| Al2O3 | 22.30 | % |
| Fe2O3 | 7.40 | % |
| CaO | 0.80 | % |
| MgO | 0.70 | % |
| Na2O | 0.20 | % |
| K2O | 1.60 | % |
| TiO2 | 0.80 | % |
| P2O5 | 0.70 | % |
| SO3 | 0.50 | % |
| Other | 1.10 | % |
| Total | 100.00 | % |
| Ash Characteristics | | |
| Fouling | Low/Medium | |
| Initial deformation temperature | 1280.00 | C |
| Softening temperature | 1480.00 | C |
| Bulk density | 768.89 | kg/m ³ |
| Mercury content (dry basis) | 0.00 | ppmw |

| | | |
|---|----------|----------|
| Pseudo molecular weight | 7.8810 | |
| Mole flow | 6.4298 | kg-mol/s |
| Mass flow (ash-free) | 182.4252 | t/h |
| Mass flow | 201.3523 | t/h |
| Mass flow | 4832 | t/day |
| LHV (ash-free) @ 25 C | 30800.00 | kJ/kg |
| LHV (adjusted)* @ 25 C | 30800.00 | kJ/kg |
| Enthalpy (ash-free) ref. to 0 C | 31987.67 | kJ/kg |
| Atomic percentage | | |
| C | 51.25 | % |
| H | 40.56 | % |
| O | 7.09 | % |
| N | 0.95 | % |
| S | 0.15 | % |
| Ar | 0.00 | % |
| * Adjusted heating values include fuel sensible enthalpy above 77 F/25 C and are on an ash-free basis | | |

| ASME Boiler Energy Balance | | | |
|--|------------------|------------------|----------|
| Energy In | HHV based | LHV based | |
| Energy input from fuel* | 1618114 | 1560772 | kW |
| Credit due to entering dry air | 2959 | 2959 | kW |
| Credit due to moisture in entering air | 65.83 | 65.83 | kW |
| Credit due to sensible heat in fuel | 0 | 0 | kW |
| Credit due to sulfation | 0 | 0 | kW |
| Credit due to sensible heat in sorbent | 0 | 0 | kW |
| Credit due to auxiliary equipment power | 3551 | 3551 | kW |
| Total credits | 6576 | 6576 | kW |
| Total energy in | 1624690 | 1567348 | kW |
| Energy Out | | | |
| Energy output to steam and water | 1452916 | 1452916 | kW |
| Loss due to sensible heat in dry gas | 79443 | 79443 | kW |
| Loss due to moisture in fuel | 7130 | 570.6 | kW |
| Loss due to moisture from burning hydrogen | 55213 | 4419 | kW |
| Loss due to moisture in air | 1730.6 | 1730.6 | kW |
| Loss due to unburned carbon | 4669 | 4669 | kW |
| Loss due to calcination of sorbent | 0 | 0 | kW |
| Loss due to radiation and unmeasured losses | 23598 | 23598 | kW |
| Total losses | 171783 | 114430 | kW |
| Total energy out | 1624699 | 1567347 | kW |
| ASME fuel efficiency (Output/Input) | 89.79 | 93.09 | % |
| ASME gross efficiency (Output/(Input+Credits)) | 89.43 | 92.7 | % |
| *Energy input from fuel is based upon fuel heating value at 77 F/25 C | | | |
| Zero enthalpy: dry gases & liquid water at 77 F/25 C | | | |
| The entering air enthalpy is calculated based on air temperature before air heater. | | | |
| The leaving gas enthalpy is calculated based on flue gas temperature after air heater. | | | |

| Solid Fuel | | |
|---|-------|-------------------|
| Fuel Name: Hunter Valley | | |
| Type: Coal, High-volatile B bituminous | | |
| Fuel supply temperature | 25 | C |
| Total LHV + Sensible heat @ 25C | 27905 | kJ/kg |
| Total fuel enthalpy referenced to 0C | 28981 | kJ/kg |
| Heating Values (at 25C) | | |
| LHV (moisture and ash included) | 27905 | kJ/kg |
| HHV (moisture and ash included) | 28930 | kJ/kg |
| Ultimate Analysis (weight %) | | |
| Moisture | 4.8 | % |
| Ash | 9.4 | % |
| Carbon | 70.72 | % |
| Hydrogen | 4.16 | % |
| Nitrogen | 1.53 | % |
| Chlorine | 0.04 | % |
| Sulfur | 0.57 | % |
| Oxygen | 8.78 | % |
| Total | 100 | % |
| Proximate Analysis (weight %) | | |
| Moisture | 4.8 | % |
| Ash | 9.4 | % |
| Volatile Matter | 31.7 | % |
| Fixed Carbon | 54.1 | % |
| Total | 100 | % |
| Other Properties | | |
| Specific Heat @ 25C, dry | 1.214 | kJ/kg-C |
| Specific Heat @ 300C, dry | 1.968 | kJ/kg-C |
| Bulk density | 768.9 | kg/m ³ |
| Hardgrove Grindability Index (HGI) | 50 | |
| Mercury content (dry basis) | 0 | ppmw |
| Ash Analysis (weight %) | | |
| SiO ₂ | 63.9 | % |
| Al ₂ O ₃ | 22.3 | % |
| Fe ₂ O ₃ | 7.4 | % |
| CaO | 0.8 | % |
| MgO | 0.7 | % |
| Na ₂ O | 0.2 | % |
| K ₂ O | 1.6 | % |
| TiO ₂ | 0.8 | % |
| P ₂ O ₅ | 0.7 | % |
| SO ₃ | 0.5 | % |
| Other | 1.1 | % |
| Total | 100 | % |
| Ash Characteristics | | |
| Fouling | | Low/Medium |
| Ash Initial Deformation Temperature (reducing atm.) | 1280 | C |
| Ash Softening Temperature (reducing atm.) | 1480 | C |

| Pulverizer | | |
|---|-------------------------|-------------------|
| Design Data | | |
| Pulverizer type | Vertical air-swept mill | |
| Number per boiler | 7 | |
| Number operating | 6 | |
| Capacity margin | 15 | % |
| Nameplate capacity at standard condition* (each) | 38.59 | tonne/hr |
| Full load capacity at current condition** (each) | 38.59 | tonne/hr |
| Fineness correction factor | 1 | |
| HGI correction factor | 1 | |
| Moisture correction factor | 1 | |
| Total correction factor | 1 | |
| Nameplate specific power consumption | 22.05 | kWh/tonne |
| Specific power consumption at current condition | 22.05 | kWh/tonne |
| * Nameplate condition: Fineness = 70%, Moisture = 8%, HGI = 50 | | |
| ** Current condition: Fineness = 70%, Moisture = 4.8%, HGI = 50 | | |
| Heat Balance (each) | | |
| Desired pulverizer exit temperature | 70 | C |
| Desired fuel outlet moisture | 1.734 | % |
| Air/fuel mass ratio | 1.75 | |
| Total power consumption | 739.8 | kW |
| Fuel in | | |
| Flow | 33.56 | t/h |
| Temperature | 25 | C |
| Moisture | 4.8 | % |
| LHV | 27905 | kJ/kg |
| HHV | 28930 | kJ/kg |
| Fuel out | | |
| Flow | 32.51 | t/h |
| Temperature | 70 | C |
| Moisture | 1.734 | % |
| LHV | 28882 | kJ/kg |
| HHV | 29862 | kJ/kg |
| Hot gas inlet | | |
| Hot gas flow | 29.77 | t/h |
| Hot gas pressure | 1.125 | bar |
| Hot gas temperature | 182.2 | C |
| Tempering air flow | 28.95 | t/h |
| Tempering air pressure | 1.125 | bar |
| Tempering air temperature | 37.06 | C |
| Drying air flow | 58.73 | t/h |
| Drying air temperature | 110.9 | C |
| Pressure | 1.125 | bar |
| Percentage of tempering air over drying air | 49.3 | % |
| Gas outlet | | |
| Mass flow | 59.77 | t/h |
| Pressure | 1.1 | bar |
| Temperature | 70 | C |
| Gauge pressure | 99.63 | millibar |
| Dew point | 33.16 | C |
| Relative humidity | 16.28 | % |
| Volume flow | 15.14 | m ³ /s |
| Pulverizer(integral) Performance | | |
| Total moisture evaporated | 6.282 | t/h |
| Actual percentage of fuel moisture evaporated | 65 | % |
| Total power consumption | 4439 | kW |
| Pressure drop | 24.91 | millibar |
| Energy in | | |
| Energy provided by drying fluid | 680.5 | kW |
| Grinding heat | 591.9 | kW |
| Total | 1272.4 | kW |
| Energy consumed | | |
| Fuel heating | 593.8 | kW |
| Moisture evaporation | 678.6 | kW |
| Total | 1272.4 | kW |

| | | |
|---|-----------|------------|
| ECO1 | | |
| Heat Balance | | |
| Inlet Water | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 306.7 | bar |
| Temperature | 287.7 | C |
| Enthalpy | 1267 | kJ/kg |
| Exit Water | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 303.7 | bar |
| Temperature | 343.5 | C |
| Enthalpy | 1568.3 | kJ/kg |
| Gas | | |
| Mass flow | 2429.1 | t/h |
| Flyash mass flow | 15.54 | t/h |
| Inlet temperature | 548 | C |
| Exit temperature | 338.4 | C |
| Sulfur dew point temperature | 119.8 | C |
| Dew point temperature | 40.5 | C |
| Static pressure drop | 0.6981 | millibar |
| Heat Transfer | | |
| Heat from gas | 161895 | kW |
| Heat from ash | 1065 | kW |
| Heat transfer to water/steam | 160552 | kW |
| Heat loss | 2408.3 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Solid fins |
| Tube arrangement | | In line |
| Tube material | | T22 |
| Number of tube rows (longitudinal) | | 20 |
| Number of tubes per row (transverse) | | 136 |
| Number of rows per waterside flow pass | | 2 |
| Longitudinal row pitch | 101.6 | mm |
| Gas path transverse width | 18.99 | m |
| Tube length | 18.61 | m |
| Tube outer diameter | 50.8 | mm |
| Tube wall thickness | 7.62 | mm |
| Transverse tube pitch | 139.6 | mm |
| Tube metal conductivity @ 500F (260C) | 36.86 | W/m-C |
| Tube metal conductivity slope | -0.0109 | W/m-C^2 |
| Fins | | |
| Fin material | | T22 |
| Fin height | 19.05 | mm |
| Fin spacing | 8.959 | mm |
| Fin thickness | 1.905 | mm |
| Number of fins per meter | 92.05 | per meter |
| Fin metal conductivity @ 500F (260C) | 36.86 | W/m-C |
| Fin metal conductivity slope | -0.0109 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 353.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5883 | |
| H.T. surface area / min. free flow cross section | 11.57 | |
| Primary tube surface / total heat transfer surf. | 0.1385 | |
| Water side flow cross section area | 0.2701 | m^2 |
| Heat exchanger prime outside surface | 6661 | m^2 |
| Heat exchanger total fin area | 41431 | m^2 |
| Heat exchanger total outside area | 48092 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 4.404 | m/s |
| Face mass flux | 6.918 | t/h-m^2 |
| Velocity at minimum flow area | 7.486 | m/s |
| Mass flux at minimum flow area | 11.76 | t/h-m^2 |
| Reynolds number | 5381 | |
| Prandtl number | 0.7196 | |
| Convective Nusselt number | 42.99 | |
| Convective heat transfer coefficient | 40.81 | W/m^2-C |
| Radiative heat transfer coefficient | 2.299 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 43.11 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1801 | |
| Friction factor Re coefficient | 3.223 | |
| Radiation beam mean length | 0.2569 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.6981 | millibar |

| ECO1 | | |
|--|------------|---------------------|
| Water Side | | |
| Mass flux | 7101 | t/h-m ² |
| Mean velocity | 2.727 | m/s |
| Reynolds number | 797852 | |
| Prandtl number | 0.8345 | |
| Nusselt number | 1141.2 | |
| Heat transfer coefficient | 18021 | W/m ² -C |
| Fouling resistance | 1.7612E-04 | m ² -C/W |
| Pressure drop correction factor | 1.351 | |
| User-defined pressure drop | 3.037 | bar |
| Hardware determined pressure drop | 2.248 | bar |
| Overall Performance | | |
| Fin effectiveness | 0.7939 | |
| Effective / total external area | 0.8224 | |
| Overall heat transfer coefficient | 30.27 | W/m ² -C |
| Tube metal mean temperature | 322.9 | C |
| Fin metal mean temperature | 340.2 | C |
| Estimated minimum tube surface temperature | 293.5 | C |
| Estimated maximum tube wall temperature | 366.8 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum fin tip temperature | 415.1 | C |
| Recommended maximum fin metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 392.7 | bar |
| Heat transfer rate from gas | 161895 | kW |
| Heat from fly ash | 1065 | kW |
| Heat transfer rate to water | 160552 | kW |
| Heat loss | 2408.3 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 1455.8 | kW/C |
| Heat exchanger effectiveness | 0.8052 | |

| | | |
|---|------------|----------|
| CS1 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 288.5 | bar |
| Temperature | 427.6 | C |
| Enthalpy | 2691 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 285.9 | bar |
| Temperature | 462.5 | C |
| Enthalpy | 2934.5 | kJ/kg |
| Gas | | |
| Mass flow | 2429.1 | t/h |
| Flyash mass flow | 15.54 | t/h |
| Inlet temperature | 875.1 | C |
| Exit temperature | 718.5 | C |
| Static pressure drop | 0.247 | millibar |
| Heat Transfer | | |
| Heat from gas | 130897 | kW |
| Heat from ash | 837.1 | kW |
| Heat transfer to water/steam | 129787 | kW |
| Heat loss | 1946.8 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | Bare | |
| Tube arrangement | In line | |
| Tube material | T91 | |
| Number of tube rows (longitudinal) | 16 | |
| Number of tubes per row (transverse) | 120 | |
| Number of rows per waterside flow pass | 2 | |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 18.88 | m |
| Tube length | 18.72 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 7.62 | mm |
| Transverse tube pitch | 157.3 | mm |
| Tube metal conductivity @ 500F (260C) | 27 | W/m-C |
| Tube metal conductivity slope | 0.0053 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 353.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5964 | |
| H.T. surface area / min. free flow cross section | 2.126 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 0.439 | m^2 |
| Heat exchanger prime outside surface | 7169 | m^2 |
| Heat exchanger total outside area | 7169 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 6.154 | m/s |
| Face mass flux | 6.918 | t/h-m^2 |
| Velocity at minimum flow area | 10.32 | m/s |
| Mass flux at minimum flow area | 11.6 | t/h-m^2 |
| Reynolds number | 5330 | |
| Prandtl number | 0.7172 | |
| Convective Nusselt number | 41.93 | |
| Convective heat transfer coefficient | 42.27 | W/m^2-C |
| Radiative heat transfer coefficient | 14.58 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 56.85 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1769 | |
| Friction factor Re coefficient | 0.1002 | |
| Radiation beam mean length | 0.1497 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.247 | millibar |
| Water Side | | |
| Mass flux | 4370 | t/h-m^2 |
| Mean velocity | 8.548 | m/s |
| Reynolds number | 1941470 | |
| Prandtl number | 1.556 | |
| Nusselt number | 2854.8 | |
| Heat transfer coefficient | 7547 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 1.922 | |
| User-defined pressure drop | 2.595 | bar |
| Hardware determined pressure drop | 2.467 | bar |

| CS1 | | |
|--|--------|---------------------|
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 51.99 | W/m ² -C |
| Tube metal mean temperature | 452 | C |
| Estimated minimum tube surface temperature | 439.1 | C |
| Estimated maximum tube wall temperature | 478.8 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 340.4 | bar |
| Heat transfer rate from gas | 130897 | kW |
| Heat from fly ash | 837.1 | kW |
| Heat transfer rate to water | 129787 | kW |
| Heat loss | 1946.8 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 372.7 | kW/C |
| Heat exchanger effectiveness | 0.35 | |

| | | |
|---|------------|----------|
| CS2 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 282.7 | bar |
| Temperature | 532.3 | C |
| Enthalpy | 3236 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 280.1 | bar |
| Temperature | 606 | C |
| Enthalpy | 3480 | kJ/kg |
| Gas | | |
| Mass flow | 2429.1 | t/h |
| Flyash mass flow | 15.54 | t/h |
| Inlet temperature | 1176.7 | C |
| Exit temperature | 1036.3 | C |
| Static pressure drop | 0.1285 | millibar |
| Heat Transfer | | |
| Heat from gas | 122712 | kW |
| Radiant heat influx | 8309 | kW |
| Heat from ash | 710.6 | kW |
| Heat transfer to water/steam | 129784 | kW |
| Heat loss | 1946.8 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | Bare | |
| Tube arrangement | In line | |
| Tube material | TP347 HFG | |
| Number of tube rows (longitudinal) | 14 | |
| Number of tubes per row (transverse) | 82 | |
| Number of rows per waterside flow pass | 7 | |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 19.2 | m |
| Tube length | 18.9 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 8.342 | mm |
| Transverse tube pitch | 234.1 | mm |
| Tube metal conductivity @ 500F (260C) | 18.34 | W/m-C |
| Tube metal conductivity slope | 0.015 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 362.9 | m^2 |
| Min. gas free flow cross section / frontal area | 0.7287 | |
| H.T. surface area / min. free flow cross section | 1.169 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 0.9881 | m^2 |
| Heat exchanger prime outside surface | 4330 | m^2 |
| Heat exchanger total outside area | 4330 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 7.564 | m/s |
| Face mass flux | 6.737 | t/h-m^2 |
| Velocity at minimum flow area | 10.38 | m/s |
| Mass flux at minimum flow area | 9.244 | t/h-m^2 |
| Reynolds number | 3664 | |
| Prandtl number | 0.716 | |
| Convective Nusselt number | 28.9 | |
| Convective heat transfer coefficient | 35.29 | W/m^2-C |
| Radiative heat transfer coefficient | 28.91 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 64.2 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1557 | |
| Friction factor Re coefficient | 0.0688 | |
| Radiation beam mean length | 0.2481 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.1285 | millibar |
| Water Side | | |
| Mass flux | 1941.5 | t/h-m^2 |
| Mean velocity | 6.219 | m/s |
| Reynolds number | 747985 | |
| Prandtl number | 1.043 | |
| Nusselt number | 1166.3 | |
| Heat transfer coefficient | 2616.8 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 1.922 | |
| User-defined pressure drop | 2.595 | bar |
| Hardware determined pressure drop | 0.2338 | bar |

| CS2 | | |
|--|--------|---------------------|
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 56.5 | W/m ² -C |
| Tube metal mean temperature | 588 | C |
| Estimated minimum tube surface temperature | 577.6 | C |
| Estimated maximum tube wall temperature | 636.2 | C |
| Maximum allowable tube wall metal temperature | 1093.3 | C |
| Estimated maximum allowable water side pressure | 296.9 | bar |
| Heat transfer rate from gas | 122712 | kW |
| Radiant heat influx | 8309 | kW |
| Heat from fly ash | 710.6 | kW |
| Heat transfer rate to water | 129784 | kW |
| Heat loss | 1946.8 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 244.6 | kW/C |
| Heat exchanger effectiveness | 0.2179 | |

| | | |
|---|------------|----------|
| CR1 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1740.2 | t/h |
| Pressure | 63.04 | bar |
| Temperature | 372.6 | C |
| Enthalpy | 3102 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1740.2 | t/h |
| Pressure | 62.12 | bar |
| Temperature | 485.2 | C |
| Enthalpy | 3385 | kJ/kg |
| Gas | | |
| Mass flow | 2429.1 | t/h |
| Flyash mass flow | 15.54 | t/h |
| Inlet temperature | 718.5 | C |
| Exit temperature | 548 | C |
| Static pressure drop | 0.5717 | millibar |
| Heat Transfer | | |
| Heat from gas | 137975 | kW |
| Heat from ash | 917.3 | kW |
| Heat transfer to water/steam | 136840 | kW |
| Heat loss | 2052.6 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Bare |
| Tube arrangement | | In line |
| Tube material | | T91 |
| Number of tube rows (longitudinal) | | 24 |
| Number of tubes per row (transverse) | | 148 |
| Number of rows per waterside flow pass | | 4 |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 19.06 | m |
| Tube length | 18.54 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 2.794 | mm |
| Transverse tube pitch | 128.8 | mm |
| Tube metal conductivity @ 500F (260C) | 27 | W/m-C |
| Tube metal conductivity slope | 0.0053 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 353.4 | m^2 |
| Min. gas free flow cross section / frontal area | 0.5069 | |
| H.T. surface area / min. free flow cross section | 3.057 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 1.559 | m^2 |
| Heat exchanger prime outside surface | 13140 | m^2 |
| Heat exchanger total outside area | 13140 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 5.316 | m/s |
| Face mass flux | 6.918 | t/h-m^2 |
| Velocity at minimum flow area | 10.49 | m/s |
| Mass flux at minimum flow area | 13.65 | t/h-m^2 |
| Reynolds number | 6747 | |
| Prandtl number | 0.7177 | |
| Convective Nusselt number | 51.92 | |
| Convective heat transfer coefficient | 47.61 | W/m^2-C |
| Radiative heat transfer coefficient | 9.889 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 57.5 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1879 | |
| Friction factor Re coefficient | 0.1365 | |
| Radiation beam mean length | 0.1128 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.5717 | millibar |
| Water Side | | |
| Mass flux | 1116 | t/h-m^2 |
| Mean velocity | 14.85 | m/s |
| Reynolds number | 699696 | |
| Prandtl number | 0.992 | |
| Nusselt number | 1087.7 | |
| Heat transfer coefficient | 1201 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 0.8695 | |
| User-defined pressure drop | 0.918 | bar |
| Hardware determined pressure drop | 0.8279 | bar |

| | | |
|--|--------|---------------------|
| CR1 | | |
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 51.31 | W/m ² -C |
| Tube metal mean temperature | 435.3 | C |
| Estimated minimum tube surface temperature | 383.5 | C |
| Estimated maximum tube wall temperature | 499.8 | C |
| Maximum allowable tube wall metal temperature | 732.2 | C |
| Estimated maximum allowable water side pressure | 105.1 | bar |
| Heat transfer rate from gas | 137975 | kW |
| Heat from fly ash | 917.3 | kW |
| Heat transfer rate to water | 136840 | kW |
| Heat loss | 2052.6 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 674.2 | kW/C |
| Heat exchanger effectiveness | 0.4929 | |

| | | |
|---|------------|-----------|
| CR2 | | |
| Heat Balance | | |
| Inlet Steam | | |
| Mass flow | 1740.2 | t/h |
| Pressure | 62.12 | bar |
| Temperature | 485.2 | C |
| Enthalpy | 3385 | kJ/kg |
| Exit Steam | | |
| Mass flow | 1740.2 | t/h |
| Pressure | 61.2 | bar |
| Temperature | 605.4 | C |
| Enthalpy | 3668 | kJ/kg |
| Gas | | |
| Mass flow | 2429.1 | t/h |
| Flyash mass flow | 15.54 | t/h |
| Inlet temperature | 1036.3 | C |
| Exit temperature | 875.1 | C |
| Static pressure drop | 0.1755 | millibar |
| Heat Transfer | | |
| Heat from gas | 138079 | kW |
| Heat from ash | 814.1 | kW |
| Heat transfer to water/steam | 136840 | kW |
| Heat loss | 2052.6 | kW |
| Hardware | | |
| Tubes | | |
| Fin-tube type | | Bare |
| Tube arrangement | | In line |
| Tube material | | TP347 HFG |
| Number of tube rows (longitudinal) | | 20 |
| Number of tubes per row (transverse) | | 86 |
| Number of rows per waterside flow pass | | 5 |
| Longitudinal row pitch | 76.2 | mm |
| Gas path transverse width | 19.04 | m |
| Tube length | 19.06 | m |
| Tube outer diameter | 63.5 | mm |
| Tube wall thickness | 2.794 | mm |
| Transverse tube pitch | 221.4 | mm |
| Tube metal conductivity @ 500F (260C) | 18.34 | W/m-C |
| Tube metal conductivity slope | 0.015 | W/m-C^2 |
| Overall Data | | |
| Gas path frontal area | 362.9 | m^2 |
| Min. gas free flow cross section / frontal area | 0.7132 | |
| H.T. surface area / min. free flow cross section | 1.264 | |
| Primary tube surface / total heat transfer surf. | 1 | |
| Water side flow cross section area | 1.133 | m^2 |
| Heat exchanger prime outside surface | 6540 | m^2 |
| Heat exchanger total outside area | 6540 | m^2 |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 6.832 | m/s |
| Face mass flux | 6.737 | t/h-m^2 |
| Velocity at minimum flow area | 9.58 | m/s |
| Mass flux at minimum flow area | 9.446 | t/h-m^2 |
| Reynolds number | 3957 | |
| Prandtl number | 0.7165 | |
| Convective Nusselt number | 30.95 | |
| Convective heat transfer coefficient | 35.18 | W/m^2-C |
| Radiative heat transfer coefficient | 23.91 | W/m^2-C |
| Convective h.t.c. adjustment factor | 1 | |
| Total gas side adjusted heat transfer coefficient | 59.1 | W/m^2-C |
| Fouling resistance | 0.0008806 | m^2-C/W |
| Nusselt number Re coefficient | 0.1585 | |
| Friction factor Re coefficient | 0.0715 | |
| Radiation beam mean length | 0.2319 | m |
| Pressure drop correction factor | 0.9 | |
| Pressure drop | 0.1755 | millibar |
| Water Side | | |
| Mass flux | 1536.4 | t/h-m^2 |
| Mean velocity | 25.11 | m/s |
| Reynolds number | 807330 | |
| Prandtl number | 0.9309 | |
| Nusselt number | 1194.3 | |
| Heat transfer coefficient | 1588.8 | W/m^2-C |
| Fouling resistance | 1.7612E-04 | m^2-C/W |
| Pressure drop correction factor | 0.8695 | |
| User-defined pressure drop | 0.918 | bar |
| Hardware determined pressure drop | 1.284 | bar |

| | | |
|--|--------|---------------------|
| CR2 | | |
| Overall Performance | | |
| Effective / total external area | 1 | |
| Overall heat transfer coefficient | 53.14 | W/m ² -C |
| Tube metal mean temperature | 556.4 | C |
| Estimated minimum tube surface temperature | 515 | C |
| Estimated maximum tube wall temperature | 620 | C |
| Maximum allowable tube wall metal temperature | 1093.3 | C |
| Estimated maximum allowable water side pressure | 93.08 | bar |
| Heat transfer rate from gas | 138079 | kW |
| Heat from fly ash | 814.1 | kW |
| Heat transfer rate to water | 136840 | kW |
| Heat loss | 2052.6 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 347.5 | kW/C |
| Heat exchanger effectiveness | 0.2925 | |

| | | |
|---|---------|----------|
| Furnace | | |
| Design Heat Balance: Once through - Coal fired | | |
| Furnace gage pressure | -0.6226 | millibar |
| Excess air | 20 | % |
| Secondary Air | | |
| Temperature | 273.9 | C |
| Mass flow | 1894.8 | t/h |
| Primary Air into Pulverizer | | |
| Temperature | 182.2 | C |
| Mass flow | 178.6 | t/h |
| Tempering Air into Pulverizer | | |
| Temperature | 37.06 | C |
| Mass flow | 173.7 | t/h |
| Pulverizer inlet Dry Air | | |
| Temperature | 110.9 | C |
| Mass flow | 352.4 | t/h |
| Pulverizer outlet Gas | | |
| Temperature | 70 | C |
| Mass flow | 358.6 | t/h |
| Gage pressure | 124.5 | millibar |
| Flue Gas | | |
| Temperature | 1176.7 | C |
| Mass flow | 2429.1 | t/h |
| Ash mass flow | 15.54 | t/h |
| Mole percent N2 | 73.65 | % |
| Mole percent O2 | 3.287 | % |
| Mole percent CO2 | 14.55 | % |
| Mole percent H2O | 7.587 | % |
| Mole percent SO2 | 0.044 | % |
| Mole percent Ar | 0.8853 | % |
| SO3 in flue gas | 2.2 | ppm |
| Emission | | |
| Reference O2 content | 6 | % |
| Actual O2 content in exit gas | 3.287 | % |
| H2O content in exit gas | 7.587 | % |
| Hg from combustion | 0 | kg/hr |
| Hg in exit gas | 0 | kg/hr |
| HCl in exit gas | 66.26 | kg/hr |
| NOx production | 0 | kg/hr |
| NOx volume concentration in exit gas | 0 | ppmv |
| NOx mass concentration in exit gas | 0 | ppm |
| Exit Steam | | |
| Steam produced by waterwall | 1918.4 | t/h |
| Pressure | 288.5 | bar |
| Temperature | 427.6 | C |
| Enthalpy | 2691 | kJ/kg |
| Inlet Water | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 303.7 | bar |
| Temperature | 343.5 | C |
| Enthalpy | 1568.3 | kJ/kg |
| Radiant Superheater Exit Steam | | |
| Mass flow | 1918.4 | t/h |
| Pressure | 282.7 | bar |
| Temperature | 532.3 | C |
| Enthalpy | 3236 | kJ/kg |
| Radiant Superheater Inlet Steam | | |
| Pressure | 285.9 | bar |
| Temperature | 462.5 | C |
| Enthalpy | 2934.5 | kJ/kg |
| Inlet Fuel : Solid | | |
| Fuel mass flow | 201.4 | t/h |
| LHV @ 77 F (25 C) | 27905 | kJ/kg |
| HHV @ 77 F (25 C) | 28930 | kJ/kg |
| Fuel input (LHV) | 1560.8 | MW |
| Fuel input (HHV) | 1618.1 | MW |
| Weight percent ash | 9.4 | % |
| Fuel ash flow | 18.93 | t/h |
| Fuel inlet temperature | 25 | C |
| Exit Ash | | |
| Bottom ash flow | 3.885 | t/h |
| Unburnt carbon flow in bottom ash | 0.0997 | t/h |

| | | |
|---|----------------|--------------------|
| Furnace | | |
| Unburnt carbon in bottom ash | 2.566 | % |
| Fly ash flow | 15.54 | t/h |
| Unburnt carbon flow in fly ash | 0.3987 | t/h |
| Unburnt carbon in fly ash | 2.566 | % |
| Total unburnt carbon flow in ash | 0.4984 | t/h |
| Combustion efficiency | 99.7 | % |
| Heat Transfer | | |
| Heat transfer to waterwall | 598281 | kW |
| Heat transfer to radiant superheater | 160810 | kW |
| Unburnt carbon in ash | 4669 | kW |
| Heat losses | 11385 | kW |
| Radiant flux past screen | 8309 | kW |
| Bottom ash (bed drain) sensible heat | 1404.6 | kW |
| Fly ash sensible heat | 5618 | kW |
| Performance | | |
| Fuel delivery power | 4439 | kW |
| Ash handling power | 856.5 | kW |
| Heat Transfer | | |
| Furnace Ratings | | |
| Heat absorption rate | 107.2 | kW/m ² |
| Heat release rate | 235.5 | kW/m ² |
| Volumetric heat release rate | 74.07 | kW/m ³ |
| Heat Transfer and Heat Balance | | |
| Energy In | | |
| Fuel input | 1560768 | kW |
| Fuel delivery energy included in heat balance calculation | 3551 | kW |
| Air input | 143562 | kW |
| Total Energy In | 1707881 | kW |
| Energy Out | | |
| Flue gas | 917381 | kW |
| Heat transfer to waterwall | 598281 | kW |
| Heat transfer to radiant superheater | 160810 | kW |
| Heat losses | 11385 | kW |
| Radiant flux past screen | 8309 | kW |
| Unburnt carbon in ash | 4669 | kW |
| Bottom ash (bed drain) sensible heat | 1404.6 | kW |
| Fly ash sensible heat | 5618 | kW |
| Total Energy Out | 1707858 | kW |
| Heat Balance Error | 0.0013 | % |
| Heat Transfer Characteristics | | |
| Gas emissivity | 0.8438 | |
| Gas absorptivity | 0.8638 | |
| Radiating mean beam length | 14.72 | m |
| Adiabatic temperature | 2029.4 | C |
| Effective radiating temperature | 1607.1 | C |
| Waterwall surface temperature | 1163.3 | C |
| Furnace exit temperature | 1176.7 | C |
| Gas mass flux @ aperture | 6.737 | t/h-m ² |
| Gas velocity leaving aperture @ furnace exit temperature | 7.564 | m/s |
| Furnace velocity @ Effective radiating temperature | 10.01 | m/s |
| Radiant flux to waterwall effective projected heat transfer surface | 112.8 | kW/m ² |
| Mean flux to waterwall effective projected heat transfer surface | 113.5 | kW/m ² |

| | | |
|---|--------|---------------------|
| Rotary Air Heater | | |
| Heat Balance | | |
| Number per station | | 3 |
| Number operating | | 3 |
| Primary Air Path (station) | | |
| Primary air flow | 178.6 | t/h |
| Primary air temperature | 182.2 | C |
| Inlet air flow | 205.4 | t/h |
| Inlet pressure | 1.13 | bar |
| Inlet temperature | 37.06 | C |
| Cold side leakage | 17.86 | t/h |
| Hot side leakage | 8.932 | t/h |
| Pressure drop | 4.869 | millibar |
| Channel velocity | 6.761 | m/s |
| Reynolds number | 3147 | |
| Stanton number | 0.005 | |
| Heat transfer coefficient | 49.73 | W/m ² -C |
| Secondary Air Path (station) | | |
| Secondary air flow | 1894.8 | t/h |
| Secondary air temperature | 273.9 | C |
| Inlet pressure | 1.018 | bar |
| Inlet temperature | 27.94 | C |
| Cold side leakage to flue gas | 132.6 | t/h |
| Hot side leakage to flue gas | 56.85 | t/h |
| Pressure drop | 6.207 | millibar |
| Channel velocity | 8.317 | m/s |
| Reynolds number | 2914.5 | |
| Stanton number | 0.0051 | |
| Heat transfer coefficient | 50.78 | W/m ² -C |
| Flue Gas Path (station) | | |
| Flue gas flow | 2429.1 | t/h |
| Fly ash flow | 15.54 | t/h |
| Flue gas temperature | 338.4 | C |
| After mixing with hot side leakages | 336.5 | C |
| Exit temperature (uncorrected) | 144.1 | C |
| Exit temperature with leakage (corrected) | 137.8 | C |
| Exit flow | 2645.4 | t/h |
| Pressure @ heater inlet | 0.9976 | bar |
| Pressure drop | 9.101 | millibar |
| Channel velocity | 11.58 | m/s |
| Reynolds number | 3137 | |
| Stanton number | 0.0051 | |
| Heat transfer coefficient | 60.73 | W/m ² -C |
| Performance (station) | | |
| Flue gas heat transfer to air paths | 144282 | kW |
| Fly ash heat transfer to air paths | 875.2 | kW |
| Secondary air heat transfer | 137411 | kW |
| Primary air heat transfer | 7747 | kW |
| Average cold end temperature (ACET) | 86.04 | C |
| Cold end minimum metal temperature | 68.33 | C |
| Flue gas exit water dew point temperature | 39.09 | C |
| Flue gas exit SO3 | 2.014 | ppm |
| Flue gas exit sulfur dew point temperature | 118.1 | C |
| Flue gas sulfur dew point temperature within air heater | 119.1 | C |
| Heat transfer effectiveness | 77.07 | % |
| Modified number of transfer units (NTU0) | 2.602 | |

| Heat Balance Results | | | |
|--|----------------------|--|-------------------------------------|
| Stack | | | |
| Inlet | | | |
| Pressure | 0.9972 | bar | |
| Temperature | 140.9 | C | |
| Mass flow | 2645.4 | t/h | |
| Exit to air | | | |
| Pressure | 0.9823 | bar | |
| Temperature | 140.9 | C | |
| Water dew point temperature | 39.25 | C | |
| Sulfur dew point temperature | 138 | C | |
| Mass flow | 2645.4 | t/h | |
| Mercury (Hg) | 0 | kg/hr | |
| Exit Velocity | 18.29 | m/s | |
| Miscellaneous | | | |
| Heat loss | 0 | kW | |
| Buoyancy (DPc-DPh) | 5.487 | millibar | |
| -- Pressure by cold air column outside stack (DPc) | 17.67 | millibar | |
| -- Pressure by hot air column inside stack (DPh) | 12.18 | millibar | |
| Pressure drop (inlet to ambient) | -2.83 | millibar | |
| -- Entrance loss | 0.8655 | millibar | |
| -- Leaving loss | 1.443 | millibar | |
| -- Friction loss | 0.3488 | millibar | |
| -- Buoyancy gain | 5.487 | millibar | |
| Emissions | | | |
| | ng/J25C HHV @ | mg/Nm³ @ 6% O₂, dry | ppmv @ 6% O₂, dry |
| Dust load | 13.34 | 39.6 | |
| Sulfur Dioxide (SO ₂) | 393.9 | 1169.2 | 409.1 |
| Nitrogen Oxides (NO _x) | 0 | 0 | 0 |
| Mercury (Hg) | 0 | 0 | 0 |
| Plume invisible | | | |
| Plume visibility index | 0 | | |

| STEAM PRO 26.1 GHD GHD Pty Ltd | | | | | | | | | | |
|---|----------|-------------|-----------|--------|---------|-----------|----------|---------|-------|---------|
| 588 04-21-2017 16:19:10 G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp | | | | | | | | | | |
| Program revision date: February 16, 2017 | | | | | | | | | | |
| Steam source: Conventional boiler | | | | | | | | | | |
| Steam turbine: Single reheat condensing turbine 3000+3000/3000 | | | | | | | | | | |
| Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train | | | | | | | | | | |
| Cooling system: Dry air cooled condenser | | | | | | | | | | |
| Steam Property Formulation: IFC-67 | | | | | | | | | | |
| STEAM CYCLE HEAT BALANCE | | | | | | | | | | |
| Energy in = | | 1478941 | kJ/s | | | | | | | |
| Boiler Heat | External | | External | Makeup | Process | Pump | Blowdown | | | |
| Addition | Steam | | Water | | Return | Aux. Load | Recovery | | | |
| 1452916 | 0 | | 0 | 0 | 0 | 26025 | 0 | | | |
| Energy out = | | 1478941 | kJ/s | | | | | | | |
| ST/Gen | BFPT | Mech/Elec/ | Main | BFPT | Process | | Pipe | CO2 | Desal | Others* |
| Output | Output | Gear Losses | Condenser | | Steam | Water | Losses | Capture | | |
| 678764 | 24382 | 7629 | 763269 | 0 | 0 | 0 | 4015 | 0 | 0 | 883 |
| * 'Others' includes pump losses, heat to air heater, fuel heater, district heating system, misc heat to/from condensate, discharged seal steam and blowdown. | | | | | | | | | | |
| Zero enthalpy: dry gases & liquid water @ 32 F (273.15 K) | | | | | | | | | | |
| Heat Balance Error (In - Out) = | | | 0.0 | kJ/s | = | 0.0000 | % | | | |

| STEAM TURBINE FLOWS | | | | | | | | | | |
|----------------------|---------|-------|--------|----------|---------|---------------|---------|---------|---------|--------|
| | P | T | h | M | s | Super-heat, C | Quality | Exp Pwr | Eff | # of |
| | bar | C | kJ/kg | t/h | kJ/kg-K | | | kW | % | Stages |
| HP steam | 280.140 | 606.0 | 3479.9 | 1918.371 | | | | | | |
| HP pipe inlet | 280.140 | 606.0 | 3479.9 | 1918.371 | | | | | | |
| HP pipe outlet | 276.000 | 604.0 | 3477.6 | 1918.371 | | | | | | |
| ST inlet | 276.000 | 604.0 | 3477.6 | 1918.371 | 6.3065 | 211.2 | | | | |
| After HPT stop valve | 269.100 | 601.9 | 3477.6 | | | | | | | |
| -Valve Stem leak 1 | | | 3477.6 | -4.186 | | | | | | |
| -Valve Stem leak 2 | | | 3477.6 | -1.380 | | | | | | |
| -HPT HP leak 1 | | | 3477.6 | -26.321 | | | | | | |
| HPT Casing: Group 1 | | | | | | | | | | |
| GROUP IN | 269.100 | 601.9 | 3477.6 | 1886.483 | 6.3166 | 211.2 | | | 68.51* | 1 |
| GROUP OUT | 212.308 | 562.3 | 3416.5 | 1886.483 | 6.3403 | 191.6 | | 32027 | 75.61** | |
| HPT Casing: Group 2 | | | | | | | | | | |
| GROUP IN | 212.308 | 562.3 | 3416.5 | 1886.483 | 6.3403 | 191.6 | | | 88.82* | 9 |
| GROUP OUT | 64.297 | 374.5 | 3103.8 | 1886.483 | 6.4017 | 94.4 | | 163816 | 88.82** | |
| Port (1) extraction | 64.297 | 374.5 | 3103.8 | -132.426 | 6.4017 | 94.4 | | | | |
| -HPT LP leak 1 | | | 3103.8 | -11.376 | | | | | | |
| -HPT LP leak 2 | | | 3103.8 | -2.436 | | | | | | |
| Cold RH pipe inlet | 64.297 | 374.5 | 3103.8 | 1740.245 | 6.4017 | 94.4 | | | | |
| Cold RH pipe outlet | 63.036 | 372.6 | 3101.5 | 1740.245 | | | | | | |
| RH steam | 61.200 | 605.4 | 3667.7 | 1740.245 | | | | | | |
| Hot RH pipe inlet | 61.200 | 605.4 | 3667.7 | 1740.245 | | | | | | |
| Hot RH pipe outlet | 60.000 | 604.0 | 3665.3 | 1740.245 | | | | | | |
| IPT inlet | 60.000 | 604.0 | 3665.3 | 1740.245 | 7.1767 | 328.4 | | | | |
| +Valve Stem leak 1 | | | 3477.6 | 4.186 | | | | | | |
| +HPT HP leak 1 | | | 3477.6 | 26.321 | | | | | | |
| IP bowl | 58.800 | 602.2 | 3662.1 | 1770.753 | 7.1820 | 328.0 | | | | |
| IPT1 Casing: Group 3 | | | | | | | | | | |
| GROUP IN | 58.800 | 602.2 | 3662.1 | 1770.753 | 7.1820 | 328.0 | | | 82.62* | 3 |
| GROUP OUT | 42.666 | 549.8 | 3555.3 | 1770.753 | 7.2002 | 295.6 | | 52535 | 87.62** | |
| Port (3) extraction | 42.666 | 549.8 | 3555.3 | -123.163 | 7.2002 | 295.6 | | | | |
| IPT1 Casing: Group 4 | | | | | | | | | | |
| GROUP IN | 42.666 | 549.8 | 3555.3 | 1647.590 | 7.2002 | 295.6 | | | 89.23* | 4 |
| GROUP OUT | 22.902 | 454.3 | 3363.3 | 1647.590 | 7.2322 | 235.0 | | 87868 | 89.23** | |
| Port (4) extraction | 22.902 | 454.3 | 3363.3 | -65.782 | 7.2322 | 235.0 | | | | |

| IPT1 Casing: Group 5 | | | | | | | | | | |
|---|--------|-------|--------|----------|--------|-------|-------|-------|---------|---|
| GROUP IN | 22.902 | 454.3 | 3363.3 | 1581.808 | 7.2322 | 235.0 | | | 90.07* | 3 |
| GROUP OUT | 13.040 | 375.4 | 3206.9 | 1581.808 | 7.2589 | 183.7 | | 68717 | 90.07** | |
| Port (5) extraction | 13.040 | 375.4 | 3206.9 | -76.741 | 7.2589 | 183.7 | | | | |
| IPT1 Casing: Group 6 | | | | | | | | | | |
| GROUP IN | 13.040 | 375.4 | 3206.9 | 1505.068 | 7.2589 | 183.7 | | | 90.93* | 3 |
| GROUP OUT | 7.000 | 296.5 | 3052.1 | 1505.068 | 7.2862 | 131.5 | | 64710 | 90.93** | |
| Port (6) extraction | 7.000 | 296.5 | 3052.1 | -220.682 | 7.2862 | 131.5 | | | | |
| -IPT LP leak | | | 3052.1 | -2.585 | | | | | | |
| +HPT LP leak 1 | | | 3103.8 | 11.376 | | | | | | |
| LPT crossover | 7.000 | 296.7 | 3052.6 | 1293.177 | 7.2870 | 131.7 | | | | |
| LPT1 Casing: Group 7 | | | | | | | | | | |
| GROUP IN | 7.000 | 296.7 | 3052.6 | 1293.177 | 7.2870 | 131.7 | | | 91.7* | 2 |
| GROUP OUT | 3.309 | 212.4 | 2889.5 | 1293.177 | 7.3174 | 75.5 | | 58599 | 91.7** | |
| Port (7) extraction | 3.309 | 212.4 | 2889.5 | -70.109 | 7.3174 | 75.5 | | | | |
| LPT1 Casing: Group 8 | | | | | | | | | | |
| GROUP IN | 3.309 | 212.4 | 2889.5 | 1223.068 | 7.3174 | 75.5 | | | 92.74* | 2 |
| GROUP OUT | 1.380 | 127.6 | 2727.9 | 1223.068 | 7.3492 | 18.7 | | 54904 | 92.74** | |
| Port (8) extraction | 1.380 | 127.6 | 2727.9 | -66.088 | 7.3492 | 18.7 | | | | |
| LPT1 Casing: Group 9 | | | | | | | | | | |
| GROUP IN | 1.380 | 127.6 | 2727.9 | 1156.980 | 7.3492 | 18.7 | | | 92.74* | 2 |
| GROUP OUT | 0.491 | 80.9 | 2568.5 | 1156.980 | 7.3844 | | 0.967 | 51221 | 92.74** | |
| Port (9) extraction | 0.491 | 80.9 | 2568.5 | -59.989 | 7.3844 | | 0.967 | | | |
| LPT1 Casing: Group 10 | | | | | | | | | | |
| GROUP IN | 0.491 | 80.9 | 2568.5 | 1096.991 | 7.3844 | | 0.967 | | 82.75* | 2 |
| GROUP OUT | 0.118 | 49.1 | 2381.3 | 1096.991 | 7.4433 | | 0.912 | | 90.79** | |
| After LL | 0.118 | 49.1 | 2397.9 | 1096.991 | 7.4948 | | 0.919 | 51996 | | |
| To condenser | 0.118 | 49.1 | 2397.9 | 1096.991 | 7.4948 | | 0.919 | | | |
| *There are 2 symmetric IPT paths, each same as IPT1 | | | | | | | | | | |
| *The LPT mass flow rates are multiplied by 2 | | | | | | | | | | |
| * : Group overall efficiency (including control valve and/or leaving losses) | | | | | | | | | | |
| ** : Group blading efficiency (excluding control valve and/or leaving losses) | | | | | | | | | | |

| STEAM TURBINE DESIGN | | | | | | |
|-----------------------------------|---------------------------------|--------------|------------------|-----------------------|-----------------------|--|
| Group | Adj Nozzle Area, m ² | No. of Steps | Dry Step Eff., % | Group Blading Eff., % | Group Overall Eff., % | |
| 1 | 0.028 | 1 | 75.61 | 75.61 | 68.51 | |
| 2 | 0.022 | 9 | 87.38 | 88.82 | 88.82 | |
| 3 | 0.114 | 3 | 86.79 | 87.62 | 82.62 | |
| 4 | 0.116 | 4 | 88.58 | 89.23 | 89.23 | |
| 5 | 0.200 | 3 | 89.65 | 90.07 | 90.07 | |
| 6 | 0.308 | 3 | 90.53 | 90.93 | 90.93 | |
| 7 | 0.443 | 2 | 91.33 | 91.70 | 91.70 | |
| 8 | 0.795 | 2 | 92.37 | 92.74 | 92.74 | |
| 9 | 1.593 | 2 | 92.71 | 92.74 | 92.74 | |
| 10 | 3.789 | 2 | 95.00 | 90.79 | 82.75 | |
| No. of parallel paths at LPT | | 1 x 2 | | | | |
| Last stage rotor exit angle | | 63.47 | | degree | | |
| Last stage blade length | | 947.33 | | mm | | |
| Last stage pitch diameter | | 2734.07 | | mm | | |
| Exhaust annulus area / end | | 8.14 | | m ² | | |
| DRY EXHAUST LOSS | | | | | | |
| Annulus Vel | Exh Loss | Annulus Vel | Exh Loss | Annulus Vel | Exh Loss | |
| m/s | kJ/kg | m/s | kJ/kg | m/s | kJ/kg | |
| 39 | 169.61 | 122 | 45.40 | 244 | 31.18 | |
| 46 | 164.81 | 137 | 34.72 | 274 | 46.16 | |
| 53 | 158.69 | 152 | 27.32 | 305 | 64.02 | |
| 61 | 144.63 | 168 | 22.64 | 335 | 81.80 | |
| 76 | 108.02 | 183 | 20.31 | 366 | 98.44 | |
| 91 | 80.59 | 198 | 20.13 | 396 | 115.70 | |
| 107 | 60.27 | 213 | 21.97 | 427 | 134.67 | |
| EXHAUST END VELOCITIES AND LOSSES | | | | | | |
| | | LPT1 | | | | |
| Annulus velocity | | 214.4 | | m/s | | |
| Dry exhaust loss | | 22.18 | | kJ/kg | | |
| Corrected exhaust loss | | 16.60 | | kJ/kg | | |

| STEAM TURBINE CASING POWER | | |
|--|----------|----------------------|
| Casing | | Expansion Power (kW) |
| HPT | | 195843 |
| IPT1 | | 273830 |
| LPT1 x 2 | | 216720 |
| | | |
| H2 COOLED GENERATOR 50 Hz | | |
| Turbine Shaft Speed | 3000 RPM | |
| Expansion power | 686393 | kW |
| ST mechanical loss | 1716 | kW |
| ST shaft power | 684677 | kW |
| Generator efficiency | 99.14 | % |
| Generator electrical & mechanical loss | 5913.3 | kW |
| - Generator electrical & windage loss | 5161.8 | kW |
| - Generator mechanical loss | 751.5 | kW |
| Generator power | 678763.8 | kW |
| | | |

| STEAM TURBINE LEAKAGES | | | | | | |
|---|-------------------|---------------|--------------------|-------------------------|---------|--------|
| Group No. | Leakage | Destination | Leakage Flow Model | C Factor m ² | h kJ/kg | M t/h |
| 1 | Valve Stem leak 1 | IPT inlet | Automatic | 8.1 | 3477.6 | 4.186 |
| 2 | Valve Stem leak 2 | SSR | Automatic | 9.3 | 3477.6 | 1.380 |
| 4 | HPT HP leak 1 | IPT inlet | Automatic | 49.9 | 3477.6 | 26.321 |
| 7 | HPT LP leak 1 | LPT cROssover | Automatic | 75.5 | 3103.8 | 11.376 |
| 8 | HPT LP leak 2 | SSR | Automatic | 123.1 | 3103.8 | 2.436 |
| 16 | IPT LP leak | SSR | Automatic | 63.9 | 3052.1 | 2.585 |
| SEALING STEAM REGULATOR & GLAND SEAL CONDENSER (IF ANY) | | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | | |
| Valve Stem leak 2 | | | 3477.6 | 1.38 | | |
| HPT LP leak 2 | | | 3103.8 | 2.436 | | |
| IPT LP leak | | | 3052.1 | 2.585 | | |
| Steam at SSR inlet | 1.241 | 344.4 | 3163.6 | 6.401 | | |
| LPT SS to condenser | | | 3163.6 | 0.5443 | | |
| LPT SS packing exhaust to GSC | | | 3163.6 | 0.6349 | | |
| SS to FWH1 from SSR | | | 3163.6 | 5.222 | | |
| Steam at GSC inlet | 0.8274 | 344.0 | 3163.6 | 0.6349 | | |
| GSC drain to Condenser | | | 395.5 | 0.6349 | | |

| CONDENSER: Dry air cooled condenser | | | | |
|-------------------------------------|--------|-------|--------|--------|
| | P | T | h | M |
| | bar | C | kJ/kg | t/h |
| LPT exhaust | 0.1181 | 49.12 | 2397.9 | 1097 |
| LPT SS to condenser | | | 3163.6 | 0.5443 |
| FPT exhaust | 0.1073 | 47.22 | 2453.9 | 147.3 |
| Drain from GSC | 0.827 | 94.47 | 395.5 | 0.6349 |
| Condenser in | 0.1073 | 47.22 | 2403.8 | 1245.5 |
| Condensate | 0.4064 | 47.22 | 197.6 | 1245.5 |
| Cooling air in | | 25.00 | | 173425 |
| Cooling air out | | 40.56 | | 173425 |
| Main condenser heat rejection = | 763268 | | kJ/s | |

| CONDENSATE, MAKEUP WATER & FEEDWATER | | | | | |
|---|--------|---------|-------|--------|----------------|
| | P | T | h | M | |
| | bar | C | kJ/kg | t/h | |
| Condenser condensate | 0.4064 | 47.22 | 197.6 | 1245.5 | |
| Condensate pump suction | 0.4064 | 47.22 | 197.6 | 1245.5 | |
| Condensate pump exit | 21.15 | 47.50 | 200.6 | 1245.5 | |
| To SJAE, GSC & recovery heat exchangers | 21.15 | 47.50 | 200.6 | 1245.5 | |
| -Enthalpy change due to GSC | | | 1.41 | | |
| Feedwater to 1st feedwater heater | 21.15 | 47.84 | 202.0 | 1245.5 | |
| | | | | | |
| BOILER FEED PUMP TURBINE (Condensing) | | | | | |
| The plant has 1 boiler feed pump turbine in operation | | | | | |
| Stream | (Port) | P | T | h | M |
| | | bar | C | kJ/kg | t/h |
| Turbine inlet from LPT cross | (6) | 6.667 | 294.9 | 3049.8 | 147.3 |
| 1st group inlet | | 5.333 | 293.3 | 3049.8 | 147.3 |
| Exhaust to main condenser | | 0.1073 | 47.2 | 2453.9 | 147.3 |
| | | | | | |
| Boiler feed pump shaft power = | | 24137.9 | | | kW |
| Feed pump turbine power = | | 24381.8 | | | kW |
| Feed pump turbine efficiency = | | 82.08 | | | % |
| Group 1 adjusted nozzle area = | | 0.058 | | | m ² |
| Number of steps in Group 1 = | | 6 | | | |

| HP casing - Group 1 | | |
|--------------------------------|--------|-------------------|
| Number of governing stage rows | 1 | |
| Governing stage pitch diameter | 1.165 | m |
| Number of paths | 1 | |
| Number of stages | 1 | |
| Dry step efficiency | 75.61 | % |
| Group efficiency | 68.51 | % |
| Group inlet mass flow | 1886.5 | t/h |
| Shaft speed | 3000 | RPM |
| Before Valve | | |
| Pressure | 276 | bar |
| Temperature | 604 | C |
| Enthalpy | 3478 | kJ/kg |
| Blading Inlet | | |
| Pressure | 269.1 | bar |
| Temperature | 601.9 | C |
| Enthalpy | 3478 | kJ/kg |
| Volume flow | 6.827 | m ³ /s |
| Nozzle area | 0.0281 | m ² |
| Blading Exit | | |
| Pressure | 212.3 | bar |
| Temperature | 562.3 | C |
| Enthalpy | 3416 | kJ/kg |
| Volume flow | 8.298 | m ³ /s |

| | | |
|----------------------------|--------|-------------------|
| HP casing - Group 2 | | |
| Number of paths | 1 | |
| Number of stages | 9 | |
| Dry step efficiency | 87.38 | % |
| Group efficiency | 88.82 | % |
| Group inlet mass flow | 1886.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 212.3 | bar |
| Temperature | 562.3 | C |
| Enthalpy | 3416 | kJ/kg |
| Volume flow | 8.298 | m ³ /s |
| Nozzle area | 0.0225 | m ² |
| Blading Exit | | |
| Pressure | 64.3 | bar |
| Temperature | 374.5 | C |
| Enthalpy | 3104 | kJ/kg |
| Volume flow | 21.72 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 64.3 | bar |
| Temperature | 374.5 | C |
| Enthalpy | 3104 | kJ/kg |
| Extraction mass flow | 132.4 | t/h |

| | | |
|----------------------------------|-------|-------------------|
| IP casing - Group 3 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 86.79 | % |
| Group efficiency | 82.62 | % |
| Group inlet mass flow (per path) | 885.4 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 58.8 | bar |
| Temperature | 602.2 | C |
| Enthalpy | 3662 | kJ/kg |
| Volume flow (per path) | 16.41 | m ³ /s |
| Nozzle area (per path) | 0.057 | m ² |
| Blading Exit | | |
| Pressure | 42.67 | bar |
| Temperature | 549.8 | C |
| Enthalpy | 3555 | kJ/kg |
| Volume flow (per path) | 21.31 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 42.67 | bar |
| Temperature | 549.8 | C |
| Enthalpy | 3555 | kJ/kg |
| Extraction mass flow (per path) | 61.58 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 4 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 4 | |
| Dry step efficiency | 88.58 | % |
| Group efficiency | 89.23 | % |
| Group inlet mass flow (per path) | 823.8 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 42.67 | bar |
| Temperature | 549.8 | C |
| Enthalpy | 3555 | kJ/kg |
| Volume flow (per path) | 19.83 | m ³ /s |
| Nozzle area (per path) | 0.0579 | m ² |
| Blading Exit | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Volume flow (per path) | 32.77 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Extraction mass flow (per path) | 32.89 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 5 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 89.65 | % |
| Group efficiency | 90.07 | % |
| Group inlet mass flow (per path) | 790.9 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 22.9 | bar |
| Temperature | 454.3 | C |
| Enthalpy | 3363 | kJ/kg |
| Volume flow (per path) | 31.46 | m ³ /s |
| Nozzle area (per path) | 0.1001 | m ² |
| Blading Exit | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Volume flow (per path) | 49.41 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Extraction mass flow (per path) | 38.37 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| IP casing - Group 6 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 3 | |
| Dry step efficiency | 90.53 | % |
| Group efficiency | 90.93 | % |
| Group inlet mass flow (per path) | 752.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 13.04 | bar |
| Temperature | 375.4 | C |
| Enthalpy | 3207 | kJ/kg |
| Volume flow (per path) | 47.01 | m ³ /s |
| Nozzle area (per path) | 0.1541 | m ² |
| Blading Exit | | |
| Pressure | 7 | bar |
| Temperature | 296.5 | C |
| Enthalpy | 3052 | kJ/kg |
| Volume flow (per path) | 77.12 | m ³ /s |

| | | |
|-----------------------------------|--------|-------------------|
| LP casing - Group 7 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 91.33 | % |
| Group efficiency | 91.7 | % |
| Group inlet mass flow (per path) | 646.6 | t/h |
| Shaft speed | 3000 | RPM |
| Port upstream of LP casing | | |
| Pressure | 7 | bar |
| Temperature | 296.5 | C |
| Enthalpy | 3052 | kJ/kg |
| Extraction mass flow | 220.7 | t/h |
| Blading Inlet | | |
| Pressure | 7 | bar |
| Temperature | 296.7 | C |
| Enthalpy | 3053 | kJ/kg |
| Volume flow (per path) | 66.29 | m ³ /s |
| Nozzle area (per path) | 0.2216 | m ² |
| Blading Exit | | |
| Pressure | 3.309 | bar |
| Temperature | 212.4 | C |
| Enthalpy | 2889.5 | kJ/kg |
| Volume flow (per path) | 119.7 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 3.309 | bar |
| Temperature | 212.4 | C |
| Enthalpy | 2889.5 | kJ/kg |
| Extraction mass flow (per path) | 35.05 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 8 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 92.37 | % |
| Group efficiency | 92.74 | % |
| Group inlet mass flow (per path) | 611.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 3.309 | bar |
| Temperature | 212.4 | C |
| Enthalpy | 2889.5 | kJ/kg |
| Volume flow (per path) | 113.3 | m ³ /s |
| Nozzle area (per path) | 0.3973 | m ² |
| Blading Exit | | |
| Pressure | 1.38 | bar |
| Temperature | 127.6 | C |
| Enthalpy | 2727.9 | kJ/kg |
| Volume flow (per path) | 224.2 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 1.38 | bar |
| Temperature | 127.6 | C |
| Enthalpy | 2727.9 | kJ/kg |
| Extraction mass flow (per path) | 33.04 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 9 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 92.71 | % |
| Group efficiency | 92.74 | % |
| Group inlet mass flow (per path) | 578.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 1.38 | bar |
| Temperature | 127.6 | C |
| Enthalpy | 2727.9 | kJ/kg |
| Volume flow (per path) | 212.1 | m ³ /s |
| Nozzle area (per path) | 0.7964 | m ² |
| Blading Exit | | |
| Pressure | 0.4907 | bar |
| Temperature | 80.88 | C |
| Enthalpy | 2568.5 | kJ/kg |
| Volume flow (per path) | 512.3 | m ³ /s |
| Port at Group Exit | | |
| Pressure | 0.4907 | bar |
| Temperature | 80.88 | C |
| Enthalpy | 2568.5 | kJ/kg |
| Extraction mass flow (per path) | 29.99 | t/h |

| | | |
|----------------------------------|--------|-------------------|
| LP casing - Group 10 | | |
| Number of paths | 2 | |
| Number of stages (per path) | 2 | |
| Dry step efficiency | 95 | % |
| Group efficiency | 82.75 | % |
| Group inlet mass flow (per path) | 548.5 | t/h |
| Shaft speed | 3000 | RPM |
| Blading Inlet | | |
| Pressure | 0.4907 | bar |
| Temperature | 80.88 | C |
| Enthalpy | 2568.5 | kJ/kg |
| Volume flow (per path) | 485.8 | m ³ /s |
| Nozzle area (per path) | 1.895 | m ² |
| Blading Exit | | |
| Pressure | 0.1181 | bar |
| Temperature | 49.12 | C |
| Enthalpy | 2381.3 | kJ/kg |
| Volume flow (per path) | 1744.9 | m ³ /s |
| Annulus area (per path) | 8.137 | m ² |
| Annulus velocity | 214.4 | m/s |
| Pitch Diameter | 2734.1 | mm |
| Bucket Length | 947.3 | mm |
| Pitch Speed | 429.5 | m/s |
| Tip Speed | 578.3 | m/s |
| After leaving loss | | |
| Pressure | 0.1181 | bar |
| Temperature | 49.12 | C |
| Enthalpy | 2397.9 | kJ/kg |

STEAM PRO 26.1 GHD GHD Pty Ltd
 588 04-21-2017 16:19:10 G:\41\30763\Tech\HELE documentation\Model\USC model_dry cooling.stp
 Program revision date: February 16, 2017
 Steam source: Conventional boiler
 Steam turbine: Single reheat condensing turbine 3000+3000/3000
 Feedwater heaters: SDDDCDDDP, single LP FWH train & double HP FWH train
 Cooling system: Dry air cooled condenser
 Steam Property Formulation: IFC-67

THERMAL OUTPUT

FWH1: Pump Forward

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|------|-------|--------|-------------------|--------|------|--------|-------|------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 21.15 | 47.8 | 202.0 | 1245.5 | LPT1 port (9) | 0.4907 | 80.9 | 2568.5 | 59.99 | |
| | | | | | Steam in | 0.4673 | 79.7 | 2566.2 | 59.99 | 79.7 |
| | | | | | Flash back | | | 345.2 | 209.6 | |
| Feedwater out | 19.34 | 76.9 | 323.4 | 1245.5 | SSR seal steam | | | 3163.6 | 5.222 | |
| | | | | | Drain before pump | 0.4673 | 79.7 | 333.5 | 274.8 | |
| | | | | | Drain to FWH2 | 19.34 | | 335.9 | 274.8 | |
| Terminal temperature difference = | | | 2.77 | | C | | | | | |

FWH2: Flash Back with Drain Cooler

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|-------|-------|--------|---------------|-------|-------|--------|-------|-------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| | | | | | LPT1 port (8) | 1.38 | 127.6 | 2727.9 | 66.09 | |
| FWH1 drain | | | 335.9 | 274.8 | | | | | | |
| Feedwater in | 19.34 | 77.4 | 325.6 | 1520.3 | Steam in | 1.314 | 126.2 | 2725.5 | 66.09 | 107.4 |
| | | | | | Flash back | | | 460.0 | 143.5 | |
| Feedwater out | 17.59 | 104.7 | 440.0 | 1520.3 | Drain to FWH1 | 1.314 | 82.4 | 345.2 | 209.6 | |
| Terminal temperature difference = | | | 2.78 | | C | | | | | |
| Drain cooler approach = | | | 5.00 | | C | | | | | |

FWH3: Flash Back with Drain Cooler

| Feedwater | | | | | Bleed Steam | | | | | |
|-----------------------------------|-------|-------|-------|--------|---------------|-------|-------|--------|-------|-------|
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| | | | | | LPT1 port (7) | 3.309 | 212.4 | 2889.5 | 70.11 | |
| Feedwater in | 17.59 | 104.7 | 440.0 | 1520.3 | Steam in | 3.151 | 210.9 | 2887.1 | 70.11 | 135.2 |
| | | | | | Flash back | | | 578.3 | 73.38 | |
| Feedwater out | 16.14 | 132.4 | 557.6 | 1520.3 | Drain to FWH2 | 3.151 | 109.7 | 460.0 | 143.5 | |
| Terminal temperature difference = | | | 2.78 | | C | | | | | |
| Drain cooler approach = | | | 5.00 | | C | | | | | |

| FWH4: Flash Back with Drain Cooler | | | | | | | | | | |
|------------------------------------|----------|--------|------------|----------|--------------------|----------|--------|------------|----------|-----------|
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 16.14 | 132.4 | 557.6 | 1520.3 | LPT cross port (6) | 7 | 296.5 | 3052.1 | 73.38 | |
| Feedwater out | 14.9 | 160.2 | 676.9 | 1520.3 | Steam in | 6.667 | 294.9 | 3049.8 | 73.38 | 163.0 |
| | | | | | Drain to FWH3 | 6.667 | 137.4 | 578.3 | 73.38 | |
| Terminal temperature difference = | | | 2.78 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |
| FWH5: Deaerator | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 12.66 | 160.3 | 676.9 | 1520.3 | IPT1 port (5) | 13.04 | 375.4 | 3206.9 | 76.74 | |
| Feedwater out | 12.66 | 190.4 | 809.2 | 1918.4 | Steam in | 12.66 | 374.0 | 3204.6 | 76.74 | 190.4 |
| Booster pump in | 14.9 | 190.4 | 809.2 | 1918.4 | Flash back | | | 863.3 | 321.4 | |
| FW pump in | 22.38 | 190.5 | 810.3 | 1918.4 | | | | | | |
| FW pump out | 308.7 | 197.4 | 854.1 | 1918.4 | | | | | | |
| FWH6: Flash Back with Drain Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 308.7 | 197.4 | 854.1 | 1918.4 | IPT1 port (4) | 22.9 | 454.3 | 3363.3 | 65.78 | |
| Feedwater out | 308 | 220.1 | 953.7 | 1918.4 | Steam in | 22.24 | 452.9 | 3361.0 | 65.78 | 217.8 |
| | | | | | Flash back | | | 967.5 | 255.6 | |
| | | | | | Drain to FWH5 | 22.24 | 202.4 | 863.3 | 321.4 | |
| Terminal temperature difference = | | | -2.28 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |
| FWH7: Flash Back with Drain Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P bar | T C | h kJ/kg | M t/h | Stream | P bar | T C | h kJ/kg | M t/h | Tsat C |
| Feedwater in | 308 | 220.1 | 953.7 | 1918.4 | Sup. cooler exit | 41.42 | 302.4 | 2963.9 | 123.2 | |
| Feedwater out | 307.4 | 250.7 | 1091.9 | 1918.4 | Steam in | 41.42 | 302.4 | 2963.9 | 123.2 | 252.4 |
| | | | | | Flash back | | | 1113.7 | 132.4 | |
| | | | | | Drain to FWH6 | 41.42 | 225.1 | 967.5 | 255.6 | |
| Terminal temperature difference = | | | 1.67 | | | | | | | C |
| Drain cooler approach = | | | 5.00 | | | | | | | C |

| FWH8: Flash Back with Drain Cooler | | | | | | | | | | |
|------------------------------------|-------|-------|--------|--------|-------------------|-------|-------|--------|-------|-------|
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 307.4 | 250.7 | 1091.9 | 1918.4 | HPT exit port (1) | 64.3 | 374.5 | 3103.8 | 132.4 | |
| Feedwater out | 306.8 | 279.9 | 1229.2 | 1918.4 | Steam in | 62.42 | 372.1 | 3101.5 | 132.4 | 278.1 |
| | | | | | Drain to FWH7 | 62.42 | 255.7 | 1113.7 | 132.4 | |
| Terminal temperature difference = | | | -1.78 | C | | | | | | |
| Drain cooler approach = | | | 5.00 | C | | | | | | |
| FWH9: Superheat Cooler | | | | | | | | | | |
| Feedwater | | | | | Bleed Steam | | | | | |
| Stream | P | T | h | M | Stream | P | T | h | M | Tsat |
| | bar | C | kJ/kg | t/h | | bar | C | kJ/kg | t/h | C |
| Feedwater in | 306.8 | 279.9 | 1229.2 | 1918.4 | IPT1 port (3) | 42.67 | 549.8 | 3555.3 | 123.2 | |
| Feedwater out | 306.7 | 287.7 | 1267.0 | 1918.4 | Steam in | 41.42 | 548.2 | 3553.0 | 123.2 | 252.4 |
| To boiler | 306.7 | 287.7 | 1267.0 | 1918.4 | Drain to FWH7 | 41.42 | 302.4 | 2963.9 | 123.2 | |
| Total bleed steam for FWH system = | | | 667.7 | t/h | 577001 | kJ/s | | | | |

| DESIGN PARAMETERS OF FEEDWATER HEATERS | | | |
|---|--|--------|---------------------|
| FWH1: Pump Forward | | | |
| 1. Heat transfer rate Q | | 41990 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 2837 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 0 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 | m ² |
| 6. Condensing section heat transfer area | | 1243 | m ² |
| 7. Drain cooler heat transfer area | | 0 | m ² |
| 8. Total heat transfer area | | 1243 | m ² |
| 9. Water velocity | | 2.90 | m/s |
| 10. Tube outer diameter | | 19.050 | mm |
| 11. Tube wall thickness | | 1.245 | mm |
| 12. Tube length per pass | | 18.4 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 1128 | |
| 15. Tube material | | TP 304 | |
| 16. Terminal temperature difference (TTD) | | 2.774 | C |
| 17. Drain cooler approach (DCA) | | N/A | |
| FWH2: Flash Back with Drain Cooler | | | |
| 1. Heat transfer rate Q | | 48275 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3173 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1328 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 | m ² |
| 6. Condensing section heat transfer area | | 1261 | m ² |
| 7. Drain cooler heat transfer area | | 378 | m ² |
| 8. Total heat transfer area | | 1640 | m ² |
| 9. Water velocity | | 2.90 | m/s |
| 10. Tube outer diameter | | 19.050 | mm |
| 11. Tube wall thickness | | 1.245 | mm |
| 12. Tube length per pass | | 19.5 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 1402 | |
| 15. Tube material | | TP 304 | |
| 16. Terminal temperature difference (TTD) | | 2.776 | C |
| 17. Drain cooler approach (DCA) | | 5 | C |

| FWH3: Flash Back with Drain Cooler | | |
|---|--|--------------------------|
| 1. Heat transfer rate Q | | 49680 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3440 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1279 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1204 m ² |
| 7. Drain cooler heat transfer area | | 262 m ² |
| 8. Total heat transfer area | | 1466 m ² |
| 9. Water velocity | | 2.90 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 1.245 mm |
| 12. Tube length per pass | | 17.1 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 1432 |
| 15. Tube material | | TP 304 |
| 16. Terminal temperature difference (TTD) | | 2.777 C |
| 17. Drain cooler approach (DCA) | | 5 C |
| FWH4: Flash Back with Drain Cooler | | |
| 1. Heat transfer rate Q | | 50380 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3647 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 979 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1172 m ² |
| 7. Drain cooler heat transfer area | | 170 m ² |
| 8. Total heat transfer area | | 1342 m ² |
| 9. Water velocity | | 2.90 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 1.245 mm |
| 12. Tube length per pass | | 15.3 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 1470 |
| 15. Tube material | | TP 304 |
| 16. Terminal temperature difference (TTD) | | 2.778 C |
| 17. Drain cooler approach (DCA) | | 5 C |

| FWH5: Deaerator | | |
|---|--|--------------------------|
| 1. Heat transfer rate Q | | 55885 kJ/s |
| FWH6: Flash Back with Drain Cooler (Each of FWH6A, FWH6B) | | |
| 1. Heat transfer rate Q | | 26522 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 491 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 2948 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1120 W/m ² -K |
| 5. Desuperheater heat transfer area | | 106 m ² |
| 6. Condensing section heat transfer area | | 941 m ² |
| 7. Drain cooler heat transfer area | | 289 m ² |
| 8. Total heat transfer area | | 1336 m ² |
| 9. Water velocity | | 2.21 m/s |
| 10. Tube outer diameter | | 22.225 mm |
| 11. Tube wall thickness | | 3.810 mm |
| 12. Tube length per pass | | 11.7 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 1642 |
| 15. Tube material | | Carbon steel |
| 16. Terminal temperature difference (TTD) | | -2.277 C |
| 17. Drain cooler approach (DCA) | | 5 C |
| FWH7: Flash Back with Drain Cooler (Each of FWH7A, FWH7B) | | |
| 1. Heat transfer rate Q | | 36837 kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 0 W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 3021 W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 1116 W/m ² -K |
| 5. Desuperheater heat transfer area | | 0 m ² |
| 6. Condensing section heat transfer area | | 1129 m ² |
| 7. Drain cooler heat transfer area | | 327 m ² |
| 8. Total heat transfer area | | 1455 m ² |
| 9. Water velocity | | 2.21 m/s |
| 10. Tube outer diameter | | 19.050 mm |
| 11. Tube wall thickness | | 3.404 mm |
| 12. Tube length per pass | | 10.0 m |
| 13. No. of passes | | 2 |
| 14. No. of tubes | | 2422 |
| 15. Tube material | | Carbon steel |
| 16. Terminal temperature difference (TTD) | | 1.667 C |
| 17. Drain cooler approach (DCA) | | 5 C |

| FWH8: Flash Back with Drain Cooler (Each of FWH8A, FWH8B) | | | |
|---|--|--------------|---------------------|
| 1. Heat transfer rate Q | | 36562 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 749 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 2929 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 735 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 119 | m ² |
| 6. Condensing section heat transfer area | | 1173 | m ² |
| 7. Drain cooler heat transfer area | | 229 | m ² |
| 8. Total heat transfer area | | 1521 | m ² |
| 9. Water velocity | | 2.21 | m/s |
| 10. Tube outer diameter | | 22.225 | mm |
| 11. Tube wall thickness | | 3.810 | mm |
| 12. Tube length per pass | | 12.2 | m |
| 13. No. of passes | | 2 | |
| 14. No. of tubes | | 1786 | |
| 15. Tube material | | Carbon steel | |
| 16. Terminal temperature difference (TTD) | | -1.781 | C |
| 17. Drain cooler approach (DCA) | | 5 | C |
| FWH9: Superheat Cooler (Each of FWH9A, FWH9B) | | | |
| 1. Heat transfer rate Q | | 10078 | kJ/s |
| 2. Overall h.t.c. in desuperheating section | | 505 | W/m ² -K |
| 3. Overall h.t.c. in condensing section | | 0 | W/m ² -K |
| 4. Overall h.t.c. in drain cooling section | | 0 | W/m ² -K |
| 5. Desuperheater heat transfer area | | 209 | m ² |
| 6. Condensing section heat transfer area | | 0 | m ² |
| 7. Drain cooler heat transfer area | | 0 | m ² |
| 8. Total heat transfer area | | 209 | m ² |
| 9. Water velocity | | 2.21 | m/s |
| 10. Tube outer diameter | | 22.225 | mm |
| 11. Tube wall thickness | | 4.191 | mm |
| 12. Tube length per pass | | 2.9 | m |
| 13. No. of passes | | 1 | |
| 14. No. of tubes | | 1029 | |
| 15. Tube material | | Carbon steel | |
| 16. Terminal temperature difference (TTD) | | N/A | |
| 17. Drain cooler approach (DCA) | | N/A | |

| FWH Hardware | FWH 1 | FWH 2 | FWH 3 | FWH 4 | FWH 5 | FWH 6 | FWH 7 | FWH 8 | FWH 9 |
|---|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| 1. Type | P | D | D | D | C | D | D | D | S |
| 2. Tube material | TP 304 | TP 304 | TP 304 | TP 304 | | Carbon steel | Carbon steel | Carbon steel | Carbon steel |
| 3. Tube outer diameter [mm] | 19.05 | 19.05 | 19.05 | 19.05 | | 22.23 | 19.05 | 22.23 | 22.23 |
| 4. Tube length (per pass) [m] | 18.41 | 19.54 | 17.1 | 15.25 | | 11.65 | 10.04 | 12.2 | 2.902 |
| 5. Number of tubes | 1128 | 1402 | 1432 | 1470 | | 1642 | 2422 | 1786 | 1029 |
| 6. Total heat transfer area [m ²] | 1242.5 | 1639.6 | 1465.7 | 1341.7 | | 1336.1 | 1455.5 | 1521.2 | 208.5 |
| 7. Number of passes | 2 | 2 | 2 | 2 | | 2 | 2 | 2 | 1 |
| 8. Tube wall thickness [mm] | 1.245 | 1.245 | 1.245 | 1.245 | | 3.81 | 3.404 | 3.81 | 4.191 |
| 9. Tube pitch [mm] | 30.48 | 29.53 | 27.62 | 27.62 | | 32.23 | 25.72 | 32.23 | 30 |
| 10. Tube thermal cond. @ 300 F [W/m-C] | 16.61 | 16.61 | 16.61 | 16.61 | | 49.5 | 49.5 | 49.5 | 49.5 |
| 11. Tube thermal conductivity slope [W/m-C ²] | 0.0125 | 0.0125 | 0.0125 | 0.0125 | | -0.0249 | -0.0249 | -0.0249 | -0.0249 |
| 12. Fouling resistance [m ² -C/W] | 0 | 0 | 0 | 0 | | 0 | 0 | 0 | 0 |
| 13. Desuperheater heat transfer area [m ²] | 0 | 0 | 0 | 0 | | 106.1 | 0 | 119 | 208.5 |
| 14. Condensing heat transfer area [m ²] | 1242.5 | 1261.2 | 1203.8 | 1172.1 | | 940.6 | 1128.6 | 1172.7 | 0 |
| 15. Drain cooler heat transfer area [m ²] | 0 | 378.3 | 261.9 | 169.6 | | 289.4 | 326.8 | 229.4 | 0 |

| FWH 1 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Pump Forward Heater | | | | |
| Saturation temperature | | 79.67 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 9 | 0.49 | 80.9 | 2568.5 | 59.990 |
| Heating steam into heater (after piping) | 0.47 | 79.7 | 2566.2 | 59.990 |
| Flash in | | | 345.2 | 209.600 |
| Steam from Sealing Steam Regulator | | | 3164.0 | 5.222 |
| Exit Drain | | | | |
| FWH 1 drain to FWH 2 | 0.47 | 79.7 | 333.5 | 274.800 |
| Feedwater | | | | |
| Feedwater into heater | 21.15 | 47.8 | 202.0 | 1245.500 |
| Feedwater leaving heater | 19.34 | 76.9 | 323.4 | 1245.500 |

| FWH 2 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 107.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 8 | 1.38 | 127.6 | 2727.9 | 66.090 |
| Heating steam into heater (after piping) | 1.31 | 126.2 | 2725.5 | 66.090 |
| Flash in | | | 460.0 | 143.500 |
| Exit Drain | | | | |
| FWH 2 drain to FWH 1 | 1.31 | 82.4 | 345.2 | 209.600 |
| Feedwater | | | | |
| Drain from FWH1 | | | 335.9 | 274.800 |
| Feedwater into heater | 19.34 | 77.4 | 325.6 | 1520.300 |
| Feedwater leaving heater | 17.59 | 104.7 | 440.0 | 1520.300 |

| FWH 3 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 135.2 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT1 - Port 7 | 3.31 | 212.4 | 2889.5 | 70.110 |
| Heating steam into heater (after piping) | 3.15 | 210.9 | 2887.1 | 70.110 |
| Flash in | | | 578.3 | 73.380 |
| Exit Drain | | | | |
| FWH 3 drain to FWH 2 | 3.15 | 109.7 | 460.0 | 143.500 |
| Feedwater | | | | |
| Feedwater into heater | 17.59 | 104.7 | 440.0 | 1520.300 |
| Feedwater leaving heater | 16.14 | 132.4 | 557.6 | 1520.300 |

| FWH 4 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 163 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from LPT cross - Port 6 | 7.00 | 296.5 | 3052.0 | 73.380 |
| Heating steam into heater (after piping) | 6.67 | 294.9 | 3050.0 | 73.380 |
| Exit Drain | | | | |
| FWH 4 drain to FWH 3 | 6.67 | 137.4 | 578.3 | 73.380 |
| Feedwater | | | | |
| Feedwater into heater | 16.14 | 132.4 | 557.6 | 1520.300 |
| Feedwater leaving heater | 14.90 | 160.2 | 676.9 | 1520.300 |

| FWH 5 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Type: Contact Heater | | | | |
| Saturation temperature | | 190.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 5 | 13.04 | 375.4 | 3207.0 | 76.740 |
| Heating steam into heater (after piping) | 12.66 | 374.0 | 3205.0 | 76.740 |
| Flash in | | | 863.3 | 321.400 |
| Feedwater | | | | |
| Feedwater into heater | 12.66 | 160.3 | 676.9 | 1520.300 |
| Feedwater leaving heater | 12.66 | 190.4 | 809.2 | 1918.400 |
| Boiler feedpump delivery | 308.70 | 197.4 | 854.1 | 1918.400 |

| FWH 6 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 6A & 6B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 217.8 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 4 | 22.90 | 454.3 | 3363.0 | 65.780 |
| Heating steam into heater (after piping) | 22.24 | 452.9 | 3361.0 | 65.780 |
| Flash in | | | 967.5 | 255.600 |
| Exit Drain | | | | |
| FWH 6 drain to FWH 5 | 22.24 | 202.4 | 863.3 | 321.400 |
| Feedwater | | | | |
| Feedwater into heater | 308.70 | 197.4 | 854.1 | 1918.400 |
| Feedwater leaving heater | 308.00 | 220.1 | 953.7 | 1918.400 |

| FWH 7 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 7A & 7B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 252.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Steam from superheat cooler exit | 41.42 | 302.4 | 2963.9 | 123.200 |
| Heating steam into heater (after piping) | 41.42 | 302.4 | 2963.9 | 123.200 |
| Flash in | | | 1113.7 | 132.400 |
| Exit Drain | | | | |
| FWH 7 drain to FWH 6 | 41.42 | 225.1 | 967.5 | 255.600 |
| Feedwater | | | | |
| Feedwater into heater | 308.00 | 220.1 | 953.7 | 1918.400 |
| Feedwater leaving heater | 307.40 | 250.7 | 1091.9 | 1918.400 |

| FWH 8 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 8A & 8B) | | | | |
| Type: Flash Back with Drain Cooler | | | | |
| Saturation temperature | | 278.1 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from HPT exit - Port 1 | 64.30 | 374.5 | 3104.0 | 132.400 |
| Heating steam into heater (after piping) | 62.42 | 372.1 | 3102.0 | 132.400 |
| Exit Drain | | | | |
| FWH 8 drain to FWH 7 | 62.42 | 255.7 | 1113.7 | 132.400 |
| Feedwater | | | | |
| Feedwater into heater | 307.40 | 250.7 | 1091.9 | 1918.400 |
| Feedwater leaving heater | 306.80 | 279.9 | 1229.2 | 1918.400 |

| FWH 9 Thermodynamic Design | p [bar] | T [C] | h [kJ/kg] | m [t/h] |
|---|----------------|--------------|------------------|----------------|
| Total of two units (FWH 9A & 9B) | | | | |
| Type: External Desuperheater | | | | |
| Saturation temperature | | 252.4 | | |
| Inlet Steam & Flash In Streams | | | | |
| Heating steam from IPT1 - Port 3 | 42.67 | 549.8 | 3555.0 | 123.200 |
| Heating steam into heater (after piping) | 41.42 | 548.2 | 3553.0 | 123.200 |
| Exit Drain | | | | |
| FWH 9 drain to FWH 7 | 41.42 | 302.4 | 2963.9 | 123.200 |
| Feedwater | | | | |
| Feedwater into heater | 306.80 | 279.9 | 1229.2 | 1918.400 |
| Feedwater leaving heater | 306.70 | 287.7 | 1267.0 | 1918.400 |
| Feedwater to boiler | 306.70 | 287.7 | 1267.0 | 1918.400 |

| CONDENSER: Dry air cooled condenser | | | | |
|-------------------------------------|--------|-------|--------|--------|
| | P | T | h | M |
| | bar | C | kJ/kg | t/h |
| LPT exhaust | 0.1181 | 49.12 | 2397.9 | 1097 |
| LPT SS to condenser | | | 3163.6 | 0.5443 |
| FPT exhaust | 0.1073 | 47.22 | 2453.9 | 147.3 |
| Drain from GSC | 0.827 | 94.47 | 395.5 | 0.6349 |
| Condenser in | 0.1073 | 47.22 | 2403.8 | 1245.5 |
| Condensate | 0.4064 | 47.22 | 197.6 | 1245.5 |
| Cooling air in | | 25.00 | | 173425 |
| Cooling air out | | 40.56 | | 173425 |
| Main condenser heat rejection = | 763268 | | kJ/s | |

| | | |
|---|---------------|--------------------|
| Dry air-cooled condenser | | |
| Heat Balance | | |
| Quantities are for all cells if not otherwise noted | | |
| Total number of existing cells | 64 | |
| Total number of operating cells | 64 | |
| Condenser pressure | 0.1073 | bar |
| Condenser saturation temperature | 47.22 | C |
| Condenser heat rejection | 763268 | kW |
| Air draft loss across tube bundles | 0.8245 | millibar |
| Air face velocity | 2.286 | m/s |
| Inlet Steam | | |
| Pressure | 0.1073 | bar |
| Temperature | 47.22 | C |
| Mass flow | 1245.5 | t/h |
| Enthalpy | 2403.8 | kJ/kg |
| Condensate @ bottom of hotwell | | |
| Pressure | 0.4064 | bar |
| Temperature | 47.22 | C |
| Mass flow | 1245.5 | t/h |
| Enthalpy | 197.6 | kJ/kg |
| Cooling Air | | |
| Inlet air | | |
| Temperature | 25 | C |
| Mass flow | 173425 | t/h |
| Exit air | | |
| Temperature | 40.56 | C |
| Mass flow | 173425 | t/h |
| Fans | | |
| Total mass flow | 173425 | t/h |
| Total fan volume flow | 41517 | m ³ /s |
| Total fan electricity consumption | 7014 | kW |
| Full speed fans | | |
| Air axial velocity | 8.217 | m/s |
| Static pressure drop | 0.8245 | millibar |
| Dynamic pressure | 0.3911 | millibar |
| Total fan DP | 1.216 | millibar |
| Flash-in Stream | | |
| Mass flow | 0 | t/h |
| Hardware | | |
| Tubes | | |
| Tube geometry | Rectangular | |
| Fin-tube type | Solid fins | |
| Tube arrangement | In line | |
| Tube material | Galvanized CS | |
| Number of tube rows (longitudinal) | 1 | |
| Number of tubes per row (transverse) | 221 | |
| Number of rows per waterside flow pass | 1 | |
| Gas path transverse width | 13.15 | m |
| Tube length | 10.79 | m |
| Tube outer width | 20 | mm |
| Tube outer height | 200 | mm |
| Tube wall thickness | 1.905 | mm |
| Transverse tube pitch | 59.52 | mm |
| Tube metal conductivity @ 500F (260C) | 46.73 | W/m-C |
| Tube metal conductivity slope | -0.0249 | W/m-C ² |
| Fins | | |
| Fin material | Aluminum | |
| Fin height | 19 | mm |
| Fin spacing | 2.009 | mm |
| Fin thickness | 0.3 | mm |
| Number of fins per meter | 433.1 | per meter |
| Fin metal conductivity @ 500F (260C) | 167.6 | W/m-C |
| Fin metal conductivity slope | 0 | W/m-C ² |
| Overall Data | | |
| Gas path frontal area | 283.8 | m ² |
| Min. gas free flow cross section / frontal area | 0.581 | |
| H.T. surface area / min. free flow cross section | 212 | |
| Primary tube surface / total heat transfer surf. | 0.0475 | |
| Water side flow cross section area | 1.522 | m ² |
| Heat exchanger prime outside surface | 1659.3 | m ² |
| Heat exchanger total fin area | 33291 | m ² |
| Heat exchanger total outside area | 34950 | m ² |
| Heat Transfer | | |
| Gas Side | | |
| Inlet face velocity | 2.286 | m/s |
| Face mass flux | 9.552 | t/h-m ² |

| | | |
|--|--------------|---------------------|
| Dry air-cooled condenser | | |
| Velocity at minimum flow area | 4.038 | m/s |
| Mass flux at minimum flow area | 16.44 | t/h-m ² |
| Reynolds number | 872 | |
| Prandtl number | 0.708 | |
| Convective Nusselt number | 4.13 | |
| Convective heat transfer coefficient | 31.12 | W/m ² -C |
| Radiative heat transfer coefficient | 0 | W/m ² -C |
| Convective h.t.c. adjustment factor | 1.15 | |
| Total gas side adjusted heat transfer coefficient | 35.78 | W/m ² -C |
| Fouling resistance | 4.342508E-05 | m ² -C/W |
| Nusselt number Re coefficient | 0.0563 | |
| Friction factor Re coefficient | 28.52 | |
| Radiation beam mean length | 0 | m |
| Pressure drop correction factor | 1 | |
| Pressure drop | 0.8245 | millibar |
| Water Side | | |
| Condensing heat transfer coefficient | 5962 | W/m ² -C |
| Overall Performance | | |
| Fin effectiveness | 0.813 | |
| Effective / total external area | 0.8219 | |
| Overall heat transfer coefficient | 26.42 | W/m ² -C |
| Heat transfer rate to gas | 11926 | kW |
| Heat transfer rate from water | 11926 | kW |
| Overall heat transfer coefficient X total outer area, (UA) | 923.4 | kW/C |

| Emissions | kg/hr | metric ton/year | kg/MWhr (gross) |
|---|----------------------|--------------------------|------------------------|
| Furnace Emissions | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2294.6 | 18586 | 3.381 |
| CO2 (net) | 520251 | 4214037 | 766.5 |
| Particulate | 15540 | 125877 | 22.9 |
| Mercury as Hg | 0 | 0 | 0 |
| Electrostatic Precipitator Exit | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2294.6 | 18586 | 3.381 |
| CO2 (net) | 520250 | 4214028 | 766.5 |
| Particulate | 77.7 | 629.4 | 0.1145 |
| Mercury as Hg | 0 | 0 | 0 |
| Plant Total Emissions | | | |
| NOx as NO2 | 0 | 0 | 0 |
| SOx as SO2 | 2294.6 | 18586 | 3.381 |
| CO2 (net) | 520250 | 4214028 | 766.5 |
| Particulate | 77.7 | 629.4 | 0.1145 |
| Mercury as Hg | 0 | 0 | 0 |
| Stack Levels | | | |
| | ng/J HHV @25C | mg/Nm³ | ppmv |
| NOx as NO2 | 0 | 0 @ 6% O2, dry | 0 @ 6% O2, dry |
| SOx as SO2 | 393.9 | 1169.3 @ 6% O2, dry | 409.1 @ 6% O2, dry |
| Particulate | 13.34 | 39.6 @ 6% O2, dry | |
| Mercury as Hg | 0 | 0 @ 6% O2, dry | 0 @ 6% O2, dry |
| Nm3 at 0 C, 101.325 kPa (32 F, 14.696 psia) | | | |
| Note: | | | |
| Boiler NOx emission is computed from the user-specified generation rate input on the Environment topic. | | | |
| The program DOES NOT predict NOx emissions. | | | |
| Therefore, it is incumbent on the user to input OEM-provided data consistent with equipment operation at this specific running condition. | | | |

| Plant Water/Steam Mass Flow Balance | | Mass flow |
|--|--|------------------|
| Mass Flow In | | 113.9 t/h |
| Steam cycle makeup | | 0 t/h |
| Cooling tower makeup | | 0 t/h |
| Wet air-cooled condenser makeup | | 0 t/h |
| Auxiliary cooling tower makeup | | 0 t/h |
| Total boiler desuperheating water from makeup | | 0 t/h |
| Total process steam desuperheating water from makeup | | 0 t/h |
| Total steam addition | | 0 t/h |
| Total water addition | | 0 t/h |
| Total external steam | | 0 t/h |
| Total process return | | 0 t/h |
| FGD makeup/cake wash | | 0 t/h |
| FGD water from reagent | | 0 t/h |
| FGD water from oxidation air | | 0 t/h |
| CO2 capture makeup | | 0 t/h |
| Water in combustion air | | 29.31 t/h |
| Water in fuel | | 9.665 t/h |
| Water from combustion of hydrogen in fuel | | 74.9 t/h |
| Seawater FGD evaporation | | 0 t/h |
| Mass Flow Out | | 113.9 t/h |
| Cooling tower blowdown | | 0 t/h |
| Cooling tower water evaporation | | 0 t/h |
| Wet air-cooled condenser blowdown | | 0 t/h |
| Wet air-cooled condenser water evaporation | | 0 t/h |
| Auxiliary cooling tower blowdown | | 0 t/h |
| Auxiliary cooling tower water evaporation | | 0 t/h |
| Boiler blowdown to external sink | | 0 t/h |
| Total process steam | | 0 t/h |
| Total water extraction | | 0 t/h |
| FGD blowdown/stacking water | | 0 t/h |
| FGD water in byproduct | | 0 t/h |
| CO2 capture drain | | 0 t/h |
| CO2 capture water evaporation | | 0 t/h |
| CO2 capture water removed with CO2 stream | | 0 t/h |
| ST leakage to external sink | | 0 t/h |
| Water in flue gas at stack exit | | 113.9 t/h |
| Seawater FGD condensation | | 0 t/h |

| Plant Water Accounting | | Current flow | % included | | |
|--|--|--------------|------------|----------|------------|
| Total Water Consumption | | | | 0 | t/h |
| Steam cycle makeup | | 0 | 100 | 0 | t/h |
| Cooling tower makeup | | 0 | 100 | 0 | t/h |
| Wet air-cooled condenser makeup | | 0 | 100 | 0 | t/h |
| Auxiliary cooling tower makeup | | 0 | 100 | 0 | t/h |
| FGD makeup/cake wash | | 0 | 100 | 0 | t/h |
| CO2 capture makeup | | 0 | 100 | 0 | t/h |
| Water addition 1 | | 0 | 0 | 0 | t/h |
| Water addition 2 | | 0 | 0 | 0 | t/h |
| Water addition 3 | | 0 | 0 | 0 | t/h |
| Process steam desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Superheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Reheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| LP reheater desuperheating water from makeup | | 0 | 100 | 0 | t/h |
| Seawater FGD evaporation | | 0 | 0 | 0 | t/h |
| Total Water Discharge | | | | 0 | t/h |
| Cooling tower blowdown | | 0 | 100 | 0 | t/h |
| Wet air-cooled condenser blowdown | | 0 | 100 | 0 | t/h |
| Auxiliary cooling tower blowdown | | 0 | 100 | 0 | t/h |
| Boiler blowdown to external sink | | 0 | 100 | 0 | t/h |
| FGD blowdown/stacking water | | 0 | 100 | 0 | t/h |
| CO2 capture drain | | 0 | 100 | 0 | t/h |
| Water extraction 1 | | 0 | 0 | 0 | t/h |
| Water extraction 2 | | 0 | 0 | 0 | t/h |
| Water extraction 3 | | 0 | 0 | 0 | t/h |
| Seawater FGD condensation | | 0 | 0 | 0 | t/h |

| ESP | | |
|---|--------------|--|
| Heat Balance | | |
| Flue Gas | | |
| Flue gas inlet temperature | 137.8 | C |
| Flue gas outlet temperature | 137.8 | C |
| Flue gas mass flow (excluding particulate flow) | 2,650 | t/h |
| Flue gas volume flow | 3,098,000 | m ³ /hr |
| Flue gas velocity | 1.361 | m/s |
| Performance | | |
| Particulate collection efficiency | 99.5 | % |
| Inlet particulate load per energy input | 2667.8 | ng/J |
| Inlet particulate load per gas flow | 7919 | mg/Nm ³ @ 6% O ₂ , dry |
| Outlet particulate load per energy input | 13.34 | ng/J |
| Outlet particulate load per gas flow | 39.6 | mg/Nm ³ @ 6% O ₂ , dry |
| Inlet particulate flow | 15.54 | t/h |
| Particulate removal | 15.46 | t/h |
| Outlet particulate flow | 0.0777 | t/h |
| Pressure drop (including ductwork) | 8.095 | millibar |
| Electricity consumption | 1613.1 | kW |
| Flue gas SO ₂ | 402.7 | ppm |
| Flue gas SO ₃ at inlet | 2.014 | ppm |
| Injected sulfur trioxide (SO ₃) for flue gas conditioning | 0.1281 | t/h |
| Flue gas SO ₃ after conditioning | 20 | ppm |
| Flue gas SO ₃ at exit | 15 | ppm |
| Heat loss | 0 | kW |
| Modified Deutsch-Anderson Equation | | |
| Specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Particulate resistivity | 1.739211E+08 | ohm-cm |
| Effective migration velocity | 0.3062 | m/s |
| Dimensionless K | 0.5032 | |
| Hardware | | |
| Design collection efficiency | 99.5 | % |
| Design inlet temperature | 137.8 | C |
| Design flue gas mass flow | 2,650 | t/h |
| Design flue gas volume flow | 3,098,000 | m ³ /hr |
| Design flue gas velocity | 1.372 | m/s |
| Overall Dimensions | | |
| Number of chambers | 3 | |
| Number of fields | 4 | |
| Total length | 30.74 | m |
| Total width | 70.68 | m |
| Total height | 20.57 | m |
| Total weight | 1,961,000 | kg |
| Collecting Plates | | |
| Design specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Total collection surface area | 77,250 | m ² |
| Number of plates per chamber | 64 | |
| Collecting plates height | 10.97 | m |
| Collecting plates spacing | 304.8 | mm |
| Collecting plates bundle width per chamber | 19.2 | m |
| Collecting plates depth per field | 4.656 | m |
| Collecting length | 18.62 | m |
| Aspect ratio (Collecting length / Plate height) | 1.697 | |

| Heat Balance Results | | |
|---|---------------|-------------------|
| Boiler Feed Pump | | |
| Type | Variable RPM | |
| Number per Boiler | 1 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 22.38 | bar |
| Temperature | 190.5 | C |
| Mass flow | 1918.4 | t/h |
| Enthalpy | 810.3 | kJ/kg |
| Density | 876.2 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 308.7 | bar |
| Temperature | 197.4 | C |
| Mass flow | 1918.4 | t/h |
| Enthalpy | 854.1 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 286.3 (3332) | bar (m) |
| Pressure rise after valve pressure drop | 286.3 (3332) | bar (m) |
| Pump shaft speed | 3000 | RPM |
| Pump isentropic efficiency | 74.45 | % |
| Pump apparent isentropic efficiency | 74.45 | % |
| Pump hydraulic work | 23386 | kW |
| Pump mechanical efficiency | 96.89 | % |
| Pump shaft work | 24138 | kW |
| Boiler Feed Booster Pump | | |
| Type | Fixed RPM | |
| Number per Boiler | 1 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 14.9 | bar |
| Temperature | 190.4 | C |
| Mass flow | 1918.4 | t/h |
| Enthalpy | 809.2 | kJ/kg |
| Density | 875.8 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 22.38 | bar |
| Temperature | 190.5 | C |
| Mass flow | 1918.4 | t/h |
| Enthalpy | 810.3 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 7.473 (87.01) | bar (m) |
| Pressure rise after valve pressure drop | 7.473 (87.01) | bar (m) |
| Pump shaft speed | 600 | RPM |
| Pump isentropic efficiency | 83.55 | % |
| Pump apparent isentropic efficiency | 83.55 | % |
| Pump hydraulic work | 544.2 | kW |
| Pump mechanical efficiency | 96.93 | % |
| Pump shaft work | 561.4 | kW |
| Recirculation ratio | 0 | |
| Recirculation cooling load | 0 | kW |
| Motor efficiency | 96.14 | % |
| Electricity consumption | 583.9 | kW |
| Condenser C.W. Pump | | |
| None | | |
| Condensate Forwarding Pump | | |
| Type | Fixed RPM | |
| Number per ST | 2 | |
| Number operating | 1 | |
| Suction Side (each) | | |
| Pressure | 0.4064 | bar |
| Temperature | 47.22 | C |
| Mass flow | 1245.5 | t/h |
| Enthalpy | 197.6 | kJ/kg |
| Density | 989.3 | kg/m ³ |
| Delivery Side (each) | | |
| Pressure | 21.15 | bar |
| Temperature | 47.5 | C |
| Mass flow | 1245.5 | t/h |
| Enthalpy | 200.6 | kJ/kg |
| Performance Data (each) | | |
| Pump pressure rise | 24.52 (252.7) | bar (m) |
| Pressure rise after valve pressure drop | 20.75 (213.9) | bar (m) |
| Pump shaft speed | 750 | RPM |

| Heat Balance Results | | |
|-------------------------------------|-------------|----|
| Pump isentropic efficiency | 83.55 | % |
| Pump apparent isentropic efficiency | 70.71 | % |
| Pump hydraulic work | 1026.2 | kW |
| Pump mechanical efficiency | 96.93 | % |
| Pump shaft work | 1058.6 | kW |
| Recirculation ratio | 0 | |
| Recirculation cooling load | 0 | kW |
| Motor efficiency | 96.51 | % |
| Electricity consumption | 1096.9 | kW |
| District Heating Pump | None | |

| PIPES | |
|--|---------------|
| Pipe name | Pressure loss |
| | bar |
| BLR to HPT | 4.14 |
| Cold Reheat | 1.26 |
| Hot Reheat | 1.20 |
| FWH 1 Heating | 0.02 |
| FWH 2 Heating | 0.07 |
| FWH 3 Heating | 0.16 |
| FWH 4 Heating | 0.33 |
| Deaerator (FWH 5) Heating | 0.38 |
| FWH 6 Heating | 0.67 |
| FWH 8 Heating | 1.87 |
| FWH 9 Heating | 1.24 |
| FPT Main Steam | 0.33 |
| FPT Exhaust (to condenser) | 0.00 |
| * Non-heat balance pipes are shown in PEACE output | |

| Project Cost Summary | Reference Cost | Estimated Cost | |
|---|----------------------|----------------------|-------------------|
| Power Plant: | | | |
| I Specialized Equipment | 388,498,000 | 505,047,000 | USD |
| II Other Equipment | 65,782,000 | 85,517,000 | USD |
| III Civil | 62,628,000 | 101,083,000 | USD |
| IV Mechanical | 195,511,000 | 346,455,000 | USD |
| V Electrical Assembly & Wiring | 19,405,000 | 35,470,000 | USD |
| VI Buildings & Structures | 18,861,000 | 31,357,000 | USD |
| VII Engineering & Plant Startup | 56,261,000 | 57,134,000 | USD |
| CO2 Capture Plant | NA | NA | |
| Desalination Plant | NA | NA | |
| Subtotal - Contractor's Internal Cost | 806,945,000 | 1,162,062,000 | USD |
| VIII Contractor's Soft & Miscellaneous Costs | 136,215,000 | 224,948,000 | USD |
| Contractor's Price | 943,160,000 | 1,387,010,000 | USD |
| IX Owner's Soft & Miscellaneous Costs | 188,632,000 | 277,402,000 | USD |
| Total - Owner's Cost (1 USD per US Dollar) | 1,131,792,000 | 1,664,412,000 | USD |
| Nameplate Net Plant Output | 650 | 650 | MW |
| Cost per kW - Contractor's | 1451.3 | 2134.2 | USD per kW |
| Cost per kW - Owner's | 1741.5 | 2561.1 | USD per kW |
| * Cost estimates as of August 2016. | | | |
| ** Land cost, utility connection cost, and spare parts costs are zero. | | | |
| The user may want to edit those inputs for better cost estimates. | | | |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|------------|--------------------|-----------|--------------------|--------------------|
| I Specialized Equipment (USD) | | | | 388,498,000 | 505,047,000 |
| 1. Boiler | | 183,772,000 | 1 | 183,772,000 | 238,903,000 |
| Furnace (incl. radiant platens) | 64,209,000 | | | | |
| Convective Elements (incl. interconnecting piping) | 68,236,000 | | | | |
| Additional Waterwall | 5,673,000 | | | | |
| Soot Blowers | 5,349,000 | | | | |
| Desuperheaters and Controls | 7,622,000 | | | | |
| Air and Flue Gas Ducts | 5,771,000 | | | | |
| Coal Pulverisers and Feeders | 17,507,000 | | | | |
| FD Fan, PA Fan, ID Fan | 1,713,000 | | | | |
| Structural Steel, Ladders, Walkways | 3,291,000 | | | | |
| Steam Air Heater | | | | | |
| Rotary Air Heaters | 4,401,000 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 2. Steam Turbine Package | | 82,605,000 | 1 | 82,605,000 | 107,386,000 |
| Turbine | incl. | | | | |
| Generator | incl. | | | | |
| Exhaust System | incl. | | | | |
| Electrical/Control/Instrumentation Package | incl. | | | | |
| Lube Oil Package w/ main, auxiliary & emergency pump | incl. | | | | |
| High Voltage Generator | | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 3. Feedwater Heaters | | | 13 | 9,964,000 | 12,954,000 |
| Feedwater Heater 1-P | 700,500 | | 1 | | |
| Feedwater Heater 2 | 669,900 | | 1 | | |
| Feedwater Heater 3 | 583,600 | | 1 | | |
| Feedwater Heater 4 | 532,600 | | 1 | | |
| Feedwater Heater 5-DA | 985,600 | | 1 | | |
| Feedwater Heater 6 (6A, 6B) | 810,700 | | 2 | | |
| Feedwater Heater 7 (7A, 7B) | 830,100 | | 2 | | |
| Feedwater Heater 8 (8A, 8B) | 1,019,000 | | 2 | | |
| Feedwater Heater 9-S (9A, 9B) | 586,300 | | 2 | | |
| Feedwater Heater 10 | | | | | |
| Feedwater Heater 11 | | | | | |
| Feedwater Heater 12 | | | | | |
| 4. Water-cooled Condensers | | | | | |
| Water-cooled Condenser 1 | | | | | |
| Water-cooled Condenser 2 | | | | | |
| Water-cooled Condenser 3 | | | | | |
| Water-cooled Condenser 4 | | | | | |
| Water-cooled Condenser 5 | | | | | |
| Water-cooled Condenser 6 | | | | | |
| Feed Pump Turbine Water-cooled Condenser | | | | | |
| 5. Air-cooled Condenser | | 61,128,000 | 1 | 61,128,000 | 79,466,000 |
| Tube Bundles | incl. | | | | |
| Fans, Gears, and Motors | incl. | | | | |
| Steam Duct & Condenser | incl. | | | | |
| Turbine Exhaust Transition | incl. | | | | |
| Steam Jet Air Ejector | incl. | | | | |
| Condensate Receiver Tank | incl. | | | | |
| Support Structures | incl. | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 6. Particulate and Mercury Control | | 18,608,000 | 1 | 18,608,000 | 24,190,000 |
| Electrostatic Precipitator (ESP) | incl. | | | | |
| Active Carbon Injection Equipment | | | | | |
| Ductwork | incl. | | | | |
| Instruments & Controls | incl. | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 7. Flue Gas Desulfurization | | | | | |
| Reagent Feed System | | | | | |
| Absorber Tower & Ancillaries | | | | | |
| Active Carbon Injection Equipment | | | | | |
| Slurry Pumps | | | | | |
| Flue Gas Handling System | | | | | |
| Flue Gas Reheater | | | | | |
| Waste/Byproduct Handling System | | | | | |
| Support Equipment | | | | | |
| 8. Nitrogen Oxide Control (SCR) | | | | | |
| 9. Stack | | 11,294,000 | 1 | 11,294,000 | 14,682,000 |
| 10. Continuous Emissions Monitoring System | | 373,300 | 1 | 373,300 | 485,300 |
| Enclosures | incl. | | | | |
| Electronics, Display Units, Printers & Sensors | incl. | | | | |
| 11. Distributed Control System | | 1,444,000 | 1 | 1,444,000 | 1,878,000 |
| Enclosures | incl. | | | | |
| Electronics, Display Units, Printers & Sensors | incl. | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 12. Transmission Voltage Equipment | | 11,359,000 | 1 | 11,359,000 | 14,766,000 |
| Transformers | 9,857,000 | | | | |
| Circuit Breakers | 960,800 | | | | |
| Miscellaneous Equipment | 540,900 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 13. Generating Voltage Equipment | | 7,951,000 | 1 | 7,951,000 | 10,336,000 |
| Generator Buswork | 4,477,000 | | | | |
| Circuit Breakers | 3,095,000 | | | | |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| Current Limiting Reactors | | | | | |
| Miscellaneous Equipment | 378,600 | | | | |
| Approximate shipping to typical US site | incl. | | | | |
| 14. User-defined | | | | 0 | 0 |

| | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-------------------|----------|-------------------|-------------------|
| II Other Equipment (USD) | | | 65,782,000 | 85,517,000 |
| 1. Pumps | | | 8,694,000 | 11,302,000 |
| Boiler Feed Pump (turbine included) | 7,109,000 | 1 | 7,109,000 | 9,242,000 |
| Boiler Feed Booster Pump | 128,900 | 1 | 128,900 | 167,550 |
| Condenser C.W. Pump | | | | |
| Condensate Forwarding Pump | 266,650 | 2 | 533,300 | 693,300 |
| Condenser Vacuum Pump | | | | |
| Fuel Oil Unloading Pump | 8,490 | 1 | 8,490 | 11,030 |
| Fuel Oil Forwarding Pump | 5,730 | 2 | 11,450 | 14,890 |
| Aux Cooling Water Pump (closed loop) | | | | |
| Treated Water Pump | 5,930 | 1 | 5,930 | 7,700 |
| Diesel Fire Pump | 72,800 | 3 | 218,450 | 284,000 |
| Electric Fire Pump | | | | |
| Jockey Fire Pump | 4,220 | 1 | 4,220 | 5,490 |
| ST+Generator Lube Oil Coolant Pump | 9,070 | 2 | 18,150 | 23,590 |
| ST Generator Coolant Pump | 15,800 | 2 | 31,610 | 41,090 |
| Demin Water Pump | 5,870 | 2 | 11,730 | 15,250 |
| Raw Water Pump 1 | 5,620 | 1 | 5,620 | 7,310 |
| Raw Water Pump 2 | 5,620 | 1 | 5,620 | 7,310 |
| Raw Water Pump 3 | | | | |
| District Heating Pump | | | | |
| Aux Cooling Water Pump (open loop) | | | | |
| FGD Slurry Pump | elsewhere | | | |
| Startup Boiler Feed Pump | 601,100 | 1 | 601,100 | 781,500 |
| 2. Tanks | | 7 | 530,300 | 689,300 |
| Fuel Oil | 187,250 | 1 | 187,250 | 243,400 |
| Hydrous Ammonia | | | | |
| Demineralized Water | 50,350 | 1 | 50,350 | 65,450 |
| Raw Water | 50,350 | 1 | 50,350 | 65,450 |
| Neutralized Water | 34,790 | 1 | 34,790 | 45,220 |
| Acid Storage | 7,280 | 1 | 7,280 | 9,460 |
| Caustic Storage | 7,280 | 1 | 7,280 | 9,460 |
| Waste Water | | | | |
| Dedicated Fire Protection Water Storage | 193,000 | 1 | 193,000 | 250,900 |
| 3. Cooling Tower | | | | |
| 4. Auxiliary Heat Exchangers | | | 737,500 | 958,700 |
| Auxiliary Cooling Water Heat Exchanger | | | | |
| Auxiliary Cooling Tower | | | | |
| Primary Air Fan Fin Fan Cooler | 79,750 | 3 | 239,200 | 310,950 |
| Induced Draft Fan Fin Fan Cooler | 83,050 | 6 | 498,300 | 647,800 |
| Miscellaneous Heat Exchangers | | | | |
| 5. District Heaters | | | | |
| District Heater 1 | | | | |
| District Heater 2 | | | | |
| 6. Auxiliary Boiler | | | | |
| 7. Makeup Water Treatment System | 1,319,000 | 1 | 1,319,000 | 1,715,000 |
| 8. Waste Water Treatment System | 168,250 | 1 | 168,250 | 218,700 |
| 9. Bridge Crane(s) | 1,545,000 | 1 | 1,545,000 | 2,009,000 |
| Steam Turbine Crane | | | | |
| 10. Station/Instrument Air Compressors | 156,400 | 5 | 782,100 | 1,017,000 |
| 11. Reciprocating Engine Genset(s) | | 6 | 13,551,000 | 17,616,000 |
| Emergency Generator | 810,700 | 1 | 810,700 | 1,054,000 |
| Black Start Generator | 2,548,000 | 5 | 12,740,000 | 16,562,000 |
| 12. General Plant Instrumentation | 371,250 | 1 | 371,250 | 482,600 |
| 13. Medium Voltage Equipment | 3,906,000 | 1 | 3,906,000 | 5,078,000 |
| Transformers | 552,800 | | | |
| Circuit Breakers | 124,800 | | | |
| Switchgear | 1,171,000 | | | |
| Motor Control Centers | 1,872,000 | | | |
| Miscellaneous | 186,000 | | | |
| 14. Low Voltage Equipment | 2,537,000 | 1 | 2,537,000 | 3,298,000 |
| Transformers | 862,200 | | | |
| Circuit Breakers | 844,200 | | | |
| Switchgear | | | | |
| Motor Control Centers | 709,800 | | | |
| Miscellaneous | 120,800 | | | |
| 15. Coal Handling Equipment | 24,108,000 | 1 | 24,108,000 | 31,341,000 |
| 16. Ash Handling Equipment | 4,400,000 | 1 | 4,400,000 | 5,720,000 |
| 17. Miscellaneous Equipment | 3,132,000 | | 3,132,000 | 4,072,000 |
| 18. User-defined | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-------------------|----------------|--------------|--------------|-------------------|-------------------|--------------------|
| III Civil (USD) | | | | | | 62,628,000 | 101,083,000 |
| 1. Site Work | 8,668,000 | 148,500 | 36 | | | 14,013,000 | 22,092,000 |
| Site Clearing | incl. | incl. | | | | | |
| Demolition | incl. | incl. | | | | | |
| Culverts & Drainage | incl. | incl. | | | | | |
| Erosion Control | incl. | incl. | | | | | |
| Fencing, Controlled Access Gates | incl. | incl. | | | | | |
| Finish Grading | incl. | incl. | | | | | |
| Finish Landscaping | incl. | incl. | | | | | |
| Material (Dirt, Sand, Stone) | incl. | incl. | | | | | |
| Waste Material Removal | incl. | incl. | | | | | |
| Obstacles R&R | incl. | incl. | | | | | |
| Miscellaneous | incl. | incl. | | | | | |
| 2. Excavation & Backfill | 1,652,000 | 35,880 | 36 | 72.16 | 40,790 m^3 | 2,944,000 | 4,763,000 |
| Steam Turbine | 164,950 | 3,600 | 36 | 66.77 | 4,410 m^3 | 294,650 | 477,050 |
| Boiler | 872,500 | 19,200 | 36 | 69.02 | 22,660 m^3 | 1,564,000 | 2,534,000 |
| Stack | elsewhere | elsewhere | | | | | |
| Water Cooled Condenser(s) | | | | | | | |
| Cooling Tower | | | | | | | |
| Air Cooled Condenser | 248,800 | 5,360 | 36 | 94.34 | 4,680 m^3 | 441,600 | 713,900 |
| Particulate and Mercury Control | 78,300 | 1,740 | 36 | 71.42 | 1,970 m^3 | 140,750 | 228,300 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Feedwater Heaters | 24,480 | 698 | 36 | 61.03 | 813 m^3 | 49,620 | 82,750 |
| District Heater(s) | | | | | | | |
| Underground Piping | 92,450 | 1,460 | 36 | 74.96 | 1,930 m^3 | 144,900 | 226,400 |
| Switchyard | 5,130 | 114 | 36 | 90.48 | 102 m^3 | 9,220 | 14,950 |
| Miscellaneous | 165,350 | 3,710 | 36 | 70.86 | 4,220 m^3 | 298,950 | 485,500 |
| 3. Concrete | 24,426,000 | 566,800 | 36 | 1,360 | 33,070 m^3 | 44,829,000 | 73,070,000 |
| Steam Turbine | 2,625,000 | 54,350 | 36 | 2,090 | 2,190 m^3 | 4,582,000 | 7,376,000 |
| Laydown pads: | 48,940 | 1,390 | 36 | | 67.86 m^3 | 99,150 | 165,250 |
| Steam Turbine | 48,940 | 1,390 | 36 | 1,460 | 67.86 m^3 | 99,150 | 165,250 |
| Boiler | 11,238,000 | 257,250 | 36 | 1,380 | 14,820 m^3 | 20,499,000 | 33,363,000 |
| Stack | elsewhere | elsewhere | | | | | |
| Water Cooled Condenser(s) | | | | | | | |
| Cooling Tower | | | | | | | |
| Air Cooled Condenser | 837,700 | 22,330 | 36 | 1,570 | 1,050 m^3 | 1,641,000 | 2,717,000 |
| Particulate and Mercury Control | 504,800 | 11,740 | 36 | 1,140 | 811 m^3 | 927,600 | 1,512,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Underground Piping: | | | | | | | |
| Circulating Water | | | | | | | |
| Miscellaneous | | | | | | | |
| Makeup Water Treatment System | 18,990 | 587 | 36 | 1,770 | 22.64 m^3 | 40,130 | 67,500 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | 1,186,000 | 30,470 | 36 | 1,430 | 1,600 m^3 | 2,283,000 | 3,763,000 |
| Feedwater Heaters | 197,150 | 7,810 | 36 | 871 | 549 m^3 | 478,250 | 825,600 |
| Pumps | 247,050 | 7,200 | 36 | 1,370 | 369 m^3 | 506,100 | 845,800 |
| Auxiliary Heat Exchangers | 45,030 | 1,840 | 36 | 1,140 | 97.33 m^3 | 111,150 | 192,450 |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 87,400 | 2,250 | 36 | 2,800 | 60.13 m^3 | 168,400 | 277,700 |
| Bridge Crane(s) | | | | | | | elsewhere |
| Reciprocating Engine Genset(s) | 498,600 | 13,350 | 36 | 1,470 | 664 m^3 | 979,400 | 1,622,000 |
| Tanks: | 345,000 | 10,430 | 36 | | 567 m^3 | 720,600 | 1,209,000 |
| Fuel Oil | 142,850 | 4,110 | 36 | 1,100 | 264 m^3 | 290,650 | 484,950 |
| Hydrous Ammonia | | | | | | | |
| Demineralized Water | 29,680 | 942 | 36 | 1,610 | 39.58 m^3 | 63,600 | 107,250 |
| Raw Water | 29,680 | 942 | 36 | 1,610 | 39.58 m^3 | 63,600 | 107,250 |
| Neutralized Water | 20,120 | 661 | 36 | 2,170 | 20.21 m^3 | 43,920 | 74,350 |
| Acid Storage | 4,440 | 149 | 36 | 2,450 | 3.991 m^3 | 9,790 | 16,610 |
| Caustic Storage | 4,440 | 149 | 36 | 2,450 | 3.991 m^3 | 9,790 | 16,610 |
| Waste Water | | | | | | | |
| Dedicated Fire Protection Water Storage | 113,800 | 3,480 | 36 | 1,220 | 196 m^3 | 239,250 | 401,950 |
| Switchyard | 52,400 | 1,560 | 36 | 1,350 | 80.56 m^3 | 108,600 | 181,900 |
| Fuel Handling System | 4,273,000 | 92,650 | 36 | 1,070 | 7,120 m^3 | 7,609,000 | 12,309,000 |
| Miscellaneous | 2,221,000 | 51,500 | 36 | 1,360 | 3,010 m^3 | 4,075,000 | 6,643,000 |
| 4. Roads, Parking, Walkways | 756,200 | 2,290 | 37.63 | | | 842,300 | 1,157,000 |
| Pavement, Curbing, Striping | 621,600 | 1,670 | 36 | 4.2 | 15070 | 681,500 | 929,500 |
| Lighting | 134,650 | 623 | 42 | 5,740 | 28 | 160,800 | 228,000 |
| 5. User-defined | | | | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|-------------------|------------------|------------|--------------|-----------------|--------------------|--------------------|
| IV Mechanical (USD) | | | | | | 195,511,000 | 346,455,000 |
| 1. On-Site Transportation & Rigging | 9,997,000 | | | | | 9,997,000 | 16,620,000 |
| 2. Equipment Erection & Assembly | 18,950,000 | 2,572,000 | 41 | | | 124,393,000 | 238,157,000 |
| Steam Turbine Package | 443,500 | 60,550 | 41 | 2,925,000 | 1 | 2,925,000 | 5,602,000 |
| Boiler | 10,610,000 | 1,448,000 | 41 | 69,982,000 | 1 | 69,982,000 | 134,022,000 |
| Feedwater Heaters | 73,800 | 10,070 | 41 | | | 486,850 | 932,300 |
| Condenser(s) | 1,954,000 | 266,650 | 41 | | | 12,885,000 | 24,677,000 |
| Cooling Tower | | | | | | | |
| Particulate and Mercury Control | 2,201,000 | 300,350 | 41 | 14,515,000 | 1 | 14,515,000 | 27,797,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Coal Handling System | 934,500 | 127,550 | 41 | 6,164,000 | 1 | 6,164,000 | 11,805,000 |
| Ash Handling System | 889,200 | 121,350 | 41 | 5,865,000 | 1 | 5,865,000 | 11,232,000 |
| Makeup Water Treatment System | 147,350 | 6,440 | 41 | | | 411,200 | 725,800 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | 257,300 | 35,120 | 41 | | | 1,697,000 | 3,250,000 |
| Pumps | 52,900 | 7,220 | 41 | | | 348,950 | 668,300 |
| Tanks + Auxiliary Heat Exchangers | 44,810 | 6,120 | 41 | | | 295,550 | 566,000 |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 5,900 | 805 | 41 | | | 38,900 | 74,500 |
| Bridge Crane(s) | 8,990 | 1,230 | 41 | | | 59,300 | 113,600 |
| Reciprocating Engine Genset(s) | 6,000 | 819 | 41 | | | 39,580 | 75,800 |
| Miscellaneous | 1,322,000 | 179,450 | 41 | | | 8,679,000 | 16,616,000 |
| 3. Piping | 42,863,000 | 394,800 | 41 | 2,830 | 20,840 m | 59,051,000 | 88,502,000 |
| High Pressure Steam | 8,635,000 | 23,260 | 41 | 44,370 | 216 m | 9,589,000 | 13,157,000 |
| Cold Reheat Steam | 2,217,000 | 20,670 | 41 | 16,930 | 181 m | 3,065,000 | 4,598,000 |
| Hot Reheat Steam | 5,471,000 | 34,440 | 41 | 29,480 | 233 m | 6,884,000 | 9,972,000 |
| FWH Heating Steam | 1,623,000 | 18,050 | 41 | 4,860 | 486 m | 2,363,000 | 3,609,000 |
| Other Steam & Heating | 2,487,000 | 16,940 | 41 | 27,040 | 118 m | 3,182,000 | 4,640,000 |
| Feedwater | 9,560,000 | 46,950 | 41 | 13,230 | 868 m | 11,485,000 | 16,326,000 |
| Circulating Water | | | | | | | |
| Auxiliary Cooling Water | 251,900 | 4,770 | 41 | 1,280 | 349 m | 447,700 | 723,900 |
| Other Water | 21,370 | 1,370 | 41 | 216 | 358 m | 77,550 | 141,600 |
| Raw Water | 138,400 | 5,600 | 41 | 516 | 714 m | 368,050 | 645,000 |
| Service Water | 271,550 | 10,350 | 41 | 567 | 1,230 m | 695,800 | 1,212,000 |
| Fuel Gas | | | | | | | |
| Fuel Oil | | | | | | | |
| Service Air | 173,100 | 5,250 | 41 | 422 | 920 m | 388,200 | 660,700 |
| Vacuum Air | 195,750 | 4,240 | 41 | 1,880 | 197 m | 369,800 | 606,900 |
| Ammonia | | | | | | | |
| Boiler & Equipment Drain | 4,962,000 | 128,000 | 41 | 902 | 11,320 m | 10,210,000 | 17,077,000 |
| Boiler Blowdown | | | | | | | |
| Steam Blowoff | 244,050 | 2,600 | 41 | 6,930 | 50.6 m | 350,700 | 533,200 |
| Fire Protection | 3,619,000 | 44,790 | 41 | 2,540 | 2,150 m | 5,456,000 | 8,424,000 |
| Miscellaneous | 2,990,000 | 27,550 | 41 | 2,830 | 1,450 m | 4,120,000 | 6,175,000 |
| 4. Steel | 1,401,000 | 16,310 | 41 | 4,950 | 418 | 2,070,000 | 3,176,000 |
| Racks, Supports, Ladders, Walkways, Platforms | 1,401,000 | 16,310 | 41 | 4,950 | 418 | 2,070,000 | 3,176,000 |
| 5. User-defined | | | | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|------------------|----------------|------------|-----------|----------|-------------------|-------------------|
| V Electrical Assembly & Wiring (USD) | | | | | | 19,405,000 | 35,470,000 |
| 1. Controls | 699,300 | 241,100 | 42 | | | 10,826,000 | 21,415,000 |
| Steam Turbine Package | 73,000 | 25,940 | 42 | 1,163,000 | 1 | 1,163,000 | 2,301,000 |
| Boiler | 354,400 | 125,900 | 42 | 5,643,000 | 1 | 5,643,000 | 11,170,000 |
| Feedwater Heaters | 2,300 | 817 | 42 | | | 36,600 | 72,450 |
| Condenser(s) | 132,450 | 47,050 | 42 | | | 2,109,000 | 4,174,000 |
| Cooling Tower | | | | | | | |
| Particulate and Mercury Control | 44,490 | 15,810 | 42 | 708,400 | 1 | 708,400 | 1,402,000 |
| Flue Gas Desulfurization | | | | | | | |
| Nitrogen Oxide Control | | | | | | | |
| Coal Handling System | 29,110 | 10,340 | 42 | 463,450 | 1 | 463,450 | 917,400 |
| Ash Handling System | 27,700 | 9,840 | 42 | 441,000 | 1 | 441,000 | 872,900 |
| Makeup Water Treatment System | 3,620 | 1,290 | 42 | | | 57,700 | 114,150 |
| Auxiliary Boiler | | | | | | | |
| Electrical Power Equipment | | | | | | | |
| Pumps | 8,710 | 3,090 | 42 | | | 138,700 | 274,500 |
| Tanks + Auxiliary Heat Exchangers | | | | | | | |
| District Heater(s) | | | | | | | |
| Station/Instrument Air Compressors | 8,090 | 345 | 42 | | | 22,580 | 39,860 |
| Bridge Crane(s) | 7,200 | 307 | 42 | | | 20,080 | 35,450 |
| Reciprocating Engine Genset(s) | 8,230 | 351 | 42 | | | 22,970 | 40,550 |
| 2. Assembly & Wiring | 4,576,000 | 95,300 | 42 | | | 8,579,000 | 14,055,000 |
| Switchgear | 31,380 | 2,290 | 42 | 25,500 | 5 | 127,500 | 235,450 |
| Motor Control Centers | 69,200 | 4,310 | 42 | 2,880 | 87 | 250,200 | 456,500 |
| Feeders | 1,067,000 | 28,320 | 42 | 14,110 | 160 | 2,257,000 | 3,796,000 |
| Medium/Low Voltage Cable Bus | 2,333,000 | 31,750 | 42 | 39,000 | 94 | 3,666,000 | 5,733,000 |
| Cable Tray | 357,200 | 7,530 | 42 | 673,600 | 1 | 673,600 | 1,105,000 |
| General Plant Instrumentation | 177,950 | 3,190 | 42 | 1,370 | 227 | 311,800 | 502,400 |
| Generator to Step-up Transformer Bus | 40,790 | 725 | 42 | 71,200 | 1 | 71,200 | 114,650 |
| Transformers | 148,200 | 7,900 | 42 | 47,990 | 10 | 479,900 | 864,400 |
| Circuit Breakers | 127,600 | 4,530 | 42 | 26,500 | 12 | 317,950 | 551,400 |
| Miscellaneous | 224,000 | 4,750 | 42 | 423,650 | 1 | 423,650 | 695,500 |
| 3. User-defined | | | | | | 0 | 0 |

| | Area | Cost/Unit Area | Ref. Cost | Est. Cost |
|---|--------|----------------|-------------------|-------------------|
| VI Buildings (USD) | | | 18,861,000 | 31,357,000 |
| 1. Boiler House and Turbine Hall | 9496 | 1800.89 | 17,101,000 | 28,430,000 |
| 2. Administration, Control Room, Machine Shop / Warehouse | 1486.5 | 1150.46 | 1,710,000 | 2,843,000 |
| 3. Water Treatment System | 23.43 | 1200.48 | 28,130 | 46,760 |
| 4. Guard House | 18.58 | 1200.48 | 22,310 | 37,080 |
| 5. Fuel Barn | | | | |
| 6. User-defined | | | 0 | 0 |

| | Material | Labor Hours | Labor Rate | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|--|------------------|---------------|--------------|-------------------|----------|-------------------|-------------------|
| VII Engineering & Plant Startup (USD) | | | | | | 56,261,000 | 57,134,000 |
| 1. Engineering | | | | | | 46,077,000 | 46,077,000 |
| 2. Start-Up | 2,911,000 | 79,850 | 91.07 | 10,183,000 | | 10,183,000 | 11,057,000 |
| 3. User-defined | | | | | | 0 | 0 |

| | Ref. Cost | Est. Cost |
|---|--------------------|--------------------|
| VIII Soft & Miscellaneous Costs (USD) | | |
| 1. Contractor's Soft Costs | 136,215,000 | 224,948,000 |
| Contingency: | 41,212,000 | 72,154,000 |
| Labor | 25,624,000 | 51,889,000 |
| Specialized Equipment | 7,770,000 | 10,101,000 |
| Other Equipment | 1,973,000 | 2,566,000 |
| Commodity | 5,845,000 | 7,599,000 |
| Profit: | 62,724,000 | 106,312,000 |
| Labor | 34,165,000 | 69,185,000 |
| Specialized Equipment | 19,425,000 | 25,252,000 |
| Other Equipment | 3,289,000 | 4,276,000 |
| Commodity | 5,845,000 | 7,599,000 |
| Permits, Licenses, Fees, Miscellaneous | 0 | 0 |
| Bonds and Insurance | 8,069,000 | 11,621,000 |
| Spare Parts & Materials | 0 | 0 |
| Contractor's Fee | 24,208,000 | 34,862,000 |
| 2. Owner's Soft Costs | 188,632,000 | 277,402,000 |
| Permits, Licenses, Fees, Miscellaneous | 18,863,000 | 27,740,000 |
| Land Cost | 0 | 0 |
| Utility Connection Cost | 0 | 0 |
| Legal & Financial Costs | 18,863,000 | 27,740,000 |
| Escalation and Interest During Construction | 141,474,000 | 208,051,000 |
| Spare Parts & Materials | 0 | 0 |
| Project Administration & Developer's Fee | 9,432,000 | 13,870,000 |
| 3. Total of all user-defined costs displayed on each account | 0 | 0 |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| CO2 Capture Plant (USD) | | | | 0 | 0 |
| 1. CO2 Capture | | | | | |
| Absorbers | | | | | |
| Strippers | | | | | |
| CO2 compressors and dehydrators | | | | | |
| Heat exchangers | | | | | |
| Pumps | | | | | |
| Piping | | | | | |
| Electrical & Controls | | | | | |
| Engineering & Design | | | | | |
| Miscellaneous | | | | | |
| Approximate shipping to typical US site | | | | | |
| 2. User-defined | | | | 0 | 0 |

| | Item Cost | Unit Cost | Quantity | Ref. Cost | Est. Cost |
|---|-----------|-----------|----------|-----------|-----------|
| Desalination Plant (USD) | | | | 0 | 0 |
| 1. Desalination | | | | | |
| MSF System | | | | | |
| - Evaporators | | | | | |
| - Brine Heater | | | | | |
| - Deaerator | | | | | |
| - Pumps | | | | | |
| - Piping | | | | | |
| - Electrical & Controls | | | | | |
| - Intake System & Distillate Delivery | | | | | |
| - Engineering & Design | | | | | |
| - Platform/ladder/walkway | | | | | |
| - Miscellaneous | | | | | |
| RO System | | | | | |
| - Intake & Outfall | | | | | |
| - Pre-treatment System | | | | | |
| - Pumps | | | | | |
| - Energy Recovery Device | | | | | |
| - RO Membrane Assembly | | | | | |
| - Post-treatment System | | | | | |
| - Miscellaneous | | | | | |
| Approximate shipping to typical US site | | | | | |
| 2. User-defined | | | | 0 | 0 |

| Estimated Site Plan Data | | |
|---|-------|----------------|
| 1. Site Plot Plan | | |
| Length | 430 | m |
| Width | 400 | m |
| Area | 17.17 | hectare |
| 2. Boiler House and Turbine Hall | | |
| Area | 9,500 | m ² |
| 3. Switchyard | | |
| Length | 117 | m |
| Width | 74.9 | m |
| Area | 8,770 | m ² |
| 4. Water Treatment Facility | | |
| Length | 6.8 | m |
| Width | 3.4 | m |
| Area | 23.43 | m ² |
| 5. Administration, Shop & Warehouse Building | | |
| Length | 35.2 | m |
| Width | 14.1 | m |
| Area | 1,490 | m ² |
| Number of Floors | 3 | |
| 6. Road | | |
| Length | 851 | m |
| Width | 7.6 | m |
| Area | 6,490 | m ² |
| 7. Parking Lot | | |
| Number of Parking Spaces | 16 | |
| Total Width | 48.8 | m |
| Depth of Parking Space | 6.1 | m |
| Total Area | 297 | m ² |
| 8. Walkways | | |
| Area | 8,580 | m ² |
| 9. Guard House | | |
| Area | 18.58 | m ² |

| Estimated Piping Data | ID x No. | Nom. D [mm] | Length [m] | Schedule | Material | Fittings | M [t/h] | Design Flow | Design Vel. [m/s] |
|--|------------|-------------|------------|----------|----------|----------|---------|--------------------------|-------------------|
| 1. High Pressure Steam Piping | | | | | | | | | |
| BLR to HPT | HP0 x 1 | 457.2 | 172.5 | Custom | TP347HFG | 8 | 1918.4 | 6.682 m ³ /s | 41.26 m/s |
| HP Bypass | HPBP x 1 | 457.2 | 43.59 | Custom | TP347HFG | 3 | 1918.4 | 6.682 m ³ /s | 41.26 m/s |
| 2. Cold Reheat Steam Piping | | | | | | | | | |
| Cold Reheat | CRH0 x 1 | 730.3 | 181.1 | Custom | P-22 | 8 | 1740.2 | 20.04 m ³ /s | 48.71 m/s |
| 3. Hot Reheat Steam Piping | | | | | | | | | |
| Hot Reheat | HRH0 x 1 | 812.8 | 189.9 | Custom | TP347HFG | 8 | 1740.2 | 31.09 m ³ /s | 61.05 m/s |
| IP Bypass | IPBP x 1 | 812.8 | 43.59 | Custom | TP347HFG | 3 | 1740.2 | 31.09 m ³ /s | 61.05 m/s |
| 4. FWH Heating Steam Piping | | | | | | | | | |
| FWH 1 Heating | FWHHS1 x 1 | 762 | 10.67 | 10 | A-106 | 4 | 59.99 | 55.51 m ³ /s | 133 m/s |
| FWH 2 Heating | FWHHS2 x 1 | 609.6 | 21.34 | 40 | A-106 | 6 | 66.09 | 24.23 m ³ /s | 97.29 m/s |
| FWH 3 Heating | FWHHS3 x 1 | 457.2 | 32 | 40 | A-106 | 7 | 70.11 | 12.98 m ³ /s | 94.24 m/s |
| FWH 4 Heating | FWHHS4 x 1 | 406.4 | 42.67 | 40 | A-106 | 9 | 73.38 | 7.521 m ³ /s | 67.93 m/s |
| Deaerator (FWH 5) Heating | FWHHS5 x 1 | 406.4 | 103 | 40 | A-106 | 19 | 76.74 | 4.794 m ³ /s | 43.07 m/s |
| FWH 6 Heating | FWHHS6 x 2 | 203.2 | 37.19 | 40 | P-11 | 8 | 32.89 | 1.308 m ³ /s | 40.97 m/s |
| FWH 8 Heating | FWHHS8 x 2 | 203.2 | 47.85 | 60 | P-22 | 10 | 66.21 | 0.7624 m ³ /s | 24.78 m/s |
| FWH 9 Heating | FWHHS9 x 2 | 203.2 | 53.04 | 60 | P-91 | 11 | 61.58 | 1.482 m ³ /s | 48.9 m/s |
| 5. Other Steam & Heating Piping | | | | | | | | | |
| FPT Main Steam | FPTMS1 x 1 | 609.6 | 71.02 | 40 | A-106 | 9 | 147.3 | 15.1 m ³ /s | 59.5 m/s |
| FPT Exhaust (to condenser) | FPTX1 x 1 | 3048 | 46.63 | 20 | A-106 | 5 | 147.3 | 567.5 m ³ /s | 82.48 m/s |
| 6. Feedwater Piping | | | | | | | | | |
| FWH 1 Exit Feedwater | FWFW1 x 1 | 508 | 23.47 | 20 | A-106 | 2 | 1245.5 | 21303 lpm | 1.891 m/s |
| FWH 2 Exit Feedwater | FWFW2 x 1 | 609.6 | 24.99 | 20 | A-106 | 2 | 1520.3 | 26517 lpm | 1.614 m/s |
| FWH 3 Exit Feedwater | FWFW3 x 1 | 609.6 | 22.25 | 20 | A-106 | 2 | 1520.3 | 27152 lpm | 1.652 m/s |
| FWH 4 Exit Feedwater | FWFW4 x 1 | 609.6 | 103 | 20 | A-106 | 11 | 1520.3 | 27918 lpm | 1.699 m/s |
| Deaerator (FWH 5) Exit Feedwater | FWFW5 x 1 | 609.6 | 103 | 20 | A-106 | 11 | 1918.4 | 36418 lpm | 2.214 m/s |
| FWH 6 Exit Feedwater | FWFW6 x 2 | 412.8 | 16.76 | Custom | A-106 | 2 | 959.2 | 18517 lpm | 2.307 m/s |
| FWH 7 Exit Feedwater | FWFW7 x 2 | 425.5 | 14.94 | Custom | A-106 | 2 | 959.2 | 19362 lpm | 2.27 m/s |
| FWH 8 Exit Feedwater | FWFW8 x 2 | 431.8 | 17.68 | Custom | A-106 | 2 | 959.2 | 20379 lpm | 2.319 m/s |
| FWH 9 Exit Feedwater | FWFW9 x 2 | 438.2 | 7.62 | Custom | A-106 | 2 | 959.2 | 20699 lpm | 2.288 m/s |
| Feedwater to Boiler | FW3 x 1 | 622.3 | 176.5 | Custom | A-106 | 14 | 1918.4 | 41397 lpm | 2.269 m/s |
| Condensate | FW1 x 1 | 457.2 | 300.8 | 20 | A-106 | 14 | 1245.5 | 20969 lpm | 2.284 m/s |
| 7. Circulating Water Piping | | | | | | | | | |
| 8. Auxiliary Cooling Water Piping | | | | | | | | | |
| CW for ST+Generator Lube Oil | CW7 x 1 | 203.2 | 174.3 | 40 | A-106 | 20 | 169.7 | 2836.3 lpm | 1.465 m/s |
| CW for ST Generator | CW8 x 1 | 254 | 174.3 | 40 | A-106 | 16 | 355.1 | 5933 lpm | 1.944 m/s |
| 9. Other Water Piping | | | | | | | | | |
| Makeup from Water Treatment System | FW2 x 1 | 63.5 | 358.4 | 40 | A-106 | 14 | 22.89 | 381.9 lpm | 2.061 m/s |
| 10. Raw Water Piping | | | | | | | | | |
| Raw Water | RW0 x 1 | 88.9 | 713.9 | 40 | A-106 | 118 | 22.89 | 382.2 lpm | 0.9987 m/s |
| 11. Service Water Piping | | | | | | | | | |
| Service Water | SW0 x 1 | 76.2 | 1226.5 | 40 | A-106 | 303 | NA | NA | 0.9541 m/s |
| 12. Fuel Gas Piping | | | | | | | | | |
| 13. Fuel Oil Piping | | | | | | | | | |
| 14. Service Air Piping | | | | | | | | | |
| Service Air | SERVA x 1 | 50.8 | 919.9 | 40 | A-106 | 228 | NA | NA | 31.1 m/s |
| 15. Vacuum Air Piping | | | | | | | | | |
| Condenser Air Removal | CAR0 x 1 | 203.2 | 197.2 | 80 | A-106 | 50 | NA | NA | 25.73 m/s |
| 16. Ammonia Piping | | | | | | | | | |
| 17. Boiler & Equipment Drain Piping | | | | | | | | | |
| FWH 1 Drain | FWDW1 x 1 | 254 | 32.31 | 40 | A-106 | 4 | 274.8 | 4710 lpm | 1.535 m/s |
| FWH 2 Drain | FWDW2 x 1 | 203.2 | 32.31 | 40 | A-106 | 4 | 209.6 | 3601 lpm | 1.859 m/s |
| FWH 3 Drain | FWDW3 x 1 | 152.4 | 31.39 | 40 | A-106 | 4 | 143.5 | 2514.7 lpm | 2.249 m/s |
| FWH 4 Drain | FWDW4 x 1 | 127 | 28.35 | 40 | A-106 | 4 | 73.38 | 1317.5 lpm | 1.701 m/s |
| FWH 6 Drain | FWDW6 x 2 | 203.2 | 89.92 | 40 | A-106 | 4 | 160.7 | 3105 lpm | 1.604 m/s |
| FWH 7 Drain | FWDW7 x 2 | 152.4 | 21.03 | 40 | A-106 | 4 | 127.8 | 2549.8 lpm | 2.28 m/s |
| FWH 8 Drain | FWDW8 x 2 | 127 | 21.64 | 80 | A-106 | 4 | 66.21 | 1391.9 lpm | 1.976 m/s |
| Small Drains | BEDR1 x 36 | 101.6 | 151.8 | 40 | A-106 | 17 | NA | NA | 0.3452 m/s |
| Medium Drains | BEDR2 x 22 | 152.4 | 151.8 | 40 | A-106 | 17 | NA | NA | 0.1521 m/s |
| Large Drains | BEDR3 x 14 | 254 | 151.8 | 40 | A-106 | 17 | NA | NA | 0.0557 m/s |
| 18. Boiler Blowdown Piping | | | | | | | | | |
| 19. Steam Blowoff Piping | | | | | | | | | |
| Steam Blowoff Piping | STBL x 2 | 457.2 | 25.3 | 40 | A-106 | 9 | NA | NA | 2.248 m/s |
| 20. Fire Protection Piping | | | | | | | | | |
| Main Fire Protection | FP0 x 1 | 508 | 1073.2 | 20 | A-106 | 90 | 1362 | 22712 lpm | 2.016 m/s |

| Estimated Piping Data | ID x No. | Nom. D [mm] | Length [m] | Schedule | Material | Fittings | M [t/h] | Design Flow | Design Vel. [m/s] |
|-------------------------------|----------|-------------|------------|----------|----------|----------|---------|-------------|-------------------|
| Miscellaneous Fire Protection | FP1 x 1 | 406.4 | 1073.2 | 20 | A-106 | 90 | 681 | 11356 lpm | 1.58 m/s |

| Estimated Pump Data | | |
|-----------------------------------|--------------------------|----------|
| Number of Units | | 1 |
| Boiler Feed Pump | | |
| Pump type | Multistage centrifugal | |
| Drive type | Variable RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 2131.5 | t/h |
| Nameplate (unrounded) head | 3155 | m |
| Nameplate volume flow | 41640 | lpm |
| Nameplate head | 3170 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 34000 | hp |
| Pump isentropic efficiency | 75 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 12.77 | m |
| Baseplate width (each) | 3.802 | m |
| Pump weight (each) | 91905 | kg |
| Turbine weight (each) | 79152 | kg |
| Boiler Feed Booster Pump | | |
| Pump type | Vertical canned | |
| Drive type | Fixed RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 2131.5 | t/h |
| Nameplate (unrounded) head | 81.81 | m |
| Nameplate volume flow | 41640 | lpm |
| Nameplate head | 83.82 | m H2O |
| Pump shaft speed | 600 | RPM |
| Shaft power | 800 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.804 | m |
| Baseplate width (each) | 1.804 | m |
| Pump weight (each) | 2102.7 | kg |
| Motor weight (each) | 2068.3 | kg |
| Condenser C.W. Pump (P4) | | |
| Number of Pumps per ST | | None |
| Condensate Forwarding Pump | | |
| Pump type | Vertical canned | |
| Drive type | Fixed RPM | |
| Number per ST | 2 - 100% | |
| Nameplate (unrounded) mass flow | 1383.9 | t/h |
| Nameplate (unrounded) head | 237.6 | m |
| Nameplate volume flow | 24605 | lpm |
| Nameplate head | 243.8 | m H2O |
| Pump shaft speed | 750 | RPM |
| Shaft power | 1500 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 2.077 | m |
| Baseplate width (each) | 2.077 | m |
| Pump weight (each) | 3965 | kg |
| Motor weight (each) | 3411 | kg |
| Condenser Vacuum Pump (P7) | | |
| Number of Pumps per ST | | None |
| Fuel Oil Unloading Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 111.5 | t/h |
| Nameplate (unrounded) head | 45.81 | m |
| Nameplate volume flow | 2271.2 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 23 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.389 | m |
| Baseplate width (each) | 0.4881 | m |
| Pump weight (each) | 247 | kg |
| Motor weight (each) | 122.5 | kg |
| Fuel Oil Forwarding Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 41.48 | t/h |
| Nameplate (unrounded) head | 38.17 | m |
| Nameplate volume flow | 851.7 | lpm |
| Nameplate head | 45.72 | m H2O |

| | | |
|---|--------------------------|-------|
| Estimated Pump Data | | |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 7 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.074 | m |
| Baseplate width (each) | 0.375 | m |
| Pump weight (each) | 129.2 | kg |
| Motor weight (each) | 49.54 | kg |
| Aux Cooling Water Pump (closed loop) (P10) | | |
| Number of Pumps per Plant | None | |
| Treated Water Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.89 | t/h |
| Nameplate (unrounded) head | 57.55 | m |
| Nameplate volume flow | 416.4 | lpm |
| Nameplate head | 60.96 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 6 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.032 | m |
| Baseplate width (each) | 0.3598 | m |
| Pump weight (each) | 116.7 | kg |
| Motor weight (each) | 41.18 | kg |
| Diesel Fire Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 3 - 100% | |
| Nameplate (unrounded) mass flow | 449.1 | t/h |
| Nameplate (unrounded) head | 70.44 | m |
| Nameplate volume flow | 7571 | lpm |
| Nameplate head | 76.2 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 140 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 2.071 | m |
| Baseplate width (each) | 0.7358 | m |
| Pump weight (each) | 1692.9 | kg |
| Electric Fire Pump (P13) | | |
| Number of Pumps per Plant | None | |
| Jockey Fire Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 10.25 | t/h |
| Nameplate (unrounded) head | 30.54 | m |
| Nameplate volume flow | 170.3 | lpm |
| Nameplate head | 38.1 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 1.5 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.753 | m |
| Baseplate width (each) | 0.2604 | m |
| Pump weight (each) | 52.71 | kg |
| Motor weight (each) | 15.19 | kg |
| ST+Generator Lube Oil Coolant Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per ST+Generator Lube Oil | 2 - 100% | |
| Nameplate (unrounded) mass flow | 169.7 | t/h |
| Nameplate (unrounded) head | 30.54 | m |
| Nameplate volume flow | 3028 | lpm |
| Nameplate head | 38.1 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 23 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.393 | m |
| Baseplate width (each) | 0.4897 | m |
| Pump weight (each) | 249 | kg |
| Motor weight (each) | 133.1 | kg |
| ST Generator Coolant Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |

| | | |
|---|--------------------------|-------|
| Estimated Pump Data | | |
| Number per ST Generator | 2 - 100% | |
| Nameplate (unrounded) mass flow | 355.1 | t/h |
| Nameplate (unrounded) head | 30.54 | m |
| Nameplate volume flow | 6624 | lpm |
| Nameplate head | 38.1 | m H2O |
| Pump shaft speed | 1500 | RPM |
| Shaft power | 50 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.638 | m |
| Baseplate width (each) | 0.5782 | m |
| Pump weight (each) | 374.5 | kg |
| Motor weight (each) | 235.5 | kg |
| Demin Water Pump | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 2 - 100% | |
| Nameplate (unrounded) mass flow | 22.89 | t/h |
| Nameplate (unrounded) head | 55.24 | m |
| Nameplate volume flow | 416.4 | lpm |
| Nameplate head | 60.96 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 6 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 1.023 | m |
| Baseplate width (each) | 0.3565 | m |
| Pump weight (each) | 114.1 | kg |
| Motor weight (each) | 39.9 | kg |
| Raw Water Pump 1 | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.89 | t/h |
| Nameplate (unrounded) head | 46.04 | m |
| Nameplate volume flow | 416.4 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 4.75 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.9825 | m |
| Baseplate width (each) | 0.3422 | m |
| Pump weight (each) | 103.1 | kg |
| Motor weight (each) | 34.65 | kg |
| Raw Water Pump 2 | | |
| Pump type | Single stage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Plant | 1 - 100% | |
| Nameplate (unrounded) mass flow | 22.89 | t/h |
| Nameplate (unrounded) head | 46.04 | m |
| Nameplate volume flow | 416.4 | lpm |
| Nameplate head | 53.34 | m H2O |
| Pump shaft speed | 3000 | RPM |
| Shaft power | 4.75 | hp |
| Pump isentropic efficiency | 85 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 0.9825 | m |
| Baseplate width (each) | 0.3422 | m |
| Pump weight (each) | 103.1 | kg |
| Motor weight (each) | 34.65 | kg |
| Raw Water Pump 3 (P28) | | |
| Number of Pumps per Plant | None | |
| District Heating Pump (P29) | | |
| Number of Pumps per DHC | None | |
| Aux Cooling Water Pump (open loop) (P30) | | |
| Number of Pumps per Plant | None | |
| FGD Slurry Pump (P31) | | |
| Number of Pumps per FGD | None | |
| Startup Boiler Feed Pump | | |
| Pump type | Multistage centrifugal | |
| Drive type | Fixed RPM | |
| Number per Boiler | 1 - 100% | |
| Nameplate (unrounded) mass flow | 532.9 | t/h |
| Nameplate (unrounded) head | 3335 | m |
| Nameplate volume flow | 10410 | lpm |
| Nameplate head | 3353 | m H2O |

| Estimated Pump Data | | |
|----------------------------|-------|-----|
| Pump shaft speed | 3000 | RPM |
| Shaft power | 9000 | hp |
| Pump isentropic efficiency | 75 | % |
| Pump mechanical efficiency | 97 | % |
| Baseplate length (each) | 5.147 | m |
| Baseplate width (each) | 1.874 | m |
| Pump weight (each) | 24282 | kg |
| Motor weight (each) | 20235 | kg |
| | | |

| Estimated Electric Load Data | Number in plant | Nameplate kW (each) | Nominal kW Operating | Nominal kW Standby | Nominal kWe Operating | Nominal kWe Standby | Voltage | Heat Balance Aux. kWe |
|---|--------------------|------------------------|-------------------------|-----------------------|--------------------------|------------------------|---------|--------------------------|
| 1. Pump Motors | | | | | | | | |
| Boiler Feed Booster Pump | 1 | 597 | 597 | 0 | 600 | 0 | 6600 V | 583.9 |
| Condensate Forwarding Pump | 2 | 1,120 | 1,120 | 1,120 | 1,200 | 1,200 | 6600 V | 1096.9 |
| Fuel Oil Unloading Pump | 1 | 15.66 | 0 | 15.66 | 0 | 19 | 415 V | 0 |
| Fuel Oil Forwarding Pump | 2 | 4.847 | 4.847 | 4.847 | 6 | 6 | 415 V | 6 |
| Treated Water Pump | 1 | 3.729 | 3.729 | 0 | 5 | 0 | 415 V | 5 |
| Jockey Fire Pump | 1 | 1.119 | 1.119 | 0 | 1.25 | 0 | 415 V | 1.25 |
| ST+Generator Lube Oil Coolant Pump | 2 | 17.15 | 17.15 | 17.15 | 19 | 19 | 415 V | 19 |
| ST Generator Coolant Pump | 2 | 37.29 | 37.29 | 37.29 | 40 | 40 | 415 V | 40 |
| Demin Water Pump | 2 | 3.729 | 3.729 | 3.729 | 4.75 | 4.75 | 415 V | 4.75 |
| Raw Water Pump 1 | 1 | 3.169 | 3.169 | 0 | 4 | 0 | 415 V | 4 |
| Raw Water Pump 2 | 1 | 3.169 | 3.169 | 0 | 4 | 0 | 415 V | 4 |
| Startup Boiler Feed Pump | 1 | 6,710 | 0 | 6,710 | 0 | 7,000 | 6600 V | 0 |
| FWH 1 Drain Water Pump | 3 | 130 | 261 | 130 | 260 | 130 | 415 V | 205.9 |
| 2. Auxiliary Cooling Fan Motors | | | | | | | | |
| ST+Generator Lube Oil Fin Fan Cooler Fan | 3 | 48.47 | 145 | 0 | 165 | 0 | 415 V | 165 |
| ST Generator Fin Fan Cooler Fan | 6 | 48.47 | 291 | 0 | 330 | 0 | 415 V | 330 |
| 3. Air Cooled Condenser Fan Motors | | | | | | | | |
| Air Cooled Condenser Fan | 64 | 130 | 8,350 | 0 | 7,680 | 0 | 415 V | 7014 |
| 4. Air Compressor Motors | | | | | | | | |
| Station Air Compressor | 5 | 205 | 1,030 | 0 | 1,120 | 0 | 6600 V | 1025.3 |
| 5. Water Treatment System Motors | | | | | | | | |
| Misc. Water Treatment Auxiliary Loads | 18 | 52.2 | 313 | 626 | 330 | 660 | 415 V | 271.5 |
| 6. Bridge Crane Motors | | | | | | | | |
| ST bridge crane hoist motor | 1 | 89.48 | 0 | 89.48 | 0 | 100 | 415 V | 0 |
| ST bridge crane bridge motor | 2 | 6.338 | 0 | 12.68 | 0 | 15 | 415 V | 0 |
| ST bridge crane trolley motor | 2 | 5.966 | 0 | 11.93 | 0 | 14 | 415 V | 0 |
| 7. Boiler Fans | | | | | | | | |
| Boiler Forced Draft Fan | 3 | 746 | 2,240 | 0 | 2,400 | 0 | 6600 V | 1924.1 |
| Boiler Induced Draft Fan | 3 | 1,040 | 3,130 | 0 | 3,300 | 0 | 6600 V | 2668.7 |
| Primary Air Fan | 3 | 671 | 2,010 | 0 | 2,100 | 0 | 6600 V | 1436.7 |
| 8. Pollution Control | | | | | | | | |
| Electrostatic Precipitator | 1 | 2,050 | 2,050 | 0 | 2,000 | 0 | 6600 V | 1613.1 |
| Ash Handling | 3 | 522 | 1,040 | 522 | 1,100 | 550 | 6600 V | 856.5 |
| 9. Fuel Delivery Motors | | | | | | | | |
| Fuel Handling | 7 | 746 | 5,220 | 0 | 5,600 | 0 | 6600 V | 4439 |
| 10. ST Auxiliary Loads | | | | | | | | |
| ST Lube Oil Pumps | 2 | 1,300 | 1,300 | 1,300 | 1,300 | 1,300 | 6600 V | 1018.1 |
| Misc. ST Aux Loads | 18 | 18.64 | 336 | 0 | 360 | 0 | 415 V | 356.4 |
| 11. Miscellaneous Plant Loads | | | | | | | | |
| HVAC Loads | 1 | 112 | 112 | 0 | 120 | 0 | 415 V | 120 |
| Lighting Loads | 1 | 298 | 298 | 0 | 275 | 0 | 415 V | 275 |
| Misc. Plant Aux Loads 1 | 8 | 205 | 1,230 | 410 | 1,200 | 400 | 6600 V | 1187.8 |
| Misc. Plant Aux Loads 2 | 9 | 55.93 | 503 | 0 | 540 | 0 | 415 V | 509.1 |
| Total Plant Motors & Loads | 180 | | 42,450 | 14,770 | 32,070 | 11,460 | | 27180.7 |
| Total 6600 V Motors & Loads | | | | | 21,920 | 10,450 | | |
| Total 415 V Motors & Loads | | | | | 10,140 | 1,010 | | |

| Estimated Main Electrical Data | | |
|---|--------------------|-------|
| 1. Steam Turbine Step-up Transformer | | |
| Count | 1 | |
| Nominal Rating | 792 | MVA |
| Cooling Configuration | OA/FA/FA | |
| High-side Voltage | 500 | kV |
| Low-side Voltage | 20 | kV |
| Length | 27.92 | m |
| Width | 9.306 | m |
| Weight | 627,400 | kg |
| Unit Mechanical Installation hours | 6,290 | hours |
| Unit Electrical Installation hours | 6,290 | hours |
| Unit Reference Cost | 9,857,000 | USD |
| 2. Medium Voltage Step-down Transformer | | |
| Count | 2 | |
| Nominal Rating | 17.99 | MVA |
| High-side Voltage | 20 | kV |
| Low-side Voltage | 6.6 | kV |
| Length | 2.406 | m |
| Width | 1.925 | m |
| Weight | 11,870 | kg |
| Unit Mechanical Installation hours | 298 | hours |
| Unit Electrical Installation hours | 298 | hours |
| Unit Reference Cost | 276,400 | USD |
| 3. Low Voltage Step-down Transformer | | |
| Count | 7 | |
| Nominal Rating | 1.77 | MVA |
| High-side Voltage | 20 | kV |
| Low-side Voltage | 0.415 | kV |
| Length | 2.198 | m |
| Width | 1.758 | m |
| Weight | 5,740 | kg |
| Unit Mechanical Installation hours | 144 | hours |
| Unit Electrical Installation hours | 144 | hours |
| Unit Reference Cost | 123,150 | USD |
| 4. Steam Turbine Generator Circuit Breaker | | |
| Count | 1 | |
| Voltage | 20 | kV |
| Amperage | 22,860 | Amps |
| Unit Mechanical Installation hours | 319 | hours |
| Unit Electrical Installation hours | 638 | hours |
| Unit Reference Cost | 3,095,000 | USD |
| 5. Utility Interconnect Circuit Breaker | | |
| Count | 1 | |
| Voltage | 500 | kV |
| Amperage | 859 | Amps |
| Unit Mechanical Installation hours | 182 | hours |
| Unit Electrical Installation hours | 364 | hours |
| Unit Reference Cost | 960,800 | USD |
| 6. Auxiliary Bus Feeder Circuit Breaker | | |
| Count | 1 | |
| Voltage | 20 | kV |
| Amperage | 1,400 | Amps |
| Unit Mechanical Installation hours | 159 | hours |
| Unit Electrical Installation hours | 317 | hours |
| Unit Reference Cost | 38,350 | USD |
| 7. Medium Voltage Circuit Breaker | | |
| Count | 2 | |
| Voltage | 6.6 | kV |
| Amperage | 1,570 | Amps |
| Unit Mechanical Installation hours | 163 | hours |
| Unit Electrical Installation hours | 327 | hours |
| Unit Reference Cost | 43,220 | USD |
| 8. Low Voltage Circuit Breaker | | |
| Count | 7 | |
| Voltage | 0.415 | kV |
| Amperage | 2,460 | Amps |
| Unit Mechanical Installation hours | 183 | hours |
| Unit Electrical Installation hours | 366 | hours |
| Unit Reference Cost | 120,600 | USD |
| 9. Generator to Step-up Transformer Bus | | |
| Steam Turbine Generator Bus Type | Isolated phase bus | |
| Number generators | 1 | |
| Length (per generator) | 73.63 | m |
| Mechanical installation hours (per generator) | 1,450 | hours |
| Electrical installation hours (per generator) | 725 | hours |

| Estimated Main Electrical Data | | |
|--|-----------|-------|
| Reference Cost (per generator) | 4,477,000 | USD |
| 10. Plant Buswork | | |
| Low Voltage | | |
| Total length (all runs) | 14,550 | m |
| Total Electrical Installation hours | 26,450 | hours |
| Total Reference Equipment Cost | 1,918,000 | USD |
| Medium Voltage | | |
| Total length (all runs) | 5,560 | m |
| Total Electrical Installation hours | 5,310 | hours |
| Total Reference Equipment Cost | 258,300 | USD |
| 11. Switch Gear | | |
| Low Voltage | | |
| Number sections in plant | 0 | |
| Medium Voltage | | |
| Number sections in plant | 5 | |
| Total weight | 8,870 | kg |
| Total Mechanical Installation hours | 687 | hours |
| Total Electrical Installation hours | 2,290 | hours |
| Total Reference Equipment Cost | 1,171,000 | USD |
| 12. Motor Control Centers | | |
| Low Voltage | | |
| Number sections in plant | 67 | |
| Total number of starters | 123 | |
| Total load on all starters | 11,300 | kW |
| Total weight | 30,390 | kg |
| Total Mechanical Installation hours | 829 | hours |
| Total Electrical Installation hours | 2,760 | hours |
| Total Reference Equipment cost | 709,800 | USD |
| Medium Voltage | | |
| Number sections in plant | 20 | |
| Total number of starters | 37 | |
| Total load on all starters | 28,430 | kW |
| Total weight | 28,070 | kg |
| Total Mechanical Installation hours | 464 | hours |
| Total Electrical Installation hours | 1,550 | hours |
| Total Reference Equipment cost | 1,872,000 | USD |
| 13. Motor & Load Feeders | | |
| Low Voltage | | |
| Number runs in plant | 123 | |
| Total length (all runs) | 11,040 | m |
| Total Electrical Installation hours | 23,580 | hours |
| Total Reference Equipment Cost | 815,100 | USD |
| Medium Voltage | | |
| Number runs in plant | 37 | |
| Total length (all runs) | 2,640 | m |
| Total Electrical Installation hours | 4,740 | hours |
| Total Reference Equipment Cost | 180,500 | USD |
| 14. Cable Tray | | |
| Total length (all runs) | 4,020 | m |
| Total Mechanical Installation hours | 21,520 | hours |
| Total Electrical Installation hours | 7,530 | hours |
| Total Reference Equipment Cost | 357,200 | USD |
| 15. General Plant Instrumentation | | |
| Instrument Count | 69.19 | |
| Total Electrical Installation hours | 3,190 | hours |
| Total Reference Equipment Cost | 371,250 | USD |

| Estimated Tank Data | Number | Volume [l] | Diameter [m] | Height [m] |
|---------------------|--------|------------|--------------|------------|
| Fuel Oil | 1 | 2,781,000 | 17.9 | 11 |
| Demineralized Water | 1 | 394,800 | 8.2 | 7.5 |
| Raw Water | 1 | 394,800 | 8.2 | 7.5 |
| Neutralized Water | 1 | 197,400 | 5.8 | 7.4 |
| Acid Storage | 1 | 23,690 | 2.4 | 5.1 |
| Caustic Storage | 1 | 23,690 | 2.4 | 5.1 |
| Fire Protection | 1 | 2,725,000 | 17.8 | 11 |

| Estimated Water Treatment System Data | | |
|--|---------|--------------------|
| 1. Clarifier-Reactivator | | None |
| 2. Pressure Filter | | None |
| 3. Softener | | 1 Twin Unit |
| Design Flow (8 hr continuous operation running one unit) | 269 | lpm |
| Exchange Capacity (each) | 72,000 | ppm per min. |
| Weight (twin unit) | 33,820 | kg |
| Cost (twin unit), Reference Basis | 411,400 | USD |
| 4. Reverse Osmosis System | | None |
| 5. Two-Bed Demineralizer | | 1 Train |
| Design Flow (each) | 269 | lpm |
| Weight (each) | 2,400 | kg |
| Cost (each), Reference Basis | 907,900 | USD |

| Estimated Boiler Data | | |
|--|------------------------|----------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| 1. Boiler System Summary | | |
| Boiler Type | Conventional, Two Pass | |
| Overall Length | 40.95 | m |
| Overall Width | 18.99 | m |
| Overall Height | 67.41 | m |
| Total Weight (wet) | 14,128,000 | kg |
| Total Weight (dry) | 13,936,000 | kg |
| Includes: | | |
| - Furnace incl. burners & waterwall | | |
| - Pulverizers & feeders | | |
| - Boiler casing & refractory | | |
| - Convective HX incl. waterwall | | |
| - Desuperheaters and controls | | |
| - Air & flue gas ducts | | |
| - Burner piping & fittings | | |
| - Soot blowers | | |
| - Structural steel incl. walkways & ladders | | |
| - Rotary air heater | | |
| - Fans | | |
| - Miscellaneous | | |
| Overall Heat Transfer Surface Area | 86,400 | m ² |
| - Water Wall effective projected surface | 5,270 | m ² |
| - Economiser | 48,090 | m ² |
| - Superheater (convective & radiant) | 13,380 | m ² |
| - Reheater (convective & radiant) | 19,680 | m ² |
| Total Number of Tubes (in convective elements) | 11,060 | |
| Total Boiler Cost, Reference Basis | 183,772,000 | USD |
| Includes: | | |
| - Furnace (incl. radiant platens) | | |
| - Convective Elements (incl. interconnecting piping) | | |
| - Additional Waterwall | | |
| - Soot Blowers | | |
| - Desuperheaters and Controls | | |
| - Air and Flue Gas Ducts | | |
| - Coal Pulverisers and Feeders | | |
| - FD Fan, PA Fan, ID Fan | | |
| - Supporting Steel Structure, Ladders, Walkways | | |
| - Rotary Air Heater | | |
| 2. Furnace | | |
| Furnace height (including hopper height if it exists) | 67.41 | m |
| Furnace width | 18.99 | m |
| Furnace depth | 18.61 | m |
| Aperture height | 18.99 | m |
| Hopper height | 11.17 | m |
| Furnace volume | 21,850 | m ³ |
| Furnace effective projected radiant surface | 7,160 | m ² |
| Water wall effective projected surface | 5,270 | m ² |
| Radiant superheater | 1,880 | m ² |
| 3. Horizontal Pass | | |
| Height (tube length) | 18.99 | m |
| Width (boiler width) | 18.99 | m |
| Depth (duct length) | 3.368 | m |
| Gas flow frontal area | 361 | m ² |
| 4. Second Vertical Downward Pass | | |
| Height (duct length) | 6.604 | m |
| Width (boiler width) | 18.99 | m |
| Depth (tube length) | 18.62 | m |
| Gas flow frontal area | 354 | m ² |
| 5. Rotary Air Heater | | |
| Matrix heat transfer surface | 46,770 | m ² |
| Total flow cross section area | 57.54 | m ² |
| Total frontal surface | 97.24 | m ² |
| - Gas surface | 50 | % |
| - Secondary air surface | 45.62 | % |
| - Primary air surface | 4.384 | % |
| Unit height | 6.035 | m |
| Unit side dimension | 12.73 | m |
| Unit foot area | 162 | m ² |

| Estimated Steam Turbine Data | | |
|--|--------------------|----------------|
| Number of Units | 1 | |
| Displayed quantities in this table are on a per unit basis | | |
| 1. Steam Turbine Description | | |
| Nameplate Capacity | 791.9 | MVA |
| Power Factor | 0.9 | |
| Steam Turbine Type | Condensing, Reheat | |
| Nameplate Throttle Pressure | 289.8 | bar |
| Nameplate Throttle Temperature | 604 | C |
| Nameplate Throttle Massflow | 1918.4 | t/h |
| Exhaust End Type | Down Draft | |
| Number of LPT Exhaust Annuli | 2 | |
| Last Stage Bucket Length | 947.3 | mm |
| Last Stage Pitch Diameter | 2734.1 | mm |
| Number of Ports | 12 | |
| Number of Auto-Extraction Ports | 0 | |
| 2. Estimated Weights, Dimensions & Cost | | |
| Steam Turbine Length | 37.33 | m |
| Steam Turbine Width | 5.89 | m |
| Steam Turbine Weight | 888,300 | kg |
| Generator Length (Including Exciter) | 15.94 | m |
| Generator Width | 4.392 | m |
| Generator Weight | 620,300 | kg |
| Overall ST and Generator Length | 53.28 | m |
| Overall ST and Generator Width | 5.89 | m |
| Overall ST and Generator Weight | 1,509,000 | kg |
| Equipment Cost per Unit, Reference Basis | 82,605,000 | USD |
| Foundation Length | 58.1 | m |
| Foundation Width | 7.068 | m |
| Foundation Concrete per Unit | 2187.6 | m ³ |

| Estimated Feedwater Heater Data | | |
|---|-----------------------|----------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| FWH 1-P | | |
| Feedwater heater configuration: Includes condensing section only | | |
| Nameplate steam pressure | 0.4673 | bar |
| Shell material | Carbon Steel | |
| Shell length | 18.41 | m |
| Shell inner diameter | 1.559 | m |
| Shell wall thickness | 7.938 | mm |
| Tube sheet thickness | 63.5 | mm |
| Nameplate water pressure | 21.15 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 564 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1128 | |
| Tube length per pass | 18.41 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 30.48 | mm |
| Total heat transfer area (outside tubes) | 1,240 | m ² |
| Tube weight, dry | 11,690 | kg |
| Overall length | 20.8 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 23,670 | kg |
| Heater total operating (wet) weight | 31,210 | kg |
| FWH 2-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 1.314 | bar |
| Shell material | Carbon Steel | |
| Shell length | 19.54 | m |
| Shell inner diameter | 1.684 | m |
| Shell wall thickness | 9.525 | mm |
| Tube sheet thickness | 63.5 | mm |
| Nameplate water pressure | 19.34 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 701 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1402 | |
| Tube length per pass | 19.54 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 29.53 | mm |
| Total heat transfer area (outside tubes) | 1,640 | m ² |
| Tube weight, dry | 15,410 | kg |
| Overall length | 22.2 | m |
| Overall outer diameter | 1.7 | m |
| Heater total dry weight | 32,470 | kg |
| Heater total operating (wet) weight | 42,100 | kg |
| FWH 3-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 3.151 | bar |
| Shell material | Carbon Steel | |
| Shell length | 17.1 | m |
| Shell inner diameter | 1.592 | m |
| Shell wall thickness | 9.525 | mm |
| Tube sheet thickness | 57.15 | mm |
| Nameplate water pressure | 17.59 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 716 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1432 | |
| Tube length per pass | 17.1 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 27.62 | mm |
| Total heat transfer area (outside tubes) | 1,470 | m ² |
| Tube weight, dry | 13,780 | kg |
| Overall length | 19.6 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 27,560 | kg |
| Heater total operating (wet) weight | 35,780 | kg |

| Estimated Feedwater Heater Data | | |
|---|-----------------------|----------------|
| FWH 4-D | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 6.667 | bar |
| Shell material | Carbon Steel | |
| Shell length | 15.25 | m |
| Shell inner diameter | 1.613 | m |
| Shell wall thickness | 9.525 | mm |
| Tube sheet thickness | 47.62 | mm |
| Nameplate water pressure | 16.14 | bar |
| Tube material | Stainless Steel (304) | |
| Number of tubes per pass | 735 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1470 | |
| Tube length per pass | 15.25 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 1.245 | mm |
| Tube pitch | 27.62 | mm |
| Total heat transfer area (outside tubes) | 1,340 | m ² |
| Tube weight, dry | 12,610 | kg |
| Overall length | 17.8 | m |
| Overall outer diameter | 1.6 | m |
| Heater total dry weight | 24,730 | kg |
| Heater total operating (wet) weight | 32,280 | kg |
| FWH 5-DA | | |
| DA type | HH | |
| Nameplate feedwater exit flow | 1918369 | kg/hr |
| Total storage volume | 255609 | l |
| Total storage capacity | 7 | Min |
| Number of units | 1 | |
| Overall height | 7.963 | m |
| Overall length | 18.75 | m |
| Storage tank | | |
| -Thickness | 25.4 | mm |
| -Outside diameter | 4.572 | m |
| -Total length | 18.75 | m |
| Heater | | |
| -Thickness | 15.88 | mm |
| -Outside diameter | 2.781 | m |
| -Total length | 16.94 | m |
| Dry weight | 85179 | kg |
| Operating weight | 331370 | kg |
| Flooded weight | 419388 | kg |
| Structure weight | 93420 | kg |
| FWH 6-D (6A, 6B) | | |
| Feedwater heater configuration: Includes desuperheating section, condensing section, drain cooler | | |
| Nameplate steam pressure | 22.24 | bar |
| Shell material | Carbon Steel | |
| Shell length | 11.65 | m |
| Shell inner diameter | 1.989 | m |
| Shell wall thickness | 25.4 | mm |
| Tube sheet thickness | 340 | mm |
| Nameplate water pressure | 309 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 821 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1642 | |
| Tube length per pass | 11.65 | m |
| Tube outer diameter (O.D.) | 22.22 | mm |
| Tube wall thickness | 3.81 | mm |
| Tube pitch | 32.23 | mm |
| Total heat transfer area (outside tubes) | 1,340 | m ² |
| Tube weight, dry | 35,000 | kg |
| Overall length | 14.7 | m |
| Overall outer diameter | 2 | m |
| Heater total dry weight | 93,400 | kg |
| Heater total operating (wet) weight | 98,700 | kg |
| FWH 7-D (7A, 7B) | | |
| Feedwater heater configuration: Includes condensing section, drain cooler | | |
| Nameplate steam pressure | 41.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 10.04 | m |
| Shell inner diameter | 1.928 | m |
| Shell wall thickness | 50.8 | mm |

| Estimated Feedwater Heater Data | | |
|---|--------------|----------------|
| Tube sheet thickness | 368 | mm |
| Nameplate water pressure | 308 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 1211 | |
| Number of passes | 2 | |
| Number of tubes in heater | 2422 | |
| Tube length per pass | 10.04 | m |
| Tube outer diameter (O.D.) | 19.05 | mm |
| Tube wall thickness | 3.404 | mm |
| Tube pitch | 25.72 | mm |
| Total heat transfer area (outside tubes) | 1,460 | m ² |
| Tube weight, dry | 34,240 | kg |
| Overall length | 13.2 | m |
| Overall outer diameter | 2 | m |
| Heater total dry weight | 102,250 | kg |
| Heater total operating (wet) weight | 106,800 | kg |
| FWH 8-D (8A, 8B) | | |
| Feedwater heater configuration: Includes desuperheating section, condensing section, drain cooler | | |
| Nameplate steam pressure | 62.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 12.2 | m |
| Shell inner diameter | 2.075 | m |
| Shell wall thickness | 76.2 | mm |
| Tube sheet thickness | 305 | mm |
| Nameplate water pressure | 307 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 893 | |
| Number of passes | 2 | |
| Number of tubes in heater | 1786 | |
| Tube length per pass | 12.2 | m |
| Tube outer diameter (O.D.) | 22.22 | mm |
| Tube wall thickness | 3.81 | mm |
| Tube pitch | 32.23 | mm |
| Total heat transfer area (outside tubes) | 1,520 | m ² |
| Tube weight, dry | 39,540 | kg |
| Overall length | 15.5 | m |
| Overall outer diameter | 2.2 | m |
| Heater total dry weight | 142,750 | kg |
| Heater total operating (wet) weight | 148,400 | kg |
| FWH 9-S (9A, 9B) | | |
| Feedwater heater configuration: Shell heating with vapor only fluid | | |
| Please Note: | | |
| Design based on condensing FWH methods - may be less accurate for single-phase fluid in shell | | |
| Nameplate steam pressure | 41.42 | bar |
| Shell material | Carbon Steel | |
| Shell length | 2.902 | m |
| Shell inner diameter | 1.466 | m |
| Shell wall thickness | 38.1 | mm |
| Tube sheet thickness | 279 | mm |
| Nameplate water pressure | 307 | bar |
| Tube material | Carbon Steel | |
| Number of tubes per pass | 1029 | |
| Number of passes | 1 | |
| Number of tubes in heater | 1029 | |
| Tube length per pass | 2.902 | m |
| Tube outer diameter (O.D.) | 22.22 | mm |
| Tube wall thickness | 4.191 | mm |
| Tube pitch | 30 | mm |
| Total heat transfer area (outside tubes) | 209 | m ² |
| Tube weight, dry | 6,630 | kg |
| Overall length | 6.5 | m |
| Overall outer diameter | 1.5 | m |
| Heater total dry weight | 40,550 | kg |
| Heater total operating (wet) weight | 42,090 | kg |

| Estimated Air Cooled Condenser Data | | |
|--|--------|-------------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| Dry air-cooled condenser | | |
| Total number of cells | | 64 |
| - Number of bays | | 8 |
| - Number of cells per bay | | 8 |
| 1. Overall Dimensions | | |
| Length | 104.9 | m |
| Width | 104.9 | m |
| Plot area | 10994 | m ² |
| 2. Cell Dimensions | | |
| Width | 13.11 | m |
| Height | 36.3 | m |
| Fan deck height | 26.53 | m |
| Steam duct outer diameter | 3.298 | m |
| Steam duct thickness | 10.65 | mm |
| Weight | 140583 | kg |
| 3. Fan Design (per fan) | | |
| Flow coefficient | 0.16 | |
| Static pressure rise coefficient | 0.054 | |
| Tip diameter | 10.12 | m |
| Hub diameter | 1.366 | m |
| RPM | 96.93 | |
| Tip speed | 51.36 | m/s |
| Static pressure drop at design point | 0.8245 | millibar |
| Dynamic pressure at design point | 0.3911 | millibar |
| Total fan DP at design point | 1.216 | millibar |
| Design volume flow | 648.7 | m ³ /s |
| Electricity consumption at design point | 109.6 | kW |

| Estimated Cooling Tower Data | | |
|--|--|---|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| | | |

| Estimated Flue Gas Treatment Data | | |
|--|------------|------------------------------------|
| Number of Units | | 1 |
| Displayed quantities in this table are on a per unit basis | | |
| ESP | | |
| Design collection efficiency | 99.5 | % |
| Design inlet temperature | 137.8 | C |
| Design flue gas mass flow | 2,650 | t/h |
| Design flue gas volume flow | 3,098,000 | m ³ /hr |
| Design flue gas velocity | 1.372 | m/s |
| Overall Dimensions | | |
| Number of chambers | 3 | |
| Number of fields | 4 | |
| Total length | 30.74 | m |
| Total width | 70.68 | m |
| Total height | 20.57 | m |
| Total weight | 1,961,000 | kg |
| Collecting Plates | | |
| Design specific collecting area (SCA) | 89.78 | m ² / m ³ /s |
| Total collection surface area | 77,250 | m ² |
| Number of plates per chamber | 64 | |
| Collecting plates height | 10.97 | m |
| Collecting plates spacing | 304.8 | mm |
| Collecting plates bundle width per chamber | 19.2 | m |
| Collecting plates depth per field | 4.656 | m |
| Collecting length | 18.62 | m |
| Aspect ratio (Collecting length / Plate height) | 1.697 | |
| 2. Stack | | |
| Type | Concrete | |
| Concrete Shell Diameter at Base Level | 17.77 | m |
| Concrete Shell Diameter at Top Level | 14.21 | m |
| Steel Liner Diameter | 7.714 | m |
| Height | 155.4 | m |
| Total Reference Cost (Installation included) | 11,294,000 | USD |

| Estimated Desalination Plant Data: MSF System | | |
|---|--|-----------------------|
| Multi-Stage Flash Desalination | | |
| 1. General | | |
| Number of units | | 1 |
| Number of stages per unit | | 21 |
| Number of stages in heat recovery section (HGS) | | 0 |
| Number of stages in heat rejection section (HRS) | | 0 |
| Nominal desalinated water flow per unit | | 0 t/h |
| Nominal desalinated water flow per unit (MIGD) | | 0 MIGD |
| Nominal desalinated water flow per unit (m ³ /day) | | 0 m ³ /day |
| 2. Overall dimensions and total weight (per unit, excluding seawater supply circuit) | | |
| Length | | 0 m |
| Width | | 0 m |
| Height | | 0 m |
| Dry weight | | 0 tonne |
| 3. Brine heater (per unit) | | |
| Tube material | | CuNi 70-30 |
| Heat transfer area | | 3,747 m ² |
| Tube outside diameter | | 38.1 mm |
| Tube wall thickness | | 1 mm |
| Tube length | | 15.24 m |
| Number of tubes | | 2054 |
| 4. Evaporator (per unit) | | |
| Length | | 0 m |
| Width | | 0 m |
| Height | | 0 m |
| Dry weight | | 0 tonne |
| HGS Stage Condensers | | |
| - Tube material | | CuNi 90-10 |
| - Heat transfer area per stage | | 3747 m ² |
| - HGS total heat transfer area | | 0 m ² |
| - Tube outside diameter | | 38.1 mm |
| - Tube wall thickness | | 1 mm |
| - Tube length | | 15.24 m |
| - Number of tubes per stage | | 2054 |
| HRS Stage Condensers | | |
| - Tube material | | Titanium |
| - Heat transfer area per stage | | 3122 m ² |
| - HRS total heat transfer area | | 0 m ² |
| - Tube outside diameter | | 31.75 mm |
| - Tube wall thickness | | 0.7 mm |
| - Tube length | | 15.24 m |
| - Number of tubes per stage | | 2054 |

| Estimated Desalination Plant Data: MED System | | |
|--|----------|---------------------|
| Multi-Effect Distillation | | |
| 1. General | | |
| Number of units | | 0 |
| Number of effects per unit | | 8 |
| System configuration | MED only | |
| First effect heating steam saturation temperature | -17.78 | C |
| Top brine temperature | -17.78 | C |
| Final effect temperature | -17.78 | C |
| Nameplate capacity | 0 | t/h |
| Nameplate capacity (MIGD) | 0 | MIGD |
| Nameplate capacity (m ³ /day) | 0 | m ³ /day |
| 2. Evaporator island (per unit, incl. main condenser) | | |
| Total heat transfer area | 0 | m ² |
| Length | 0 | m |
| Width | 0 | m |
| Height | 0 | m |
| Dry weight | 0 | tonne |
| Operating weight | 0 | tonne |
| 3. Evaporators (per unit) | | |
| Total heat transfer area | 0 | m ² |
| Number of effects | 8 | |
| Heat transfer area per effect | 0 | m ² |
| Number of tubes per effect | 0 | |
| Tube outside diameter | 0 | mm |
| Tube wall thickness | 0 | mm |
| Tube length | 0 | m |
| Tube material | Titanium | |
| Tube dry weight per effect | 0 | tonne |
| Total shell length of all effects | 0 | m |
| Shell outside diameter | 0 | m |
| Shell wall thickness | 0 | mm |
| Total tube dry weight | 0 | tonne |
| Total dry weight | 0 | tonne |
| Total operating weight | 0 | tonne |
| Total flooding weight | 0 | tonne |
| 4. Main condenser (per unit) | | |
| Overall length | 0 | m |
| Overall width | 0 | m |
| Overall height | 0 | m |
| Heat transfer area | 0 | m ² |
| Number of tubes | 0 | |
| Number of passes | 0 | |
| Tube outside diameter | 0 | mm |
| Tube wall thickness | 0 | mm |
| Tube length | 0 | m |
| Tube material | Titanium | |
| Tube dry weight | 0 | tonne |
| Total dry weight | 0 | tonne |
| Total operating weight | 0 | tonne |


| | | |
|---|----|---------------------|
| Estimated Desalination Plant Data: RO System | | |
| Reverse Osmosis Desalination | | |
| 1. Nameplate Data | | |
| Total number of RO trains in plant | 0 | |
| Desalinated water flow | 0 | t/h |
| Desalinated water flow (MIGD) | 0 | MIGD |
| Desalinated water flow (m ³ /day) | 0 | m ³ /day |
| Inlet water flow | 0 | t/h |
| Inlet water salinity | 0 | % |
| Water recovery ratio | 40 | % |
| Membrane feed pressure | 0 | bar |
| Total power consumption | 0 | kW |

| Estimated Miscellaneous Equipment Data | | |
|--|--------------|-------------|
| 1. Air Compressor | | |
| Number of Air Compressors in plant | 5 - 100% | |
| Capacity (each) | 1529.1 | m³/h |
| Motor Power (each) | 205 | kW |
| Weight (each) | 7,070 | kg |
| Installation Labor (each) | 230 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 156,400 | USD |
| Foundation Concrete (each) | 12.03 | m³ |
| Foundation Labor (each) | 450 | Labor Hours |
| 2. Auxiliary Boiler | | |
| None | | |
| 3. Emergency Generator | | |
| Number of Generators | 1 | |
| Generator Set Type | Medium Speed | |
| Capacity (each) | 1,750 | kW |
| Length | 9.9 | m |
| Width | 2.4 | m |
| Height | 3.3 | m |
| Weight | 34,750 | kg |
| Installation Labor (each) | 195 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 810,700 | USD |
| Foundation Concrete (each) | 57.84 | m³ |
| Foundation Labor (each) | 1,340 | Labor Hours |
| 4. Black Start Generator | | |
| Number of Generators | 5 | |
| Generator Set Type | Medium Speed | |
| Capacity (each) | 5,500 | kW |
| Length | 12.5 | m |
| Width | 2.5 | m |
| Height | 3.9 | m |
| Weight | 73,050 | kg |
| Installation Labor (each) | 195 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 2,548,000 | USD |
| Foundation Concrete (each) | 121 | m³ |
| Foundation Labor (each) | 2,400 | Labor Hours |
| 5. ST+Generator Lube Oil Fin Fan Cooler | | |
| Number of Cells (per plant) | 3 | |
| Capacity (each) | 822 | kW |
| Fan Power (each) | 48.47 | kW |
| Weight (each) | 5,080 | kg |
| Length (each) | 3.658 | m |
| Width (each) | 2.743 | m |
| Installation Labor (each) | 45.5 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 79,750 | USD |
| 6. ST Generator Fin Fan Cooler | | |
| Number of Cells (per plant) | 6 | |
| Capacity (each) | 860 | kW |
| Fan Power (each) | 48.47 | kW |
| Weight (each) | 5,310 | kg |
| Length (each) | 3.962 | m |
| Width (each) | 2.743 | m |
| Installation Labor (each) | 46.8 | Labor Hours |
| Equipment Cost, Reference Basis, (each) | 83,050 | USD |
| 7. Bridge Crane (for ST) | | |
| Number of Cranes in Plant | 1 | |
| Span | 38.1 | m |
| Capacity | 134 | Ton |
| Crane Weight | 286,300 | kg |
| Hoist Motor Power | 89.48 | kW |
| Bridge Motors | 2 - 6.338 | kW |
| Trolley Motor Power | 5.966 | kW |
| Installation Labor | 1,530 | Labor Hours |
| Crane & Support Cost, Reference Basis, (each) | 1,545,000 | USD |


| | | |
|--|---------------|------------------|
| Caution! These results are based on a single set of nameplate plant performance data applied for user-input number of operating hours per year. | | |
| Annual Electricity Exported | 5,260 | 10^6 kWh |
| Annual Heat Exported | 0 | TJ |
| Annual Fuel Imported | 45,510 | TJ LHV |
| Annual Water Imported | 0 | 10^6 l |
| Annual CO2 Emission | 4,210 | ktonne |
| Annual Desal Water Exported | 0 | MM imperial gal. |
| Annual Hydrogen Exported | 0 | TJ LHV |
| Annual Syngas Exported | 0 | TJ LHV |
| Annual CO2 Captured | 0 | ktonne |
| Annual Limestone Consumed | 0 | ktonne |
| Annual Lime Consumed | 0 | ktonne |
| Annual CO2 Capture Solvent Consumed | 0 | ktonne |
| Annual Combustion Waste Production | 157 | ktonne |
| Annual FGD Waste/Byproducts Production | 0 | ktonne |
| Annual Activated Carbon Consumed | 0 | ktonne |
| Total Investment | 1,664,412,000 | USD |
| Specific Investment | 2561.1 | USD per kW |
| Initial Equity | 499,324,000 | USD |
| Cumulative Net Cash Flow | 7,681,889,000 | USD |
| Internal Rate of Return on Investment (ROI) | 13.690 | % |
| Internal Rate of Return on Equity (ROE) | 22.547 | % |
| Years for Payback of Equity | 5.398 | years |
| Net Present Value | 1,013,126,000 | USD |
| Break-even Electricity Price @ Input Fuel Price (i.e. Levelised Cost of Electricity) | 0.0443 | USD/kWhr |
| Break-even Fuel LHV Price @ Input Electricity Price | 3.768 | USD/GJ |
| Other | | |
| First Year Combustion Waste Disposal Cost | 0 | USD/tonne |
| First Year FGD Waste/Byproducts Disposal Cost | 0 | USD/tonne |
| First Year Combustion Waste Disposal Expense | 0 | USD |
| First Year FGD Waste/Byproducts Disposal Expense | 0 | USD |
| First Year Total Other Expense | 0 | USD |

| Cash Flow USD | 2020 (1) | 2021 (2) | 2022 (3) | 2023 (4) | 2024 (5) | 2025 (6) | 2026 (7) | 2027 (8) | 2028 (9) | 2029 (10) | 2030 (11) | 2031 (12) | 2032 (13) | 2033 (14) | 2034 (15) | 2035 (16) | 2036 (17) | 2037 (18) | 2038 (19) | 2039 (20) |
|--|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| Escalators | | | | | | | | | | | | | | | | | | | | |
| Inflation | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Fuel | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Steam | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Electricity | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Imported Water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| H2 from syngas | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Reagent | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Activated carbon | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Prices | | | | | | | | | | | | | | | | | | | | |
| Electricity, USD per kWh | 0.065 | 0.0679 | 0.071 | 0.0742 | 0.0775 | 0.081 | 0.0846 | 0.0885 | 0.0924 | 0.0966 | 0.1009 | 0.1055 | 0.1102 | 0.1152 | 0.1204 | 0.1258 | 0.1315 | 0.1374 | 0.1436 | 0.15 |
| Fuel, USD/GJ | 1.37 | 1.432 | 1.496 | 1.563 | 1.634 | 1.707 | 1.784 | 1.864 | 1.948 | 2.036 | 2.128 | 2.223 | 2.323 | 2.428 | 2.537 | 2.651 | 2.771 | 2.895 | 3.026 | 3.162 |
| Steam, USD/GJ | 4.739 | 4.953 | 5.175 | 5.408 | 5.652 | 5.906 | 6.172 | 6.45 | 6.74 | 7.043 | 7.36 | 7.691 | 8.037 | 8.399 | 8.777 | 9.172 | 9.585 | 10.02 | 10.47 | 10.94 |
| Imported Water, USD/m^3 | 0.2642 | 0.2761 | 0.2885 | 0.3015 | 0.315 | 0.3292 | 0.344 | 0.3595 | 0.3757 | 0.3926 | 0.4103 | 0.4287 | 0.448 | 0.4682 | 0.4892 | 0.5112 | 0.5343 | 0.5583 | 0.5834 | 0.6097 |
| CO2 Emission Penalty, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water, USD per 1000 imperial gallons | 4 | 4.18 | 4.368 | 4.565 | 4.77 | 4.985 | 5.209 | 5.443 | 5.688 | 5.944 | 6.212 | 6.491 | 6.784 | 7.089 | 7.408 | 7.741 | 8.089 | 8.454 | 8.834 | 9.231 |
| H2 from syngas, USD/GJ | 7.583 | 7.924 | 8.281 | 8.653 | 9.043 | 9.45 | 9.875 | 10.32 | 10.78 | 11.27 | 11.78 | 12.31 | 12.86 | 13.44 | 14.04 | 14.68 | 15.34 | 16.03 | 16.75 | 17.5 |
| Syngas, USD/GJ | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Limestone, USD/tonne | 22.05 | 23.04 | 24.08 | 25.16 | 26.29 | 27.47 | 28.71 | 30 | 31.35 | 32.76 | 34.24 | 35.78 | 37.39 | 39.07 | 40.83 | 42.67 | 44.59 | 46.59 | 48.69 | 50.88 |
| Lime, USD/tonne | 88.18 | 92.15 | 96.3 | 100.6 | 105.2 | 109.9 | 114.8 | 120 | 125.4 | 131.1 | 136.9 | 143.1 | 149.6 | 156.3 | 163.3 | 170.7 | 178.3 | 186.4 | 194.8 | 203.5 |
| Captured CO2, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent, USD/tonne | 2204.6 | 2303.8 | 2407.5 | 2515.8 | 2629.1 | 2747.4 | 2871 | 3000 | 3135 | 3276 | 3424 | 3578 | 3739 | 3907 | 4083 | 4267 | 4459 | 4659 | 4869 | 5088 |
| Activated carbon, USD/tonne | 2204.6 | 2303.8 | 2407.5 | 2515.8 | 2629.1 | 2747.4 | 2871 | 3000 | 3135 | 3276 | 3424 | 3578 | 3739 | 3907 | 4083 | 4267 | 4459 | 4659 | 4869 | 5088 |
| Revenues | | | | | | | | | | | | | | | | | | | | |
| Electricity | 342,165,000 | 357,563,000 | 373,653,000 | 390,467,000 | 408,038,000 | 426,400,000 | 445,588,000 | 465,639,000 | 486,593,000 | 508,490,000 | 531,372,000 | 555,284,000 | 580,271,000 | 606,384,000 | 633,671,000 | 662,186,000 | 691,984,000 | 723,124,000 | 755,664,000 | 789,669,000 |
| Capacity | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Steam | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 from syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Captured CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 342,165,000 | 357,563,000 | 373,653,000 | 390,467,000 | 408,038,000 | 426,400,000 | 445,588,000 | 465,639,000 | 486,593,000 | 508,490,000 | 531,372,000 | 555,284,000 | 580,271,000 | 606,384,000 | 633,671,000 | 662,186,000 | 691,984,000 | 723,124,000 | 755,664,000 | 789,669,000 |
| Operating Expenses | | | | | | | | | | | | | | | | | | | | |
| Fuel | 62,351,000 | 65,157,000 | 68,089,000 | 71,153,000 | 74,355,000 | 77,701,000 | 81,197,000 | 84,851,000 | 88,669,000 | 92,660,000 | 96,829,000 | 101,187,000 | 105,740,000 | 110,498,000 | 115,471,000 | 120,667,000 | 126,097,000 | 131,771,000 | 137,701,000 | 143,898,000 |
| Limestone | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Lime | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Imported Water | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Activated carbon | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Other | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Inflating O&M | 57,580,000 | 60,171,000 | 62,879,000 | 65,708,000 | 68,665,000 | 71,755,000 | 74,984,000 | 78,358,000 | 81,884,000 | 85,569,000 | 89,420,000 | 93,444,000 | 97,649,000 | 102,043,000 | 106,635,000 | 111,433,000 | 116,448,000 | 121,688,000 | 127,164,000 | 132,886,000 |
| Book Value O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Constant O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 119,931,000 | 125,328,000 | 130,968,000 | 136,861,000 | 143,020,000 | 149,456,000 | 156,181,000 | 163,209,000 | 170,554,000 | 178,229,000 | 186,249,000 | 194,630,000 | 203,389,000 | 212,541,000 | 222,106,000 | 232,100,000 | 242,545,000 | 253,459,000 | 264,865,000 | 276,784,000 |
| Operating Income | 222,234,000 | 232,235,000 | 242,685,000 | 253,606,000 | 265,018,000 | 276,944,000 | 289,407,000 | 302,430,000 | 316,039,000 | 330,261,000 | 345,123,000 | 360,653,000 | 376,883,000 | 393,842,000 | 411,565,000 | 430,086,000 | 449,440,000 | 469,664,000 | 490,799,000 | 512,885,000 |
| -Depreciation | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 | 99,865,000 |
| -Deductible Interest Exp | 81,556,000 | 78,311,000 | 74,838,000 | 71,122,000 | 67,146,000 | 62,892,000 | 58,340,000 | 53,470,000 | 48,258,000 | 42,682,000 | 36,715,000 | 30,331,000 | 23,499,000 | 16,190,000 | 8,369,000 | 0 | 0 | 0 | 0 | 0 |
| Pre-Tax Income | 40,813,000 | 54,059,000 | 67,982,000 | 82,619,000 | 98,007,000 | 114,187,000 | 131,202,000 | 149,096,000 | 167,917,000 | 187,715,000 | 208,543,000 | 230,458,000 | 253,519,000 | 277,788,000 | 303,332,000 | 430,086,000 | 449,440,000 | 469,664,000 | 490,799,000 | 512,885,000 |
| -Tax | 14,285,000 | 18,921,000 | 23,794,000 | 28,917,000 | 34,303,000 | 39,966,000 | 45,921,000 | 52,183,000 | 58,771,000 | 65,700,000 | 72,990,000 | 80,660,000 | 88,732,000 | 97,226,000 | 106,166,000 | 150,530,000 | 157,304,000 | 164,383,000 | 171,780,000 | 179,510,000 |
| -Non-Deductible Interest Exp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Net Income | 26,529,000 | 35,139,000 | 44,189,000 | 53,702,000 | 63,705,000 | 74,222,000 | 85,281,000 | 96,912,000 | 109,146,000 | 122,015,000 | 135,553,000 | 149,798,000 | 164,787,000 | 180,562,000 | 197,166,000 | 279,556,000 | 292,136,000 | 305,282,000 | 319,020,000 | 333,375,000 |
| Debt Principal Payment | 46,364,000 | 49,610,000 | 53,082,000 | 56,798,000 | 60,774,000 | 65,028,000 | 69,580,000 | 74,451,000 | 79,662,000 | 85,239,000 | 91,205,000 | 97,590,000 | 104,421,000 | 111,731,000 | 119,552,000 | 0 | 0 | 0 | 0 | 0 |
| Debt Coverage | 1.74 | 1.82 | 1.9 | 1.98 | 2.07 | 2.16 | 2.26 | 2.36 | 2.47 | 2.58 | 2.7 | 2.82 | 2.95 | 3.08 | 3.22 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Net Cash Flow | 80,029,000 | 85,393,000 | 90,971,000 | 96,769,000 | 102,795,000 | 109,058,000 | 115,566,000 | 122,326,000 | 129,348,000 | 136,641,000 | 144,212,000 | 152,073,000 | 160,231,000 | 168,696,000 | 177,479,000 | 279,556,000 | 292,136,000 | 305,282,000 | 319,020,000 | 333,375,000 |
| Cumulative Net Cash Flow | 80,029,000 | 165,423,000 | 256,393,000 | 353,162,000 | 455,958,000 | 565,016,000 | 680,582,000 | 802,908,000 | 932,256,000 | 1,068,896,000 | 1,213,109,000 | 1,365,181,000 | 1,525,412,000 | 1,694,108,000 | 1,871,587,000 | | | | | |

| Cash Flow USD | 2040 (21) | 2041 (22) | 2042 (23) | 2043 (24) | 2044 (25) | 2045 (26) | 2046 (27) | 2047 (28) | 2048 (29) | 2049 (30) |
|--|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| Escalators | | | | | | | | | | |
| Inflation | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Fuel | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Steam | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Electricity | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Imported Water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| H2 from syngas | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Reagent | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Activated carbon | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 | 0.045 |
| Prices | | | | | | | | | | |
| Electricity, USD per kWh | 0.1568 | 0.1638 | 0.1712 | 0.1789 | 0.1869 | 0.1954 | 0.2041 | 0.2133 | 0.2229 | 0.233 |
| Fuel, USD/GJ | 3.304 | 3.453 | 3.608 | 3.77 | 3.94 | 4.117 | 4.303 | 4.496 | 4.699 | 4.91 |
| Steam, USD/GJ | 11.43 | 11.94 | 12.48 | 13.04 | 13.63 | 14.24 | 14.88 | 15.55 | 16.25 | 16.99 |
| Imported Water, USD/m^3 | 0.6371 | 0.6658 | 0.6957 | 0.727 | 0.7598 | 0.794 | 0.8297 | 0.867 | 0.906 | 0.9468 |
| CO2 Emission Penalty, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water, USD per 1000 imperial gallons | 9.647 | 10.08 | 10.53 | 11.01 | 11.5 | 12.02 | 12.56 | 13.13 | 13.72 | 14.34 |
| H2 from syngas, USD/GJ | 18.29 | 19.11 | 19.97 | 20.87 | 21.81 | 22.79 | 23.82 | 24.89 | 26.01 | 27.18 |
| Syngas, USD/GJ | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Limestone, USD/tonne | 53.17 | 55.56 | 58.06 | 60.67 | 63.41 | 66.26 | 69.24 | 72.36 | 75.61 | 79.01 |
| Lime, USD/tonne | 212.7 | 222.2 | 232.2 | 242.7 | 253.6 | 265 | 277 | 289.4 | 302.4 | 316.1 |
| Captured CO2, USD/tonne | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent, USD/tonne | 5317 | 5556 | 5806 | 6067 | 6341 | 6626 | 6924 | 7236 | 7561 | 7901 |
| Activated carbon, USD/tonne | 5317 | 5556 | 5806 | 6067 | 6341 | 6626 | 6924 | 7236 | 7561 | 7901 |
| Revenues | | | | | | | | | | |
| Electricity | 825,204,000 | 862,339,000 | 901,144,000 | 941,695,000 | 984,072,000 | 1,028,355,000 | 1,074,631,000 | 1,122,989,000 | 1,173,524,000 | 1,226,332,000 |
| Capacity | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Steam | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Desal water | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| H2 from syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Syngas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Captured CO2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 825,204,000 | 862,339,000 | 901,144,000 | 941,695,000 | 984,072,000 | 1,028,355,000 | 1,074,631,000 | 1,122,989,000 | 1,173,524,000 | 1,226,332,000 |
| Operating Expenses | | | | | | | | | | |
| Fuel | 150,373,000 | 157,140,000 | 164,211,000 | 171,600,000 | 179,322,000 | 187,392,000 | 195,825,000 | 204,637,000 | 213,845,000 | 223,468,000 |
| Limestone | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Lime | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 capture solvent | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Imported Water | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CO2 Emission Penalty | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Activated carbon | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Other | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Inflating O&M | 138,866,000 | 145,115,000 | 151,645,000 | 158,470,000 | 165,601,000 | 173,053,000 | 180,840,000 | 188,978,000 | 197,482,000 | 206,369,000 |
| Book Value O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Constant O&M | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| TOTAL | 289,239,000 | 302,255,000 | 315,856,000 | 330,070,000 | 344,923,000 | 360,445,000 | 376,665,000 | 393,615,000 | 411,327,000 | 429,837,000 |
| Operating Income | 535,965,000 | 560,084,000 | 585,287,000 | 611,625,000 | 639,148,000 | 667,910,000 | 697,966,000 | 729,375,000 | 762,196,000 | 796,495,000 |
| -Depreciation | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| -Deductible Interest Exp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Pre-Tax Income | 535,965,000 | 560,084,000 | 585,287,000 | 611,625,000 | 639,148,000 | 667,910,000 | 697,966,000 | 729,375,000 | 762,196,000 | 796,495,000 |
| -Tax | 187,588,000 | 196,029,000 | 204,851,000 | 214,069,000 | 223,702,000 | 233,769,000 | 244,288,000 | 255,281,000 | 266,769,000 | 278,773,000 |
| -Non-Deductible Interest Exp | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Net Income | 348,377,000 | 364,054,000 | 380,437,000 | 397,556,000 | 415,447,000 | 434,142,000 | 453,678,000 | 474,093,000 | 495,428,000 | 517,722,000 |
| Debt Principal Payment | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Debt Coverage | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| Net Cash Flow | 348,377,000 | 364,054,000 | 380,437,000 | 397,556,000 | 415,447,000 | 434,142,000 | 453,678,000 | 474,093,000 | 495,428,000 | 517,722,000 |
| Cumulative Net Cash Flow | 3,749,332,000 | 4,113,387,000 | 4,493,823,000 | 4,891,380,000 | 5,306,826,000 | 5,740,968,000 | 6,194,646,000 | 6,668,739,000 | 7,164,167,000 | 7,681,889,000 |




| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Site Plan |
| | |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |





| | | | | | | | | | |
|---|---------|---|---|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| - | 18.99 m | - | - | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | BOILER |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |



| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | BOILER |
| | ELEVATION VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |









| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 20.81 m | 18.41 m | 0.7642 m | 1.575 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 1-P |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| A | B | C | D | E | F | G | H | I | J |
|---------|---------|----------|---------|---|---|---|---|---|---|
| 22.16 m | 19.54 m | 0.8511 m | 1.703 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 2-D |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| | | | | | | | | | |
|---------|--------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 19.63 m | 17.1 m | 0.8594 m | 1.611 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 3-D |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| | | | | | | | | | |
|--------|---------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 17.8 m | 15.25 m | 0.8696 m | 1.632 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 4-D |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |











| | | | | | | | | | |
|---------|---------|----------|--------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 13.16 m | 10.04 m | 0.7181 m | 2.03 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 7-D (7A, 7B) |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |



















| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | STEAM HEATED DEAERATOR |
| | ELEVATION VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |

| | | | | | | | | | |
|---------|---------|---------|---------|---------|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 16.94 m | 7.963 m | 2.781 m | 4.572 m | 18.75 m | - | - | - | - | - |


FOR QUALITATIVE INDICATION ONLY





| | | | | | | | | | |
|---------|---------|----------|--------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 13.16 m | 10.04 m | 0.7181 m | 2.03 m | - | - | - | - | - | - |


| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 7-D (7A, 7B) |
| | SIDE ELEVATION VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |





FOR QUALITATIVE INDICATION ONLY

| | | | | | | | | | |
|---------|--------|----------|---------|---|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I | J |
| 15.47 m | 12.2 m | 0.7343 m | 2.227 m | - | - | - | - | - | - |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH 8-D (8A, 8B) |
| | SIDE ELEVATION VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |








| A | B | C | D | E | F | G | H | I | J |
|---------|---------|---------|---------|---------|---------|---------|---------|---|---|
| 13.11 m | 104.9 m | 9.768 m | 26.53 m | 13.11 m | 10.12 m | 104.9 m | 3.298 m | - | - |


| | |
|------------------|--------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | DRY AIR-COOLED CONDENSER |
| | ELEV |
| Date: 04/21/17 | |
| Drawing No: | |
| | |



| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2131.5 t/h |
| Nameplate head | 3155 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 3170 m |
| Nameplate RPM | 3000 |
| Design flow | 1918.4 t/h |
| Design head | 3332 m |
| Design RPM | 3000 |


| | |
|------------------|-----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Pump (P1) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |

Boiler Feed Booster Pump (P3)




| | |
|--------------------------|------------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 2131.5 t/h |
| Nameplate head | 81.81 m |
| Nameplate flow (nominal) | 41640 lpm |
| Nameplate head (nominal) | 83.82 m |
| Nameplate RPM | 600 |
| Design flow | 1918.4 t/h |
| Design head | 87.01 m |
| Design RPM | 600 |
| Minimum continuous flow | 319.7 t/h |
| Maximum continuous flow | 2877.6 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Boiler Feed Booster Pump (P3) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|------------|
| No. per ST | 2 |
| No. operating per ST | 1 |
| Nameplate flow | 1383.9 t/h |
| Nameplate head | 237.6 m |
| Nameplate flow (nominal) | 24605 lpm |
| Nameplate head (nominal) | 243.8 m |
| Nameplate RPM | 750 |
| Design flow | 1245.5 t/h |
| Design head | 213.9 m |
| Design RPM | 750 |
| Minimum continuous flow | 207.6 t/h |
| Maximum continuous flow | 1868.2 t/h |

| | |
|------------------|---------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Condensate Forwarding Pump (P6) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|------------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 111.5 t/h |
| Nameplate head | 45.81 m |
| Nameplate flow (nominal) | 2271.2 lpm |
| Nameplate head (nominal) | 53.34 m |
| Nameplate RPM | 3000 |
| Design flow | 89.21 t/h |
| Design head | 45.81 m |
| Design RPM | 3000 |
| Minimum continuous flow | 22.3 t/h |
| Maximum continuous flow | 133.8 t/h |

| | |
|------------------|------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Fuel Oil Unloading Pump (P8) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|-----------|
| No. per Plant | 2 |
| No. operating per Plant | 1 |
| Nameplate flow | 41.48 t/h |
| Nameplate head | 38.17 m |
| Nameplate flow (nominal) | 851.7 lpm |
| Nameplate head (nominal) | 45.72 m |
| Nameplate RPM | 3000 |
| Design flow | 33.18 t/h |
| Design head | 30.54 m |
| Design RPM | 3000 |
| Minimum continuous flow | 8.296 t/h |
| Maximum continuous flow | 49.78 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Fuel Oil Forwarding Pump (P9) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.89 t/h |
| Nameplate head | 57.55 m |
| Nameplate flow (nominal) | 416.4 lpm |
| Nameplate head (nominal) | 60.96 m |
| Nameplate RPM | 3000 |
| Design flow | 16.03 t/h |
| Design head | 43.16 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.579 t/h |
| Maximum continuous flow | 27.47 t/h |

| | |
|------------------|--------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Treated Water Pump (P11) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 10.25 t/h |
| Nameplate head | 30.54 m |
| Nameplate flow (nominal) | 170.3 lpm |
| Nameplate head (nominal) | 38.1 m |
| Nameplate RPM | 3000 |
| Design flow | 10.25 t/h |
| Design head | 30.54 m |
| Design RPM | 3000 |
| Minimum continuous flow | 2.051 t/h |
| Maximum continuous flow | 12.31 t/h |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Jockey Fire Pump (P14) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |



| | |
|--------------------------------|-----------|
| No. per ST+Generator Lube Oi | 2 |
| No. operating per ST+Generator | 1 |
| Nameplate flow | 169.7 t/h |
| Nameplate head | 30.54 m |
| Nameplate flow (nominal) | 3028 lpm |
| Nameplate head (nominal) | 38.1 m |
| Nameplate RPM | 3000 |
| Design flow | 169.7 t/h |
| Design head | 30.54 m |
| Design RPM | 3000 |
| Minimum continuous flow | 33.95 t/h |
| Maximum continuous flow | 203.7 t/h |


| | |
|------------------|--|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | ST+Generator Lube Oil Coolant Pump (P21) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |



| | |
|--------------------------------|-----------|
| No. per ST Generator | 2 |
| No. operating per ST Generator | 1 |
| Nameplate flow | 355.1 t/h |
| Nameplate head | 30.54 m |
| Nameplate flow (nominal) | 6624 lpm |
| Nameplate head (nominal) | 38.1 m |
| Nameplate RPM | 1500 |
| Design flow | 355.1 t/h |
| Design head | 30.54 m |
| Design RPM | 1500 |
| Minimum continuous flow | 71.02 t/h |
| Maximum continuous flow | 426.1 t/h |


| | |
|------------------|---------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | ST Generator Coolant Pump (P22) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |

Demin Water Pump (P23)




| | |
|--------------------------|-----------|
| No. per Plant | 2 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.89 t/h |
| Nameplate head | 55.24 m |
| Nameplate flow (nominal) | 416.4 lpm |
| Nameplate head (nominal) | 60.96 m |
| Nameplate RPM | 3000 |
| Design flow | 16.03 t/h |
| Design head | 44.2 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.579 t/h |
| Maximum continuous flow | 27.47 t/h |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Demin Water Pump (P23) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.89 t/h |
| Nameplate head | 46.04 m |
| Nameplate flow (nominal) | 416.4 lpm |
| Nameplate head (nominal) | 53.34 m |
| Nameplate RPM | 3000 |
| Design flow | 16.03 t/h |
| Design head | 34.53 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.579 t/h |
| Maximum continuous flow | 27.47 t/h |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Raw Water Pump 1 (P26) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| | |
|--------------------------|-----------|
| No. per Plant | 1 |
| No. operating per Plant | 1 |
| Nameplate flow | 22.89 t/h |
| Nameplate head | 46.04 m |
| Nameplate flow (nominal) | 416.4 lpm |
| Nameplate head (nominal) | 53.34 m |
| Nameplate RPM | 3000 |
| Design flow | 16.03 t/h |
| Design head | 36.83 m |
| Design RPM | 3000 |
| Minimum continuous flow | 4.579 t/h |
| Maximum continuous flow | 27.47 t/h |

| | |
|------------------|------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Raw Water Pump 2 (P27) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| | |
|--------------------------|-----------|
| No. per Boiler | 1 |
| No. operating per Boiler | 1 |
| Nameplate flow | 532.9 t/h |
| Nameplate head | 3335 m |
| Nameplate flow (nominal) | 10410 lpm |
| Nameplate head (nominal) | 3353 m |
| Nameplate RPM | 3000 |
| Design flow | 532.9 t/h |
| Design head | 3335 m |
| Design RPM | 3000 |
| Minimum continuous flow | 106.6 t/h |
| Maximum continuous flow | 692.7 t/h |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | Startup Boiler Feed Pump (P2) |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|--------------|----------|---------------|----------|
| HPO x 1 | 457.2 mm | 172.5 m | Custom | TP347HFG | 280.1 bar | 606 C | 1918.4 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | HP PIPING |
| | DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|-------------|------------|---------------|----------|
| CRHO x 1 | 730.3 mm | 181.1 m | Custom | P-22 | 64.3 bar | 374.5 C | 1740.2 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | RH PIPING |
| | DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|-------------|------------|---------------|----------|
| HRHO x 1 | 812.8 mm | 189.9 m | Custom | TP347HFG | 61.2 bar | 605.4 C | 1740.2 t/h | lpm |

| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | RH PIPING |
| | DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FWHHS1 x 1 | 762 | 10.67 | 10 | A-106 | 0.4907 | 80.88 | 59.99 | |
| FWHHS2 x 1 | 609.6 | 21.34 | 40 | A-106 | 1.38 | 127.6 | 66.09 | |
| FWHHS3 x 1 | 457.2 | 32 | 40 | A-106 | 3.309 | 212.4 | 70.11 | |
| FWHHS4 x 1 | 406.4 | 42.67 | 40 | A-106 | 7 | 296.5 | 73.38 | |
| FWHHS5 x 1 | 406.4 | 103 | 40 | A-106 | 13.04 | 375.4 | 76.74 | |
| FWHHS6 x 2 | 203.2 | 37.19 | 40 | P-11 | 22.9 | 454.3 | 32.89 | |
| FWHHS8 x 2 | 203.2 | 47.85 | 60 | P-22 | 64.3 | 374.5 | 66.21 | |
| FWHHS9 x 2 | 203.2 | 53.04 | 60 | P-91 | 42.67 | 549.8 | 61.58 | |
| | mm | m | | | bar | C | t/h | lpm |

| | |
|------------------|---|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FWH HEATING STEAM PIPING DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|-------------|------------|----------|----------|----------|------------|--------------|----------|
| FPTMS1 x 1 | 609.6 mm | 71.02 m | 40 | A-106 | 7 bar | 296.5 C | 147.3 t/h | lpm |

| | |
|------------------|---------------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | OTHER HEATING STEAM PIPING DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FW1 x 1 | 457.2 | 300.8 | 20 | A-106 | 21.15 | 47.85 | 1245.5 | 20969 |
| FWFW1 x 1 | 508 | 23.47 | 20 | A-106 | 19.34 | 76.9 | 1245.5 | 21303 |
| FWFW2 x 1 | 609.6 | 24.99 | 20 | A-106 | 17.59 | 104.7 | 1520.3 | 26517 |
| FWFW3 x 1 | 609.6 | 22.25 | 20 | A-106 | 16.14 | 132.4 | 1520.3 | 27152 |
| FWFW4 x 1 | 609.6 | 103 | 20 | A-106 | 14.9 | 160.2 | 1520.3 | 27918 |
| FWFW5 x 1 | 609.6 | 103 | 20 | A-106 | 12.66 | 190.4 | 1918.4 | 36418 |
| FWFW6 x 2 | 412.8 | 16.76 | Custom | A-106 | 308 | 220.1 | 959.2 | 18517 |
| FWFW7 x 2 | 425.5 | 14.94 | Custom | A-106 | 307.4 | 250.7 | 959.2 | 19362 |
| FWFW8 x 2 | 431.8 | 17.68 | Custom | A-106 | 306.8 | 279.9 | 959.2 | 20379 |
| FWFW9 x 2 | 438.2 | 7.62 | Custom | A-106 | 306.7 | 287.7 | 959.2 | 20699 |
| FW3 x 1 | 622.3 | 176.5 | Custom | A-106 | 306.7 | 287.7 | 1918.4 | 41397 |
| | mm | m | | | bar | C | t/h | lpm |


| | |
|------------------|-------------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FEEDWATER PIPING DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |




| ID & # OFF | DIAMETER | LENGTH | SCHEDULE | MATERIAL | DESIGN P | DESIGN T | DESIGN M | DESIGN Q |
|------------|----------|--------|----------|----------|----------|----------|----------|----------|
| FP0 x 1 | 508 | 1073.2 | 20 | A-106 | 6.895 | 15 | 1362 | 22712 |
| FP1 x 1 | 406.4 | 1073.2 | 20 | A-106 | 6.895 | 15 | 681 | 11356 |
| | mm | m | | | bar | C | t/h | lpm |

| | |
|------------------|-------------------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | FIRE PROTECTION PIPING |
| | DIAGRAM |
| Date: 04/21/17 | |
| Drawing No: | |
| | |








| | |
|------------------|----------------------|
| Thermoflow, Inc. | Company: GHD Pty Ltd |
| | User: GHD |
| | ESP |
| | PLAN VIEW |
| Date: 04/21/17 | |
| Drawing No: | |
| | |

| | | | | | | | | |
|---------|---------|--------|---------|---|---|---|---|---|
| A | B | C | D | E | F | G | H | I |
| 30.74 m | 70.68 m | 19.2 m | 4.656 m | - | - | - | - | - |

FOR QUALITATIVE INDICATION ONLY



Appendix C – Benchmarking Details

Ultra - Super Critical Power Stations (HELE)

GHD compilation of publicly available data and comparison to ThermoFlow™ PEACE estimates

| Publicly available plant details | | | | | | | | | | | | | | | | | PEACE estimate | | |
|---|-------------|----------------|---------|-----------------|-------------------|-------------------------|---------------|-----------------------|-------------|---------------------------------|--------------------|-----------------------------------|----------------------|--|------------------|----------------|--------------------------|----------------|--|
| Plant Name | Location | Unit size (MW) | # units | Plant size (MW) | Year of Operation | Reference year for cost | PPI used | PPI in reference year | PPI in 2016 | Reported cost in reference year | Reported cost unit | Reported cost escalated using PPI | Exchange rate used | Exch. rate at April 2017 (USD per 1 native currency) | Cost in 2016 USD | USD million/MW | Plant cost (USD million) | USD million/MW | Benchmark project deviation from PEACE |
| Linkou | Taiwan | 800 | 3 | 2,400 | 2016/2017/2021 | 2011 | Taiwan | 100 | 105 | \$152,500 M | NTD | \$160,125 M | New Taiwan \$ to USD | 0.033 | \$5,284 M | \$2.2 | \$3,680 | 1.5 | 44% |
| Talin | Taiwan | 800 | 2 | 1,600 | 2016/2017 | 2011 | Taiwan | 100 | 105 | \$119,200 M | NTD | \$125,160 M | New Taiwan \$ to USD | 0.033 | \$4,130 M | \$2.6 | \$2,510 | 1.6 | 65% |
| Shenao | Taiwan | 800 | 2 | 1,600 | 2018/2019 | 2011 | Taiwan | 100 | 105 | \$108,900 M | NTD | \$114,345 M | New Taiwan \$ to USD | 0.033 | \$3,773 M | \$2.4 | \$2,510 | 1.6 | 50% |
| Maasvlakte 3 | Netherlands | 1,100 | 1 | 1,100 | 2015 | 2012 | Netherlands | 115 | 99 | \$1,200 M | Euro | \$1,036 M | Euro to USD | 1.06 | \$1,098 M | \$1.0 | \$1,920 | 1.7 | -43% |
| Mannheim | Germany | 912 | 1 | 912 | 2015 | 2015 | Germany | 105 | 104 | \$1,200 M | Euro | \$1,192 M | Euro to USD | 1.06 | \$1,263 M | \$1.4 | \$1,670 | 1.8 | -24% |
| Wai Gao Qiao 3 | China | 1,000 | 2 | 2,000 | 2008 | 2008 | China | 93 | 94 | \$8,500 M | Yuan | \$8,637 M | Yuan to USD | 0.15 | \$1,296 M | \$0.6 | \$2,280 | 1.1 | -43% |
| Westfalen D and E | Germany | 800 | 2 | 1,600 | 2012/2014 | 2012 | Germany | 105 | 104 | \$2,400 M | Euro | \$2,384 M | Euro to USD | 1.06 | \$2,527 M | \$1.6 | \$2,840 | 1.8 | -11% |
| John W. Turk, Jr. | America | 600 | 1 | 600 | 2012/2013 | 2012 | United States | 110 | 104 | \$1,800 M | USD | \$1,695 M | N/A | 1 | \$1,695 M | \$2.8 | \$1,060 | 1.8 | 60% |
| Hualbei Pingshan | China | 660 | 2 | 1,320 | 2015/2016 | 2015 | China | 90 | 94 | \$5,000 M | Yuan | \$5,274 M | Yuan to USD | 0.15 | \$791 M | \$0.6 | \$1,630 | 1.2 | -51% |
| Eemshaven | Netherlands | 800 | 2 | 1,600 | 2015 | 2014 | Netherlands | 111 | 99 | \$2,200 M | Euro | \$1,968 M | Euro to USD | 1.06 | \$2,086 M | \$1.3 | \$2,800 | 1.8 | -26% |
| Safi | Morocco | 693 | 2 | 1,386 | 2018 | 2014 | Morocco | 110 | 102 | \$2,600 M | USD | \$2,411 M | N/A | 1 | \$2,411 M | \$1.7 | \$2,000 | 1.4 | 21% |
| Tanjung Bin Energy | Malaysia | 1,000 | 1 | 1,000 | 2016 | 2016 | Malaysia | 100 | 100 | \$1,000 M | Euro | \$1,000 M | Euro to USD | 1.06 | \$1,060 M | \$1.1 | \$1,510 | 1.5 | -30% |
| Chugoku Electric | Malaysia | 1,000 | 2 | 2,000 | 2018 | 2014 | Malaysia | 112 | 100 | \$360,000 M | Yen | \$321,429 M | Yen to USD | 0.00920 | \$2,957 M | \$1.5 | \$2,860 | 1.4 | 3% |
| Manjung Unit 4 | Malaysia | 1,000 | 1 | 1,000 | 2015 | 2012 | Malaysia | 113 | 100 | \$1,000 M | Euro | \$885 M | Euro to USD | 1.06 | \$938 M | \$0.9 | \$1,510 | 1.5 | -38% |
| Lunen | Germany | 820 | 1 | 820 | 2013 | 2013 | Germany | 105 | 104 | \$1,400 M | Euro | \$1,385 M | Euro to USD | 1.06 | \$1,468 M | \$1.8 | \$1,530 | 1.9 | -4% |
| Moorburg | Germany | 820 | 2 | 1,640 | 2014 | 2014 | Germany | 105 | 104 | \$2,800 M | Euro | \$2,779 M | Euro to USD | 1.06 | \$2,945 M | \$1.8 | \$2,900 | 1.8 | 2% |
| Yuhuan | China | 1,000 | 4 | 4,000 | 2006/2007 | 2007 | China | 94 | 94 | \$14,500 M | Yuan | \$14,577 M | Yuan to USD | 0.15 | \$2,187 M | \$0.5 | \$4,400 | 1.1 | -50% |
| Kogan Creek (SC only) | Australia | 750 | 1 | 750 | 2007 | 2007 | Australia | 88 | 106 | \$1,200 M | AUD | \$1,445 M | AUD to USD | 0.75 | \$1,084 M | \$1.4 | \$1,330 | 1.8 | -18% |
| Tanjung Jati B (recently announced, not yet under construction) | Indonesia | 1,000 | 2 | 2,000 | 2019/2020 | 2016 | N/A | - | - | \$500,000 M | Yen | \$500,000 M | Yen to USD | 0.00920 | \$4,600 M | \$2.3 | \$3,130 | 1.6 | 47% |

GHD

145 Ann Street Brisbane QLD 4000
GPO Box 668 Brisbane QLD 4001
T: (07) 3316 3000 F: (07) 3316 3333 E: bnemail@ghd.com

© GHD 2017

This document is and shall remain the property of GHD. The document may only be used for the purpose for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

G:\41\30763\WP\478110.docx

Document Status

| Revision | Author | Reviewer | | Approved for Issue | | |
|----------|----------|-----------|-------------------|--------------------|-------------------|---------|
| | | Name | Signature | Name | Signature | Date |
| 0 | D Baptie | P Wootton | <i>P Wootton</i> | S Bond | <i>S Bond</i> | 1/6/17 |
| 1 | D Baptie | P Wootton | <i>P Wootton</i> | S Bond | <i>S Bond</i> | 2/6/17 |
| 2 | D Baptie | P Wootton | <i>P. Wootton</i> | S Bond | <i>P. Wootton</i> | 23/6/17 |

www.ghd.com

